



MGM INSTITUTE OF HEALTH SCIENCES
CENTRAL PURCHASE DEPARTMENT (CPD)
Plot 1 &2, Sector -1 Kamothe, Navi Mumbai 410209

E-Tender for Synchronization Panel

Tenders invited from reputed manufactures or their authorised distributors / dealers of Synchronization Panel for MGM Hospital, Kamothe in the format given below:

Name & Address of Vendor: _____

Sr. No.	Discription	In	QTY	Rate Per Item Group (Excluding GST)	GST %
A. SUBSTATION MAIN LT SYNCHRONIZING PANEL					
1	DG INCOMER -1 SYNCHRONIZING BREAKER				
	SANDWICH TYPE BUS FROM DG MAIN I/C - 1 SYNCH TO O/G DG SYNCH - 1 (AS PER SITE LOCATION DESING)				
	MAKE - SIEMENS POLE, In-5000A, EDO TYPE, 230V CONTROL SUPPLY, 65KA, UV -415VAC CLOSING COIL - 230V , TRIPING COIL 230VAC, MICROLOGIC6.0 P, O/C, SC, G/F AND INST TNC , AUTO/MANUAL SELECTOR SWITCH, Multifunction Meter, ON, OFF AND TRIP, R ,Y & B INDICATOR WITH INTERLOCKING WITH SYNCHRONIZING CONTROLLER AND PROTECTION NUMARICALRELAY	5000A	1		
2	DG INCOMER -2 SYNCHRONIZING BREAKER				
	SANDWICH TYPE BUS FROM DG MAIN I/C - 2 SYNCH TO O/G DG SYNCH -2 (AS PER SITE LOCATION DESING)				

Sr. No.	Discription	In	QTY	Rate Per Item Group (Excluding GST)	GST %
	MAKE - SIEMENS 4 POLE, In-5000A, EDO TYPE, 230V CONTROL SUPPLY, 65KA, UV -415VAC CLOSING COIL - 230V , TRIPING COIL- 230VAC, MICROLOGIC6.0 P, O/C, SC, G/F AND INST TNC , AUTO/MANUAL SELECTOR SWITCH, Multifunction Meter, ON, OFF AND TRIP, R ,Y & B INDICATOR WITH INTERLOCKING WITH SYNCHRONIZING CONTROLLER AND PROTECTION NUMARICALRELAY	5000A	1		
3	BUSCOUPLER				
	MAKE - SIEMENS 4 POLE, In-5000A, EDO TYPE, 230V CONTROL SUPPLY, 65KA, UV -415VAC CLOSING COIL - 230V , TRIPING COIL- 230VAC, MICROLOGIC6.0 P, O/C, SC, G/F AND INST TNC , AUTO/MANUAL SELECTOR SWITCH, ON, OFF AND TRIP INDICATOR . WITH INTERLOCKING MAIN DG SYNCH - 1 AND MAIN DG SYNCH - 2	5000A	1		
4	INCOMER - 1 1010 KVA DG SET TO MAIN SYNCH PANEL -1				
	MAKE - SIEMENS 3 POLE, In-1600A, EDO TYPE, 230V CONTROL SUPPLY, 55KA, UV -415VAC CLOSING COIL - 230V , TRIPING COIL- 230VAC, MICROLOGIC6.0 P, O/C, SC, G/F AND INST TNC , AUTO/MANUAL SELECTOR SWITCH, Multifunction Meter, ON, OFF AND TRIP, R ,Y & B INDICATOR.	1600A	1		
5	INCOMER - 3 500 KVA DG SET TO MAIN SYNCH PANEL -1				
	MAKE - SIEMENS 3 POLE, In-1600A, EDO TYPE, 230V CONTROL SUPPLY, 55KA, UV -415VAC CLOSING COIL - 230V , TRIPING COIL- 230VAC, MICROLOGIC6.0 P, O/C, SC, G/F AND INST TNC , AUTO/MANUAL SELECTOR SWITCH, Multifunction Meter, ON, OFF AND TRIP, R ,Y & B INDICATOR.	1600A	1		

Sr. No.	Discription	In	QTY	Rate Per Item Group (Excluding GST)	GST %
6	INCOMER - 3 500 KVA DG SET TO MAIN SYNCH PANEL -1 (SPARE FEEDER)				
	MAKE - SIEMENS 3 POLE, In-1600A, EDO TYPE, 230V CONTROL SUPPLY, 55KA, UV -415VAC CLOSING COIL - 230V , TRIPING COIL- 230VAC, MICROLOGIC6.0 P, O/C, SC, G/F AND INST TNC , AUTO/MANUAL SELECTOR SWITCH, Multifunction Meter, ON, OFF AND TRIP, R ,Y & B INDICATOR.	1600A	1		
7	INCOMER - 1 1010 KVA DG SET TO MAIN SYNCH PANEL -2				
	MAKE - SIEMENS 3 POLE, In-1600A, EDO TYPE, 230V CONTROL SUPPLY, 55KA, UV -415VAC CLOSING COIL - 230V , TRIPING COIL- 230VAC, MICROLOGIC6.0 P, O/C, SC, G/F AND INST TNC , AUTO/MANUAL SELECTOR SWITCH, Multifunction Meter, ON, OFF AND TRIP, R ,Y & B INDICATOR.	1600A	1		
8	INCOMER - 3 500 KVA DG SET TO MAIN SYNCH PANEL -2				
	MAKE - SIEMENS 3 POLE, In-1600A, EDO TYPE, 230V CONTROL SUPPLY, 55KA, UV -415VAC CLOSING COIL - 230V , TRIPING COIL- 230VAC, MICROLOGIC6.0 P, O/C, SC, G/F AND INST TNC , AUTO/MANUAL SELECTOR SWITCH, Multifunction Meter, ON, OFF AND TRIP, R ,Y & B INDICATOR.	1600A	1		
9	INCOMER - 3 500 KVA DG SET TO MAIN SYNCH PANEL -1 (SPARE FEEDER)				
	MAKE - SIEMENS 3 POLE, In-1600A, EDO TYPE, 230V CONTROL SUPPLY, 55KA, UV -415VAC CLOSING COIL - 230V , TRIPING COIL- 230VAC, MICROLOGIC6.0 P, O/C, SC, G/F AND INST TNC , AUTO/MANUAL SELECTOR SWITCH, Multifunction Meter, ON, OFF AND TRIP, R ,Y & B INDICATOR.	1600A	1		
Grand Total					

Sr. No.	Discription	In	QTY	Rate Per Item Group (Excluding GST)	GST %
Terms and Condition					
Payment :					
Warranty :					
Freight Cost :					
Loading / Unloading Cost :					
Delivery Period :					
Kindly email your lowest quotation for above with your terms & conditions as well as applicable brochure / catalog, user list to only etenders@mgmuhs.com					
Date:			Signature of Tenderer:		
			Name:		
			Designation:		
			Email ID:		
			Mobile No.:		
			Full Address:		