

**MGM MEDICAL COLLEGE & HOSPITAL**  
**ELECTRICAL MAINTANCE REPORT 01 Sept 2023 to 30 Sept 2023**

Sr.No.	Received Date	Time	Attende Time	Complaint No.	Nature Of Complent	Name Of Department	Date Of Complation	Close Time	Remark
1	02.09.2023	09.55 am	1015 am	2518	LED Tube light not working	NICU	02.09.2023	10.50 am	
2	02.09.2023	11.00 am	11.25 am	2396	Req.new tube light	OBGY OPD	02.09.2023	02.20 pm	
3	02.09.2023	11.20 am	11.20 am	2028	Ex.board not working	Cath Lab	02.09.2023	05.00 pm	
4	02.09.2023	03.00 pm	03.00 pm	224	Ex.board not working	Blood Bank	02.09.2023	05.35 pm	
5	04.09.2023	12.10 pm	12.35 pm	60	Celling Fan not Working	Pead.Ward.03	04.09.2023	02.15 pm	
6	04.09.2023	02.25 pm	03.30 pm	230	Fridge Not working	Dailysis	04.09.2023	03.30 pm	
7	05.09.2023	11.30 am	11.30 am	2428	Tharmameter not working	OT Complex	05.09.2023	11.35 am	
8	05.09.2023	10.45 am	11.00 am	3984	Gizar not working	Nepro ward	05.09.2023	12.00 pm	
9	05.09.2023	03.00 pm	03.10 pm	5540	LED Light not working	MCRI Opthal OPD	05.09.2023	03.25 pm	
10	05.09.2023	11.00 am	11.15 am	4291	AC Not working	IT Dept	09.09.2023	01.00 pm	
11	05.09.2023	08.00 am	10.00 am	6	Lift no 05 not working	Time Office	05.09.2023	12.00 pm	
12	05.09.2023	04.00 pm	04.25 pm	1080	LED Tube light not working	Surgury ward 02	05.09.2023	04.50 pm	
13	05.09.2023	05.00 pm	05.10 pm	646	X-Ray view Box not working	MSW 03	05.09.2023	05.30 pm	
14	05.09.2023	10.10 am	11.00am	533	LED Tube light not working	SS OPD	11.09.2023	11.10 am	
15	05.09.2023	05.05 pm	05.20 pm	2116	LED Light not working	Central lab.	06.09.2023	10.30 am	
16	06.09.2023	02.30 pm	02.30 pm	1154	LED Tube light not working	Microbiology	06.09.2023	02.30 pm	
17	06.09.2023	02.40 pm	03.00 pm	478	Switch Board not working	Physiotherepy opd	06.09.2023	03.25 pm	
18	07.09.2023	09.30 am	09.30 am	2761	LED Tube light not working	Male Ortho WD	07.09.2023	09.35 am	
19	07.09.2023	11.00 am	11.35 am	963	LED Tube light not working	Ped.wd.02	07.09.2023	12.05 pm	
20	07.09.2023	03.40 pm	03.55 pm	1544	Fan Regulator not working	Super Deluxe	08.09.2023	04.00 pm	
21	07.09.2023	12.15 pm	12.40 pm	1742	Switch Board not working	FSW 01	07.09.2023	03.45 pm	
22	08.09.2023	11.00 am	1125 am	1411	Switch Board not working	Biochemistry Dept.	08.09.2023	12.30 pm	
23	08.09.2023	02.55 pm	03.00 pm	4292	AC Not working	IT Dept	09.09.2023	11.30 am	
24	08.09.2023	12.00 pm	12.35 pm	7477	LED Tube light not working	Anatomy	08.09.2023	02.48 pm	
25	08.09.2023	10.28 am	10.40 am	1743	Switch Board not working	FSW 01	08.09.2023	12.05 pm	
26	08.09.2023	11.45 am	12.40 pm	128	HDMI Cable Laying	Physiotherepy	12.09.2023	10.38 am	
27	08.09.2023	10.00 am	10.25 am	1086	Celling Fan not Working	Old Deluxe	09.09.2023	11.45 am	
28	09.09.2023	09.30 am	10.15 am	11	Lift no 01 Not working	Time office	09.09.2023	11.03 am	
29	09.09.2023	02.20 pm	02.20 pm	647	Tharmameter not working	FSW 03	09.09.2023	02.25 pm	
30	09.09.2023	11.40 am	12.15 pm	2335	LED Tube light not working	Medical Store	09.09.2023	03.30 pm	
31	11.09.2023	10.36 am	10.36 am	1541	view box not working	Dermatology	11.09.2023	11.09 am	
32	11.09.2023	09.45 am	10.00 am	535	LED Tube light not working	SS OPD	11.09.2023	11.20 am	
33	11.09.2023	10.25 am	10.35 am	1141	Switch Board not working	Dental OPD	11.09.2023	10.50 am	

*Handwritten signature and date:*  
 24/10/24

34	11.09.2023	10.25 am	10.25 am	2240	LED Light not working	PICU	11.09.2023	10.30 am
35	11.09.2023	09.00 am	11.45 am	1092	Exzost fan not working	Old Deluxe	11.09.2023	11.58 am
36	11.09.2023	09.00 am	11.44 am	1094	Gizar not working	Old Deluxe	11.09.2023	11.53 am
37	11.09.2023	02.20 am	02.45 pm	5957	Tube light not working	CSSD	11.09.2023	03.50 pm
38	11.09.2023	10.01 am	10.35 am	1330	Tube light not working	OBGY WD 01	11.09.2023	04.13 pm
39	11.09.2023	03.13 pm	03.48 pm	2441	LED Light not working	OT Complex	11.09.2023	05.10 pm
40	11.09.2023	06.45 pm	06.45 pm	965	Bathroom light not working	Ped.wd.02	11.09.2023	06.45 pm
41	12.09.2023	11.00 am	11.15 am	167	LED Tube light not working	Pul.Medicine ward	12.09.2023	11.50 am
42	12.09.2023	01.15 pm	01.15 pm	435	Extension Board Not working	CVTS	12.09.2023	01.40 pm
43	12.09.2023	02.35 pm	02.30 pm	5049	Req.06 Ex. Boaed	OT Complex	12.09.2023	02.35 pm
44	12.09.2023	12.39 pm	01.00 pm	1034	Switch Board not working	Medicine Dept	12.09.2023	03.55 pm
45	13.09.2023	02.10 pm	02.25 pm	1432	LED Tube light not working	OBGY WD 02	13.09.2023	02.50 pm
46	13.09.2023	10.30 am	11.00 am	7478	LED Tube light not working	Anatomy	15.09.2023	12.40 pm
47	13.09.2023	12.10 pm	12.50 pm	4430	Switch Board not working	Dailysis	13.09.2023	03.20 pm
48	14.09.2023	11.30 am	11.30 am	7391	Tharmameter not working	Ped.wd.01	14.09.2023	11.35 am
49	14.09.2023	03.10 pm	04.00 pm	1156	LED Light not working	Microbiology	15.09.2023	10.10 am
50	14.09.2023	11.25 am	12.00 pm	1087	LED Tube light not working	Surgury 02	15.09.2023	10.30 am
51	15.09.2023	11.15 am	11.38 am	2763	LED Tube light not working	Male Ortho WD	15.09.2023	12.30 pm
52	15.09.2023	12.45 pm	01.00 pm	18	Lift No 06 Not Working	Time Office	15.09.2023	02.00 pm
53	15.09.2023	02.40 pm	03.00 pm	233	Exzost fan not working	Dailysis Dept.	16.09.2023	02.30 pm
54	15.09.2023	12.15 pm	12.30 pm	2455	Switch Board not working	OT Complex	15.09.2023	12.45 pm
55	16.09.2023	11.00 am	11.40 am	1098	Celling Fan not Working	Old Deluxe	16.09.2023	12.10 pm
56	16.09.2023	11.30 am	11.50 am	1097	LED Light not working	Old Deluxe	16.09.2023	12.10 pm
57	16.09.2023	03.25 pm	03.25 pm	2462	LED Tube light not working	OT Complex	16.09.2023	03.30 pm
58	16.09.2023	11.35 am	12.00 pm	896	LED Tube light not working	OBGY WD. 03	16.09.2023	03.05 pm
59	16.09.2023	11.35 am	12.00 pm	897	Exzost fan not working	OBGY WD. 03	16.09.2023	03.05 pm
60	16.09.2023	01.30 pm	02.00 pm	470	Exzost fan not working	MSW 03	16.09.2023	03.00 pm
61	16.09.2023	04.00 pm	04.30 pm	1599	Switch Board not working	Execative Deluxe	16.09.2023	04.30 pm
62	18.09.2023	09.10 am	09.30 am	3763	Gizar not working	MSW 01	18.09.2023	10.10 am
63	18.09.2023	10.05 am	10.35 am	1051	Celling Fan not Working	ENT OPD	18.09.2023	11.00 am
64	18.09.2023	02.30 pm	03.00 pm	2465	Refrigerator not working	OT Complex	10.10.2023	03.45 pm
65	18.09.2023	11.30 am	11.45 am	1436	Exzost fan not working	OBGY WD 02	18.09.2023	12.10 pm
66	18.09.2023	11.50 am	12.25 pm	2452	LED Tube light not working	OT Complex	18.09.2023	04.20 pm
67	18.09.2023	11.51 am	12.35 pm	3373	Spot Light not working	Radiology Dept	23.09.2023	06.03 pm
68	18.09.2023	11.50 am	12.28 pm	5959	Bell not working	CSSD	20.09.2023	11.30 am
69	19.09.2023	07.05 pm	07.05 pm	3703	Bathroom light not working	Execative Deluxe	19.09.2023	07.10 pm
70	20.09.2023	09.30 am	10.17 am	583	Celling Fan not Working	PSY OPD	20.09.2023	11.00 am

71	20.09.2023	11.20 am	11.20 am	759	Extension Board Not working	New Deluxe	20.09.2023	12.53 pm	
72	21.09.2023	11.45 am	12.00 pm	2836	Switch Board not working	Medical Store	21.09.2023	04.45 pm	
73	21.09.2023	09.56 pm	1048 am	25	Lift no 5 not working	Time office	21.09.2023	11.40 am	
74	21.09.2023	09.56 am	10.18 am	1747	Switch Board not working	FSW 01	21.09.2023	04.20 pm	
75	22.09.2023	09.00 am	10.05 am	2289	New Gizer installation	PSY WD	22.09.2023	03.35 pm	
76	22.09.2023	11.35 am	11.35 am	1360	Tharmameter not working	Casualty	22.09.2023	11.37 am	
77	22.09.2023	02.05 pm	02.35 pm	2452	Wall fan not working	Central Resrach lab	27.09.2023	12.00 pm	
78	22.09.2023	02.35 pm	02.35 pm	368	Exzost fan not working	MCRI Ortho OPD	11.10.2023	09.45 am	
79	22.09.2023	01.00 pm	01.00 pm	458	Tharmameter not working	F.M.W 01	26.09.2023	16.53 pm	
80	22.09.2023	02.15 pm	02.45 pm	1606	LED Light not working	SICU	22.09.2023	04.11 pm	
81	23.09.2023	11.18 am	11.18 am	1849	Tharmameter not working	Male Ortho WD 02	23.09.2023	11.18 am	
82	23.09.2023	11.00 am	11.00 am	1950	LED Light not working	Central Laibrary	23.09.2023	11.15 am	
83	23.09.2023	12.20 pm	12.20 pm	5721	Extension Board Not working	MICU	23.09.2023	12.25 pm	
84	23.09.2023	02.25 pm	03.00 pm	1978	Gizar not working	MICU	23.09.2023	03.00 pm	Not repairable
85	23.09.2023	03.15 pm	03.30 pm	27	Bathroom light not working	Dr.Hostel5th floor	23.09.2023	04.10 pm	
86	23.09.2023	03.05 pm	03.30 pm	1608	LED Light not working	SICU	23.09.2023	04.05 pm	
87	23.09.2023	04.20 pm	04.31 pm	3806	Gizar not working	Old Deluxe	23.09.2023	05.21 pm	
88	23.09.2023	10.00 am	10.20 am	1437	Gizar not working	OBGY WD 02	23.09.2023	05.35 pm	
89	25.09.2023	10.00 am	10.45 am	1438	Fan Regulator not working	OBGY WD 02	25.09.2023	12.00 pm	
90	25.09.2023	12.01 pm	02.00 pm	1036	Gizar not working	Sur.ward 02	26.09.2023	11.45 am	
91	25.09.2023	10.11 am	10.20 am	5960	Light & Switch board not work	CSSD	25.09.2023	10.30 am	
92	25.09.2023	11.05 am	11.10 am	2250	LED Light not working	PICU	25.09.2023	11.30 am	
93	25.09.2023	02.20 pm	02.30 pm	1608	Celling Fan not Working	Execative Deluxe	25.09.2023	02.30 pm	
94	26.09.2023	12.05pm	12.05 pm	969	Tharmameter not working	Ped.WD 02	26.09.2023	12.07 pm	
95	26.09.2023	02.55 pm	02.55 pm	1144	PED. Fan Broken	Dental OPD	26.09.2023	03.00 pm	Not repairable
96	26.09.2023	01.00 pm	04.45 pm	304	Switch Board not working	MMW WD	26.09.2023	05.00 pm	
97	15.09.2023	10.00 am	10.35 am	2285	Wall fan not working	Psy ward	17.11.2023	02.10 pm	
98	26.09.2023	10.30 pm	05.35 pm	909	Switch Board not working	Super Deluxe	26.09.2023	06.00 pm	
99	26.09.2023	12.51 pm	05.17 pm	204	LED Tube light not working	OBGY WD 03	27.09.2023	11.30 am	
100	26.09.2023	11.15 am	05.19 pm	1517	Switch Board not working	F.Ortho ward	26.09.2023	05.25 pm	
101	26.09.2023	09.00 am	04.35 pm	1367	X-Ray view Box not working	Casualty	26.09.2023	04.37 pm	Not repairable
102	27.09.2023	10.15 am	10.50 am	3295	Fan Regulator not working	PED. DEPT.	27.09.2023	11.15 am	
103	27.09.2023	12.30 pm	12.30 pm	3376	Req.Extension board	Radiology Dept	27.09.2023	12.40 pm	
104	27.09.2023	11.15 am	01.20 pm	2483	AC Not working	OT Complex	29.07.2023	01.45 pm	
105	27.09.2023	10.35 am	11.00 am	177	LED Tube light not working	Pul.Medicine ward	27.09.2023	08.25 pm	
106	27.09.2023	11.29 am	12.18 pm	2732	LED Tube light not working	Immunization opd	29.09.2023	10.30 am	

107	28.09.2023	01.15 pm	01.50 pm	31	Lift no 05 not working	Time office	28.09.2023	04.15 pm	
108	29.09.2023	02.45 pm	03.55 pm	537	Switch Board not working	SS OPD	30.09.2023	11.35 am	
109	29.09.2023	10.20 am	10.35 pm	4030	Pedastal Fan not work	MCRI OPD	30.09.2023	03.14 pm	
110	29.09.2023	01.00 pm	02.10 pm	910	AC Not working	Super Deluxe	01.10.2023	02.50 pm	
111	29.09.2023	11.30 am	12.15 pm	3812	Celling Fan not Working	Old Deluxe	29.09.2023	02.10 pm	
112	30.09.2023	10.10 am	11.00 am	906	Light & Fan not Working	Surgury wd 02	30.09.2023	12.00 pm	
113	30.09.2023	10.21 am	11.00 am	464	Switch Board not working	FMW 01	30.09.2023	01.00 pm	
114	30.09.2023	12.15 pm	12.50 pm	907	Exzost fan not working	Sur WD 02	17.11.2023	03.00 pm	
115	30.09.2023	03.30 pm	03.45 pm	5723	Switch Board not working	MICU	30.09.2023	03.45 pm	

Electrical Supervisor  
MGM-EED Aurangabad

Electrical Engineer  
MGM-EED Aurangabad

Technical Executive(Elect.  
MGM-EED Aurangabad

HOD  
MGM-EED Aurangabad

**MGM MEDICAL COLLEGE & HOSPITAL**  
**ELECTRICAL MAINTANCE REPORT 01 Oct 2023 to 31 Oct 2023**

Sr.No.	Received Date	Time	Attende Time	Complaint No.	Nature Of Complent	Name Of Department	Date Of Complation	Close Time	Remark
1	01.10.2023	09.45 am	11.30 am	463	Exzost fan not working	FMW 01	03.10.2023	03.10.2023	
2	03.10.2023	11.05. am	10.35 am	468	Switch Board not working	FMW 01	03.10.2023	03.10.2023	
3	03.10.2023	09.17 am	09.40 am	3815	Gizar not working	Old Deluxe	03.10.2023	03.10.2023	
4	03.10.2023	12.10 pm	12.40 pm	3993	LED Tube light not working	Nepro ward	03.10.2023	03.10.2023	
5	03.10.2023	12.15 am	02.30 am	7392	Light &Fan not working	Ped.wd 01	03.10.2023	03.10.2023	
6	03.10.2023	03.10 pm	04.00 pm	210	Focus lamp not working	OBGY 03 WD	03.10.2023	03.10.2023	
7	04.10.2023	09.25 am	11.35 am	1440	Switch Board not working	OBGY 02 WD	04.10.2023	04.10.2023	
8	04.10.2023	11.35 am	02.45 pm	394	LED Tube light not working	Ophthal ward	04.10.2023	04.10.2023	
9	04.10.2023	12.00 pm	12.35 pm	227	LED Light not working	Blood Bank	04.10.2023	04.10.2023	
10	04.10.2023	02.00 pm	02.05 pm	2265	Collection pump Not working	STP / ETP	10.10.2023	10.10.2024	
11	04.10.2023	04.45 pm	05.00 pm	1424	LED Tube light not working	Biomedical Dept.	04.10.2023	04.10.2023	
12	04.10.2023	11.00 am	11.25 am	447	Switch Board not working	CVTS	04.10.2023	04.10.2023	
13	04.10.2023	11.40 am	12.00 pm	7395	Switch Board not working	Ped.wd 01	04.10.2023	04.10.2023	
14	05.10.2023	07.25 am	09.00 am	41	Lift no 01 Not working	Time Office	05.10.2023	05.10.2023	
15	05.10.2023	02.35 pm	02.45 pm	1145	Celling Fan not Working	Dental OPD	05.10.2023	05.10.2023	
16	05.10.2023	04.20 pm	04.31 pm	1801	Led tube ,Exzost fan not working	H R Dept	21.11.2023	21.11.2024	
17	06.10.2023	09.35 am	09.35 am	1757	Gizer Switch board not working	FSW 01	06.10.2023	06.10.2024	
18	06.10.2023	11.20 am	12.50 pm	538	Switch Board not working	OPD Complex	07.10.2023	07.10.2024	
19	06.10.2023	11.30 am	03.30 pm	1371	LED Tube light not working	Casualty	06.10.2023	06.10.2024	
20	06.10.2023	11.25 am	10.00 am	3816	Fan Regulator not working	Old Deluxe	07.10.2023	07.10.2023	
21	06.10.2023	11.30 am	12.00 pm	2837	LED Tube light not working	Medical Store	07.10.2023	07.10.2023	
22	06.10.2023	11.25 am	10.00 am	3818	RN.650 led light not work	Old Deluxe	06.10.2023	06.10.2023	
23	06.10.2023	01.00 pm	01.30 pm	47	Collage side lift not work	Time Office	06.10.2023	06.10.2023	
24	06.10.2023	11.25 am	10.00 am	3817	RN.651 Exzost fan not work	Old Deluxe	07.10.2023	07.10.2024	
25	06.10.2023	04.00 pm	04.10 pm	4544	New Point Requied	EICU	06.10.2023	06.10.2024	
26	06.10.2023	12.00 pm	12.32 pm	1996	Switch Board not working	Pharmaclogy	07.10.2023	07.10.2024	
27	06.10.2023	11.30 am	03.30 pm	1372	Celling Fan not Working	Casualty	06.10.2023	06.10.2024	
28	07.10.2023	09.54 am	11.00 am	590	Celling Fan not Working	Ophthal OPD	07.10.2023	07.10.2023	
29	07.10.2023	10.00 am	10.45 am	1996	Switch Board not working	Pharmaclogy	07.10.2023	07.10.2023	
30	07.10.2023	12.35 pm	03.00 pm	2491	A.C Switch not working	OT Complex	10.10.2023	10.10.2024	
31	07.10.2023	10.40 am	11.30 am	4032	LED Light not working	MCRI OPD	16.10.2023	16.10.2024	
32	07.10.2023	12.35 pm	03.00 pm	2490	A.C Switch not working	OT Complex	10.10.2023	10.10.2024	
33	07.10.2023	10.35 am	11.30 am	4035	Switch Board not working	MCRI OPD	07.10.2023	07.10.2024	
34	08.10.2023	04.30 pm	05.00 pm	49	Lift no 01 Not working	Time Office	08.10.2023	08.10.2024	
35	09.10.2023	12.31 pm	12.31 pm	1302	LED Tube light not working	Central Store	09.10.2023	09.10.2024	
36	09.10.2023	12.30 pm	12.55 pm	2539	Bathroom light not working	NICU	10.10.2023	10.10.2024	

*Amman*  
*24/10/24*

37	09.10.2023	02.30 pm	02.30 pm	4037	PED. Fan not working	MCRI OPD	09.10.2023	09.10.2024	
38	09.10.2023	03.15 pm	03.45 pm	51	Sport Hostel light not work	Time Office	10.10.2023	10.10.2024	
39	09.10.2023	10.00 am	10.20 am	4545	AC Not working	EICU	09.10.2023	09.10.2024	
40	09.11.2023	12.35 pm	01.00 pm	2538	Exzost fan not working	NICU	24.11.2023	24.11.2024	
41	09.10.2023	12.30 pm	04.00 pm	915	LED Tube light not working	Sur.ward 02	10.10.2023	10.10.2023	
42	09.10.2023	11.20 am	10.55 am	2543	Switch Board not working	NICU	10.10.2023	10.10.2023	
43	10.10.2023	11.14 am	03.01 pm	1406	Switch Board not working	OT Complex	10.10.2023	10.10.2023	
44	10.10.2023	02.30 pm	03.01 pm	1408	LED Tube light not working	OT Complex	10.10.2023	10.10.2023	
45	10.10.2023	04.30 pm	04.30 pm	1949	LED Light not working	EMS Ward	10.10.2023	10.10.2023	
46	10.10.2023	11.25 am	03.00 pm	2905	Switch Board not working	OBYG ICU	10.10.2023	10.10.2023	
47	10.10.2023	11.25 am	12.00 pm	576	LED Light not working	OBYG ICU	10.10.2023	10.10.2023	
48	11.10.2023	10.30 am	10.30 am	2033	Fan not working	CATHLAB	11.10.2023	11.10.2023	
49	11.10.2023	02.20 pm	02.45 pm	2298	LED Light not working	PSY WD.	11.10.2023	11.10.2023	
50	11.10.2023	10.15 pm	03.00 pm	1204	Focus lamp not working	OBYG OPD	11.10.2023	11.10.2023	
51	11.10.2023	11.20 am	03.15 pm	229	LED Light not working	Blood Bank	11.10.2023	11.10.2023	
52	11.10.2023	11.15 am	12.00 pm	878	Wall fan not working	MJPJAY OPD	12.10.2023	12.10.2024	
53	11.10.2023	10:00am	12:45pm	3364	New tube light install work.	PSM Dept.	1.11.2023	1.11.2024	
54	12.10.2023	10.15 am	10.45 am	191	Exzost fan not working	Pul.Medicine ward	12.10.2023	12.10.2023	
55	12.10.2023	10.15 am	10.45 am	190	Switch Board not working	Isolation ICU	12.10.2023	12.10.2023	
56	12.10.2023	02.10 am	02.10 pm	1413	Light Not working	OT Complex	12.10.2023	12.10.2023	
57	12.10.2023	02.55 pm	03.25 pm	1411	Bulb not working	OT Complex	12.10.2023	12.10.2023	
58	13.10.2023	11.20 am	11.20 am	1418	Pedestal Fan not working	Dean office	12.10.2023	12.10.2023	
59	13.10.2023	04.38 pm	04.50 pm	24157	Exzost fan not working	Nuesing Collage			
60	13.10.2023	12.05 pm	02.28 pm	1513	Humidity Meter not working	MJPJAY ICU	14.10.2023	14.10.2024	
61	13.10.2023	02.36 pm	03.00 pm	769	R.No 305 Led.light not work	New Deluxe	13.10.2023	13.10.2024	
62	14.10.2023	10.12 am	10.50 am	2300	Wall fan not working	PSY WD	14.10.2023	14.10.2023	
63	14.10.2023	12.25 pm	12.25 pm	1260	Switch Board not working	CCU / CVTS	14.10.2023	14.10.2023	
64	14.10.2023	11.00 am	11.00 am	793	LED Light not working	Endoscopy	14.10.2023	14.10.2023	
65	14.10.2023	02.54 pm	03.55 pm	3825	Gizer not working	Old Deluxe	14.10.2023	14.10.2023	
66	16.10.2023	10.30 am	10.30 am	2301	Tharmameter not working	PSY WD	14.10.2023	14.10.2023	
67	16.10.2023	02.30 pm	02.45 pm	1417	Switch Board not working	OT Complex	16.10.2023	16.10.2023	
68	16.10.2023	11.56 am	03.15 am	1619	Exzost fan not working	Execative Deluxe	16.10.2023	16.10.2023	
69	16.10.2023	11:56am	03:41pm	1620	Switch Board not working	Execative Deluxe	16.10.2023	16.10.2023	
70	17.10.2023		10:20am	1550	Fan not working	Dermatology	18.10.2023	18.10.2024	
71	17.10.2023		03:45pm	1551	Fa working	Dermatology	19.10.2023	19.10.2024	
72	17.10.2023	12:30am	12:40am	1381	Board repair work	Casualty	17.10.2023	17.10.2024	
73	17.10.2023	03:45pm	04:00pm	1420	Tube light not working	O.T. complex	18.10.2023	18.10.2023	
74	18.10.2023	02:06pm	04:00pm	1422	Tube light not working	O.T. complex	18.10.2023	18.10.2023	
75	18.10.2023	10:30am	12:00pm	1511	Switch Board not working	Fe.Ortho.WD	18.10.2023	18.10.2023	
76	19.10.2023	10:00	10:10am	1560	Board repair work	Super Deluxe	19.10.2023	19.10.2023	

77	19.10.2023	12:40pm	12:50pm	2556	Electrical board not working	NICU	19.10.2023	19.10.2023	
78	19.10.2023	10:20am	10:30am	1383	X-Ray machine pin repair	Casualty	19.10.2023	19.10.2023	
79	19.10.2023	11:30am	11:45am	3405	Tube light not working	Ped.wd-01	19.10.2023	19.10.2023	
80	19.10.2023	02:50pm	03:00pm	3404	Fan & switch board not working	Ped. wd-01	19.10.2023	19.10.2023	
81	19.10.2023	12:00pm	12:30pm	1963	Fan not working	EMSP	19.10.2023	19.10.2023	
82	19.10.2023	12:30PM	04:35pm	1962	view box not working	EMSP	26.10.2023	26.10.2024	
83	19.10.2023	03:00pm	03:05pm	595	New electrical Board installation	Ophthal OPD	21.10.2023	21.10.2024	
84	19.10.2023	04:10pm	04:35pm	1269	LED Light not working	MET CELL	19.10.2023	19.10.2023	
85	19.10.2023	09:10pm	09:22pm	4043	Light Not working	MCRI OPD	19.10.2023	19.10.2023	
86	20.10.2023	12:10pm	12:30pm	217	Focus lamp fitting	OBGy wd-03	20.10.2023	20.10.2023	
87	20.10.2023	02:45pm	02:50pm	1805	Fan not working	HR Dept.	20.10.2023	20.10.2023	
88	20.10.2023	03:15pm	03:32pm	86	Wall fan fitting work	ENT ward	20.10.2023	20.10.2023	
89	20.10.2023	04:00pm	4:50pm	1625	View box cable short.	Execative Deluxe	20.10.2023	20.10.2023	
90	21.10.2023	10:15am	10:30am	87	Tube light not working	ENT ward	21.10.2023	21.10.2023	
91	21.10.2023	10:20am	10:40am	6609	LED light broken	MSI	21.10.2023	21.10.2023	
92	21.10.2023	03:50pm	04:00pm	3832	Geizer not working	Old Deluxe	21.10.2023	21.10.2023	
93	21.10.2023	06:26pm	06:30pm	451	Switch Board not working	CVTS bed -11	21.10.2023	21.10.2023	
94	22.10.2023	11:00am	11:30am	62	UPS Not working	Time office	22.10.2023	22.10.2023	
95	22.10.2023	07:00pm	07:00pm	63	Lift 1 not working	Time office	22.10.2023	22.10.2023	
96	23.10.2023	11:00am	11:15am	1152	Fan & Tube not working	Uro/Pls wd	24.10.2023	24.10.2024	
97	23.10.2023	12:20pm	12:30pm	1523	Tube light not working	Fe.Ortho.WD	25.10.2023	25.10.2024	
98	23.10.2023	02:10pm	02:15pm	1966	LED Bulb not working	EMSP	23.10.2023	23.10.2024	
99	23.10.2023	03:50pm	04:00pm	1524	Tube light not working	Fe.Ortho.WD	25.10.2023	25.10.2024	
100	24.10.2023	09:35am	09:40am	3013	Switch Board not working	MCRI ICU	24.10.2023	24.10.2024	
101	25.10.2023	10:20am	10:30am	2257	Tube light proper fixing	FMW-02	25.10.2023	25.10.2023	
102	25.10.2023	10:20am	10:30am	2258	Electric stick broken	FMW -02	25.10.2023	25.10.2023	
103	25.10.2023	04:00pm	04:20pm	1999	General toilet Maint.work	HR Dept.	02.11.2023	02.11.2024	
104	25.10.2023	10:20am	10:30am	7483	Light Not working	Anatomy	25.10.2023	25.10.2023	
105	25.10.2023	10:30am	10:40am	2550	Tube light not working	Record Section	25.10.2023	25.10.2023	
106	25.10.2023	11:30am	12:45pm	1768	X-Ray machine pin repair	FSW-01	25.10.2023	25.10.2023	
107	25.10.2023	12:33PM	01:00PM	3616	New electrical Board installation	Nepro ward	25.10.2023	25.10.2023	
108	25.10.2023	12:10pm	02:40pm	2702	Fan not working	Nepro ward	25.10.2023	25.10.2023	
109	26.10.2023	12:14pm	02:15pm	774	Tube light not working	New Deluxe	26.10.2023	26.10.2023	
110	26.10.2023	10:54am	02:30pm	221	Tube light not working	OBG wd-03	26.10.2023	26.10.2023	
111	26.10.2023			926	Fan not working	Sur.ward 02	26.10.2023	26.10.2023	
112	26.10.2023	11:37am	12:00pm	927	Switch board plate,	Sur.ward 02	27.10.2023	27.10.2024	
113	26.10.2023	11:45am	12:00pm	1430	Suction central pannel contactor not working	Biomedical Dept.			
114	26.10.2023	12.15 pm	12.30 pm	3383	Req.New power point	Radiology Dept	01.11.2023	01.11.2024	
115	26.10.2023	03:15pm	03:31pm	1432	New socket and switch required	Biomedical Dept.	26.10.2023	26.10.2024	
116	27.10.2023	12:10pm	12:10pm	222	Tube light not working	OBGY wd 3	27.10.2023	27.10.2023	

117	27.10.2023	02:30pm	02:30pm	455	Fridge Not working	MJPJY wd	27.10.2023	27.10.2023	
118	27.10.2023	02:30pm	04:10pm	454	Tube light proper fixing & Fan button replace	MJPJY wd	27.10.2023	27.10.2023	
119	27.10.2023	03:07pm	04:00pm	1163	Switch Board not working	Microbiology	28.10.2023	28.10.2023	
120	28.10.2023	11:30am	03:00pm	2261	Tube light fitting work.	FMW -02	28.10.2023	28.10.2023	
121	28.10.2023	02:00pm	02:45pm	4050	Electric MCCB board check.	MCRI OPD	28.10.2023	28.10.2023	
122	28.10.2023	11:00am	02:45pm	4045	Light Not working	MCRI OPD	28.10.2023	28.10.2023	
123	28.10.2023	02:00pm	02:45pm	4049	Fan not proper working	MCRI OPD	28.10.2023	28.10.2023	
124	29.10.2023	07:06am	07:25am	71	Lift not working	Time Office	29.10.2023	29.10.2024	
125	30.10.2023		10:17am	224	Tube light fitting work.	OBGY wd 3	30.10.2023	30.10.2023	
126	30.10.2023	11:00am	11:30am	4052	3 pin Socket proper fitting work.	MCRI OPD	30.10.2023	30.10.2023	
127	30.10.2023	10:50am	11:01am	1444	Switch board not working	OT Complex	30.10.2023	30.10.2023	
128	30.10.2023	10:50am	11:01am	1443	Switch board checking work	OT Complex	30.10.2023	30.10.2023	
129	30.10.2023	03:00pm	03:10pm	457	Exhaust fan not available	MJPJAY wd	30.10.2023	30.10.2023	
130	30.10.2023	11:50am	12:30pm	91	Fan regulator damage	ENT ward	31.10.2023	31.10.2023	
131	31.10.2023	10:00am	10:10am	2771	Tube light fitting work.	Male ORTHO ward	31.10.2023	31.10.2023	
132	31.10.2023	11:10am	11:35am	782	Fridge thermometer not working	New Deluxe	31.10.2023	31.10.2023	
133	31.10.2023	11:15am	11:31am	3385	LED Light not working	Radiology Dept.	31.10.2023	31.10.2023	

Electrical Supervisor  
MGM-EED Aurangabad

Electrical Engineer  
MGM-EED Aurangabad

Technical Executive(Elect.  
MGM-EED Aurangabad

HOD  
MGM-EED Aurangabad



**MGM MEDICAL COLLEGE & HOSPITAL**  
**ELECTRICAL MAINTANCE REPORT 01 Nov 2023 to 30 Nov 2023**

Sr.No.	Received Date	Time	Attende Time	Complaint No.	Nature Of Complent	Name Of Department	Date Of Complation	Close Time	Remark
1	01.11.2023	10.00 am	10.27 am	77	Dr.Hostel light not working	Time Office	01.11.2023	10.35 am	
2	01.11.2023	10.09 am	10.15 am	585	LED Tube light not working	PSY OPD	01.11.2023	10.28 am	
3	01.11.2023	10.30 am	11.10 am	226	Switch Board not working	OBGY WD 03	01.11.2023	10.38 am	
4	01.11.2023	11.40 am	12.00 pm	2315	LED Tube light not working	PSY WD	01.11.2023	03.07 pm	
5	01.11.2023	11.00 am	11.30 am	1348	Celling Fan not Working	OBGY WD 01	01.11.2023	04.19 pm	
6	02.11.2023	11.00 am	11.00 am	1276	Tharmameter not working	CCU	02.11.2023	11.05 am	
7	02.11.2023	11.10 am	11.10 am	454	Tharmameter not working	CVTS	02.11.2023	11.15 am	
8	02.11.2023	12.00 pm	12.27 pm	1516	Switch board not working	MJPJAY ICU	02.11.2023	12.35 pm	
9	03.11.2023	10.26 am	10.45 am	3388	Celling Fan install	Radiology Dept	03.11.2023	04.34 pm	
10	03.11.2023	06.16 pm	06.30 pm	82	Lift no 01 Not working	Time office	03.11.2023	07.05 pm	
11	04.11.2023	09.30 am	09.30 am	1974	Switch Board not working	EMS-P	04.11.2023	09.40 am	
12	04.11.2023	02.17 pm	02.38 pm	921	LED Light not working	Dyotan Hall	04.11.2023	03.10 pm	
13	04.11.2023	03.00 pm	03.15 pm	1866	Tubelight not working	Male ortho ward 02	04.11.2023	03.17 pm	
14	04.11.2023	12.33 pm	03.15 pm	325	Switch Board not working	MMW WD	04.11.2023	03.30 pm	
15	04.11.2023	12.00 pm	02.35 pm	852	Light Not working	2 D Eco	04.11.2023	02.40 pm	
16	04.11.2023	02.40 pm	02.55 pm	2256	Celling Fan not Working	FMW 02	04.11.2023	04.40 pm	
17	06.11.2023	11.01 am	11.16 am	543	Switch Board not working	MGM OPD Complex	06.11.2023	11.30 am	
18	06.11.2023	09.25 am	10.00 am	462	LED Light not working	MJPJAY WD	06.11.2023	04.22 pm	
19	06.11.2023	11.30 am	02.10 pm	1529	Celling Fan not Working	F.Ortho ward	13.12.2023	02.24 pm	
20	06.11.2023	04.00 pm	04.45 pm	3153	LED Tubelight not working	Linen Department	07.11.2023	10.00 am	
21	06.11.2023	11.56 am	12.10 pm	2707	Switch Board not working	Nepro ward	06.11.2023	04.46 pm	
22	06.11.2023	11.58 am	12.38 pm	1518	LED Tube light not working	MJPJAY ICU	06.11.2023	04.25 pm	
23	07.11.2023	10.40 am	11.30 am	932	Switch Board not working	Surgury ward 02	07..11.2023	12.40 pm	
24	07.11.2023	10.22 am	10.52 am	409	LED Light not working	Isolation ICU	07.11.2023	04.25 pm	
25	08.11.2023	02.08 pm	02.17 pm	394	Install the Sky Latern	School of Bio med.Sci.	08.11.2023	04.45 pm	
26	08.11.2023	09.30 am	10.00 am	1576	Switch Board not working	Super Deluxe	08.11.2023	11.45 pm	
27	08.11.2023	11.55 am	12.00 pm	2589	Switch Board not working	NICU	08.11.2023	12.05 pm	
28	08.11.2023	09.30 am	10.00 am	1573	All room Light,fan checked	Super Deluxe	08.11.2023	12.00 pm	
29	09.11.2023	10.00 am		86	Sky lanterns install in all dept.	Time office	11.11.2023	04.15 pm	
30	09.11.2023	12.00 pm	12.15 pm	3853	Gizer not working	Old Deluxe	09.11.2023	12.45 pm	
31	09.11.2023	10.15 am	10.15 am	1304	LED Tube light not working	Central Store	09.11.2023	10.30 am	
32	10.11.2023	02.44 pm	02.44 pm	1637	Switch Board not working	SICU	10.11.2023	03.45 pm	
33	11.11.2023	10.00 am	10.20 am	3855	Gizer not working	Old Deluxe	11.11.2023	11.32 am	
34	11.11.2023	02.18 pm	03.30 pm	2318	Wall fan not working	PSY WD	11.11.2023	03.45 pm	
35	11.11.2023	02.45 pm	02.45 pm	2132	Celling Fan not Working	OPD no 249	11.11.2023	03.00 pm	

*Handwritten signature*  
24/11/24

36	11.11.2023	08.00 am	09.31 am	932	switch board . Fan not working	Surgery ward no.2	11.11.2023	10.00 pm	
37	13.11.2023	01.15pm	01.30 pm	1987	LED Light not working	EMS- P	13.11.2023	01.48 pm	
38	13.11.2023	01.30pm	01.30 pm	1989	Switch Board not working	EMS ICU	13.11.2023	01.45 pm	
39	15.11.2023	09.30 am	10.00 am	5545	Switch Board not working	MCRI Ophta opd	15.11.2023	10.36 am	
40	15.11.2023	11.40 am	12.00 pm	2320	Wall fan not working	Psy ward	17.11.2023	12.55 pm	
41	15.11.2023	02.33 pm	02.40 pm	1631	Switch Board not working	Execative Deluxe	15.11.2023	02.50 pm	
42	17.11.2023	01 00 pm	02.00 pm	5751	LED Light not working	MICU	18.11.2023	02.35 pm	
43	17.11.2023	11.12 am	12.00 pm	4066	fan standg not working	MCRI opd no 13	21.11.2023	11.17 am	
44	17.11.2023	11.10am	12.00 pm	231	LED Tube light not working	OBGY WD 03	18.11.2023	03.15 pm	
45	17.11.2023	10.00 am	10.55 am	2269	Switch Board not working	F M W 02	17.11.2023	11.30 am	
46	18.11.2023	09.00 am	10.15 am	1454	Fan nob not working	OBGY WD 02	18.11.2023	10.30 am	
47	18.11.2023	09.25 am	11.20 am	3858	Led . Fan, switch, not working	Old Deluxe	18.11.2023	12.00 pm	
48	18.11.2023			Latter	Ophthal OT AC Install work	OPHTHAL OT	18.11.2023		
49	19-11-23	12:00 PM	12:30 PM	1591	Switch Board not working	Super Deluxe	21-11-23	12:00 PM	
50	20.11.2023	10.54 am	11.25 am	3714	LED Light not working	Execative Deluxe	20.11.2023	12.30 pm	
51	20.11.2023	09.55 am	11.30 am	73	Celling Fan not Working	Medicine OPD	20.11.2023	11.45 am	
52	20.11.2023	09 00 am	11.15 am	74	Wall fan not working	Medicine OPD	20.11.2023	12.00 pm	
53	21.11.2023	12.23 pm	12.33 pm	5753	Tharmameter not working	MICU	21.11.2023	12.24 pm	
54	21.11.2023	04.00 pm	04.30 pm	24166	LED tube light,swith board not working	Nursing College	21.11.2023	05.00 pm	
55	22.11.2023	9:15 AM	9:25 AM	922	LED tube,fan not working	Bio-Chem. Lecture hall	22.11.2023	11:00 AM	
56	22.11.2023	12.56 pm	01.38 pm	97	Lift no 05 not working	Time office	22.11.2023	02.00 pm	
57	22.11.2023	12:00 PM	12:27 PM	98	Celling Fan not Working	ENT ward	22.11.2023	2:05 PM	
58	23.11.2023	10:30 AM	10:50 AM	234	Focus lamp not working	OBGY WD 03	23.11.2023	11:10 AM	
59	23.11.2023	11:00 AM	11:15 AM	464	LED Tube light not working	MJPJAY wd	28.11.2023	11:45 AM	
60	23.11.2023	3:00 PM	3:40 PM	2043	LED Light not working	Cath Lab	28.11.2023	10:30 AM	
61	24.11.2023	10:25 AM	10:25 AM	3414	LED Light not working	Ped.wd-01	24.11.2023	10:30 AM	
62	24.11.2023	9:30 AM	10:20 AM	2712	Switch Board not working	Nepro ward	24.11.2023	11:10 AM	
63	24.11.2023	1:00 PM	1:55 PM	80	Celling Fan not Working	Ped.wd	24.11.2023	2:40 PM	
64	24.11.2023	10:00 AM	10:30 AM	1121	LED Tube and fan not working	Physiology	27.11.2023	4:45 PM	
65	25.11.2023	10:00 AM	10:45 AM	940	Exhuast fan not available	Surgery ward no.2	25.11.2023	12:15 PM	
66	25.11.2023	10:30 AM	11:15 AM	1561	Celling Fan not Working	Dermatology wd	28.11.2023	10:45 AM	
67	27.11.2023	12:00 PM	12:30 PM	4072	View box not working	MCRI OPD 25	27.11.2023	3:30 PM	
68	28.11.2023	12:00 PM	12:40 PM	1590	Gizer not working	Super Deluxe	28.11.2023	1:00 PM	
69	28.11.2023	9:30 AM	10:00 AM	1712	LED Light not working	EICU	28.11.2023	2:34 PM	
70	28.11.2023	12:00 PM	12:25 PM	3861	LED Tube light not working	Old Deluxe	28.11.2023	3:00 PM	
71	28.11.2023	12:00 PM	12:25 PM	3863	Celling Fan not Working	Old Deluxe	28.11.2023	3:00 PM	
72	28.11.2023	2:50 PM	3:10 PM	2923	LED Light not working	OBGY ICU	28.11.2023	3:35 PM	
73	28.11.2023	3:20 PM	3:30 PM	2551	LED Tube light not working	Record section	28.11.2023	4:20 PM	
74	29.11.2023	11:30 AM	11:35 AM	2775	Tharmameter not working	Male Ortho wd	29.11.2023	12:30 PM	
75	29.11.2023	10:27 AM	11:00 AM	1353	Celling Fan not Working	OBGY WD 01	29.11.2023	2:45 PM	

76	29.11.2023	12.13 pm	12.15 pm	425	Tharmameter not working	Pul.Medicine ward	29.11.2023	12.20 pm	
77	30.11.2023	04.53 pm	05.15 pm	408	Lift no 01 Not working	Time office	31.11.2023	06.30 pm	
78	30.11.2023	10:00 AM	10:30 AM	2039	Exhuast fan switch not working	Cath Lab	30.11.2023	12:00 PM	
79	30.11.2023	11:00 AM	11:10 AM	945	Wall fan not working	Surgery ward no.2	30.11.2023	12:00 PM	
80	30.11.2023	11:00 AM	11:10 AM	1483	Switch Board not working	OT Complex	30.11.2023	12:50 PM	
81	30.11.2023	12:30 PM	12:46 PM	1484	Switch Board not working	OT Complex	30.11.2023	3:00 PM	
82	30.11.2023	09.30 am	11.00 am	395	LED Tube light not working	MGM OPD Complex	30.11.2023	11.33 am	
83	30.11.2023	1:30 PM	1:40 PM	2266	ETP pump connection work	STP/ETP	01.12.2023	9:30 AM	

Electrical Supervisor  
MGM-EED Aurangabad

Electrical Engineer  
MGM-EED Aurangabad

Technical Executive(Elect.  
MGM-EED Aurangabad

HOD  
MGM-EED Aurangabad

**MGM MEDICAL COLLEGE & HOSPITAL**  
**ELECTRICAL MAINTANCE REPORT 01 Dec 2023 to 31 Dec 2023**

Sr.No.	Received Date	Time	Attende Time	Complaint No.	Nature Of Complent	Name Of Department	Date Of Completion	Close Time	Remark
1	01.12.2023	10:00 AM	10:30 AM	429	Switch Board not working	Isolation ICU	01.12.2023	11:30 AM	
2	01.12.2023	10:00 AM	10:30 AM	430	LED Light not working	Isolation ICU	01.12.2023	2:50 PM	
3	01.12.2023	9:30 AM	10:30 AM	2327	LED Tube light not working	PSY WD	01.12.2023	10:30 AM	
4	01.12.2023	12.30 pm	12.30 pm	2267	EIP pump not working	STP/ETP	12.12.2023	12.00 pm	
5	01.12.2023	11:30 AM	12:00 PM	3676	Extension Board not working	Cardaic OT	01.12.2023	12:30 PM	
6	01.12.2023	12:50 PM	1:00 PM	2268	Motor pump connection work	STP/ETP	01.12.2023	2:30 PM	
7	02.12.2023	12.40 pm	12.40 pm	912	Tharmameter not working	NICU	11.12.2023	12.12 pm	
8	02.12.2023	9:25 AM	9:35 AM	2330	LED Tube light not working	PSY WD	02.12.2023	11:30 AM	
9	02.12.2023	2:10 PM	2:30 PM	3398	LED Light not working	Radiology Dept	02.12.2023	3:00 PM	
10	02.12.2023	10:30 AM	10:45 AM	433	Exhuast fan not working	Pul. Med. Ward	04.12.2023	3:15 PM	
11	04.12.2023	11:10 AM	11:20 AM	1214	LED Light not working	EMS ICU	04.12.2023	11:33 AM	
12	04.12.2023	10:50 AM	11:00 AM	1716	LED Light not working	EICU	04.12.2023	11:10 AM	
13	04.12.2023	12:25 PM	12:30 PM	1458	LED Tube light not working	OBGY WD 02	04.12.2023	12:41 PM	
14	04.12.2023	10:05 AM	10:12 AM	805	Celling fan not Working	Endoscopy	04.12.2023	10:20 AM	
15	04.12.2023	12:00 PM	12:11 PM	1895	Extension board plug not working	Super Deluxe	04.12.2023	1:00 PM	
16	04.12.2023	11.13 am	11.20 am	1214	LED Light not working	EMS ICU	04.12.2023	11.33 am	
17	04.12.2023	03.27 pm	04.38 pm	1638	Exzost fan not working	Execative Deluxe	08.12.2023	10.00 am	
18	04.12.2023	11.15 am	11.30 am	1270	LED Light not working	MET CELL	13.11.2023	10.05 am	
19	04.12.2023	11.38 am	12.00 pm	303	LED Tube light not working	ENT ward	05.12.2023	10.15 am	
20	04.12.2023	11.39 am	12.10 pm	923	LED Light not working	Dyotan Hall	05.12.2023	04.10 pm	
21	06.12.2023	11.35 am	11.40 am	1496	OT no 04 Switch Board not work	OT Complex	06.12.2023	12.15 pm	
22	06.12.2023	11.05 am	02.00 pm	3041	LED Light not working	MCRI ICU	07.12.2023	03.04 pm	
23	06.12.2023	12.10 pm	01.53 pm	915	Spot Light not working	Super Deluxe	13.12.2023	02.43 pm	
24	06.12.2023	11.30 am	12.00 pm	1651	Switch Board not working	SICU	06.12.2023	03.05 pm	
25	06.12.2023	12.00 pm	12.28 pm	482	LED Bulb not working	Physiotherepy opd	06.12.2023	05.10 pm	
26	07.12.2023	12.10 pm	01.23 pm	2051	Bathroom light not working	Cath Lab	07.12.2023	01.34 pm	
27	07.12.2023	12.00 pm	01.40 pm	237	PV Lamp not working	OBGY WD 03	07.12.2023	01.45 pm	
28	07.12.2023	11.35 am	02.10 pm	1218	LED Light not working	Casualty	07.12.2023	04.00 pm	
29	07.12.2023	05.00 pm	05.15 pm	305	LED Tube light not working	ENT ward	07.12.2023	05.30 pm	
30	08.12.2023	10.25 am	10.25 am	3044	LED Light not working	MCRI ICU	08.12.2023	11.53 am	
31	08.12.2023	02.45 pm	02.45 pm	1221	Extension Board not working	EMS-P	08.12.2023	02.45 pm	
32	09.12.2023	09.35 am	10.18 am	4083	LED Light not working	MCRI OPD	09.12.2023	12.05 pm	
33	09.12.2023	01.50 pm	01.55 pm	1459	Bathroom light not working	OBGY WD 02	09.12.2023	02.00 pm	
34	09.12.2023	03.18 pm	03.37 pm	2294	LED Light not working	PICU	09.12.2023	04.00 pm	
35	09.12.2023	11.43 am	12.05 pm	1003	OT no 02 Tube light not work	OT Complex	09.12.2023	05.00 pm	
36	09.12.2023	02.20 pm	03.00 pm	3786	Switch Board not working	MSW 01	11.12.2023	10.00 am	

*Handwritten signature*  
 24/12/24

37	09.12.2023	10.36 am	11.29 am	2552	LED Tube light not working	Record section	13.12.2023	11.55 am	
38	09.12.2023	02.10 pm	03.12 pm	553	Switch Board not working	Labour Room	09.12.2023	05.00 pm	
39	11.12.2023	10.00 am	10.00 am	554	Tharmameter not working	Labour Room	11.12.2023	10.11 am	
40	11.12.2023	01.46 pm	02.27 pm	414	Light Not working	Time office	11.12.2023	11.00 am	
41	11.12.2023	01.46 pm	02.27 pm	415	Celling Fan not Working	Time office	13.11.2023	11.15 am	
42	11.12.2023	10.00 am	10.45 am	441	Switch Board not working	Pul. Med. Ward	11.12.2023	12.41 pm	
43	11.12.2023	5.30 pm	05.30 pm	237	Switch Board not working	Blood Bank	11.12.2023	06.00 pm	
44	12.12.2023	02.45 pm	03.10 pm	550	Switch Board not working	MGM SS OPD 233	15.12.2023	11.20 pm	
45	12.12.2023	11.10 am	11.10 am	2270	ETP pump connection work	STP/ETP	12.12.2023	12.00 pm	
46	12.12.2023	02.42 pm	02.10 pm	2929	Extension Board not working	OBGY ICU	12.12.2023	02.45 pm	
47	13.12.2023	11.30 am	11.35 am	955	Light Not working	Sur.ward 02	13.12.2023	11.41 am	
48	13.12.2023	02.45 pm	03.15 pm	1303	LED Light not working	EMS ICU	13.12.2023	03.50 pm	
49	13.12.2023	10.27 am	11.00 am	443	Extension Board not working	Pul.Medicine ward	13.12.2023	11.46 am	
50	13.12.2023	11.19 am	02.10 pm	1537	Gizer not working	F.Ortho ward	13.12.2023	02.27 pm	
51	13.12.2023	12.00 pm	12.30 pm	680	View box not working	FSW 03	13.12.2023	02.12 pm	
52	13.12.2023	12.12 pm	12.48 pm	2930	LED Light not working	OBGY ICU	13.12.2023	03.30 pm	
53	14.12.2023	11.25 am	12.00 pm	483	LED Light not working	Physiotherapy opd	16.12.2023	11.31 am	
54	15.12.2023	04.20 pm	04.48 pm	3036	Switch Board not working	MCKI Dental OPD	16.12.2023	10.10 am	
55	16.12.2023	10.45 am	11.00 am	3369	Water Filter not working	PSM Dept.	16.12.2023	11.35 am	
56	16.12.2023	07.22 pm	07.10 pm	1234	Switch Board not working	Casualty	16.12.2023	08.04 pm	
57	18.12.2023	11.15 am	11.28 am	605	Extension Board not working	Pathology	18.12.2023	11.40 am	
58	19.12.2023	09.45 am	09.50 am	1587	Switch Board not working	Metern office	19.12.2023	10.00 am	
59	19.12.2023	10.00 am	10.15 am	938	Switch Board not working	NICU	19.12.2023	10.25 am	
60	19.12.2023	11.45 am	11.50 am	2284	Tharmameter not working	FMW 02	19.12.2023	12.00 pm	
61	19.12.2023	04.00 pm	04.45 pm	478	Gizer not working	MJPJAY WD	19.12.2023	05.38 pm	
62	19.12.2023	04.00 pm	04.30 pm	792	Switch Board not working	New Deluxe	19.12.2023	05.28 am	
63	19.12.2023	02.30 pm	01.05 pm	959	Celling Fan not Working	Surgery ward no.2	22.12.2023	12.00 pm	
64	20.12.2023	11.42 am	12.00 pm	2696	LED Tube light not working	Exam Cell	21.12.2023	12.00 pm	
65	21.12.2023	12.45 pm	01.30 pm	1239	LED Tube light not working	MGM Casualty	22.12.2023	02.05 pm	
66	21.12.2023	10.56 am	11.20 am	960	Switch board not working	Surgery ward no.2	23.12.2023	02.45 pm	
67	22.12.2023	01.15 pm	03.50 pm	3209	LED Tube light not working	Dermatology	22.12.2023	04.20 pm	
68	23.12.2023	09.00 am	09.15 am	2056	Call Bell instolelicn	Cathlab	23.12.2023	09.30 am	
69	23.12.2023	09.00 am	09.20 am	404	Akash dive dismantle	Time office	23.12.2023	12.36 pm	
70	23.12.2023	12.30 pm	02.00 pm	964	Switch board not working	Surgery ward no.2	23.12.2023	02.38 pm	
71	23.12.2023	01.35 pm	02.45 pm	2722	Exhaust fan not working	Nepro ward	25.12.2023	04.00 pm	
72	26.12.2023	12.30 pm	12.30 pm	3423	Tharmameter not working	PED.WD 03	26.12.2023	12.38 pm	
73	26.12.2023	01.18 pm	01.18 pm	1306	Wall fan not working	Central Store	26.12.2023	02.00 pm	
74	26.12.2023	01.18 pm	01.19 pm	1307	Req.New Tharmameter	Central Store	26.12.2023	01.20 pm	
75	26.12.2023	09.50 pm	10.15 am	1155	LED Light not working	Dental OPD	26.12.2023	11.00 am	
76	26.12.2023	11.00 am	11.25 am	5768	Bathroom light not working	MICU	26.12.2023	12.45 pm	

77	26.12.2023	11.00 am	11.25 am	5769	Switch Board not working	MICU	26.12.2023	11.50 am	
78	26.12.2023	01.03 pm	12.45 pm	1176	Tube light not working	Microbiology	27.10.2023	12.50 pm	
79	26.12.2023	11.00 am	02.11 pm	809	LED Light not working	Endoscopy	27.12.2023	03.35 pm	
80	26.12.2023	11.18 am	01.11 pm	245	Focus lamp not working	OBGY Ward 03	26.12.2023	02.00 pm	
81	27.12.2023	12.55 pm	12.20 pm	1707	Main supply Fail	Anaestheciya Dept.	27.12.2023	11.45 am	
82	27.12.2023	10.45 am	10.45 am	3424	Extension Board not working	PED Ward 01	27.12.2023	10.50 am	
83	27.12.2023	10.12 am	10.20 am	2057	Switch Board not working	Cath-lab	27.12.2023	10.43 am	
84	27.12.2023	10.45 am	11.20 am	11	LED Light not working	MCRI OPD	27.12.2023	01.00 pm	
85	28.12.2023	10.25 am	10.27 am	2149	Power supply Failure	Central lab	28.12.2023	10.45 am	
86	28.12.2023	12.00 pm	12.00 pm	243	Switch Board not working	Blood Bank	28.12.2023	12.05 pm	
87	28.12.2023	10.50 am	01.31 pm	315	DR. room light not working	Endoscopy	03.01.2024	01.36 pm	
88	28.12.2023	11.30 am	11.45 am	454	Switch Board not working	Isolation ICU	28.12.2023	12.00 pm	
89	28.12.2023	10.15 am	11.00 am	3629	Booster pump not working	Fire Dept.	28.12.2023	11.15 am	
90	28.12.2023	03.02 pm	03.35 pm	7439	LED Bulb not working	Anatomy	28.12.2023	04.00 pm	
91	29.12.2023	05.30 pm	06.00 pm	434	Water Pump not working	Dialysis	31.12.2023	06.30 pm	
92	30.12.2023	10.00 am	10.30 am	1788	Celling Fan not Working	FSW 01	30.12.2023	10.30 am	
93	30.12.2023	10.20 am	10.45 am	2553	LED Tube light not working	Record section	30.12.2023	11.00 am	
94	30.12.2023	11.10 am	11.55 am	4937	LED Tube light not working	Psy ward	30.12.2023	12.00 pm	
95	30.12.2023	02.19 pm	02.38 pm	108	Celling Fan not Working	Opthal opd	02.01.2024	10.39 am	
96	30.12.2023	02.38 pm	03.00 pm	1102	LED Tube light not working	OT Complex	31.12.2023	04.00 pm	
97	30.12.2023	11.40 am	11.55 am	2338	Switch Board not working	Psy ward	30.12.2023	12.00 pm	
98	31.12.2023	12.20 pm	12.15 pm	1316	Switch board not working	EMS -P	31.12.2023	12.20 pm	

**Electrical Supervisor  
MGM-EED Aurangabad**

**Electrical Engineer  
MGM-EED Aurangabad**

**Technical Executive(Elect.  
MGM-EED Aurangabad**

**HOD  
MGM-EED Aurangabad**

**MGM MEDICAL COLLEGE & HOSPITAL**  
**ELECTRICAL MAINTANCE REPORT 01 Jan 2024 to 31 Jan 2024**

Sr.No.	Received Date	Time	Attende Time	Response Time	Cpmplaint No.	Nature Of Complent	Name Of Department	Date Of Completion	Close Time	Remark
1	01.01.2024	11	12.41	1.41	1530	LED Tube light not working	MJPJAY ICU	01.01.2024	01.10 pm	
2	01.01.2024	11	12.41	1.41	1529	Switch Board not working	MJPJAY ICU	01.01.2024	12.55 pm	
3	01.01.2024	10.54	12.39	1.85	349	LED Tube light not working	MMW WD 02	03.01.2024	05.20 pm	
4	01.01.2024	11.38	14.15	2.77	924	LED Light not working	Dayotan Hall	02.01.2024	02.40 pm	
5	01.01.2024	11.25	11.3	0.05	136	Switch Board not working	Physiotherepy Collage	01.01.2024	11.45 am	
6	02.01.2024	11.17	11.5	0.33	2339	Wall fan not working	PSY WD	02.01.2024	01.08 pm	
7	02.01.2024	15.45	15.45	0	2060	Install The spot Light 02 NOS	Cathlab	02.01.2024	05.45 pm	
8	03.01.2024	7.26	9.3	2.04	444	Lift no 01 Not working	Time office	03.01.2024	10.04 am	
9	03.01.2024	15.15	15.45	0.3	258	Switch Board not working	Dialysis	03.01.2024	04.01 pm	
10	04.01.2024	9.45	9.5	0.05	138	All Department light not work	Physiotherepy Collage	04.01.2024	10.04 am	
11	04.01.2024	11.5	12.15	0.65	5779	LED Light not working	MICU	04.01.2024	03.47 pm	
12	05.01.2024	10.3	10.4	0.1	466	Switch Board not working	Isolation ICU	05.01.2024	11.10 am	
13	05.01.2024	10.3	11.4	1.1	1323	LED Light not working	EMS -P	05.01.2024	01.10 pm	
14	05.01.2024	8.3	9.3	1	1667	LED Light not working	SICU	05.01.2024	10.30 am	
15	05.01.2024	10.45	12	1.55	2292	LED Tube light not working	FMW WD 02	05.01.2024	12.15 pm	
16	05.01.2024	14.45	15	0.55	7490	LED Tube light not working	Anatomy	05.01.2024	03.15 pm	
17	05.01.2024	14.15	15.45	1.3	353	LED Tube light not working	MMW 01	05.01.2024	04.00 pm	
18	05.01.2024	15.15	15.4	0.25	1468	LED Tube light not working	OBGY 02 WD	05.01.2024	04.20 pm	
19	06.01.2024	9.31	10	0.69	1108	Switch Board not working	MSW 01	06.01.2024	11.30 am	
20	06.01.2024	9.3	10	0.7	1109	LED Tube light not working	MSW 01	06.01.2024	11.30 am	
21	06.01.2024	11.17	11.19	0.02	950	Tharmameter not working	NICU	06.01.2024	11.20 am	
22	06.01.2024	11.5	15.06	3.56	1724	Celling Fan not Working	Surgery opd	06.01.2024	03.55 pm	
23	06.01.2024	10	10	0	952	Switch Board not working	NICU	06.01.2024	10.15 am	
24	06.01.2024	16.12	16.23	0.11	1029	Switch Board not working	OT Complex	06.01.2024	04.45 pm	
25	06.01.2024	9.55	10.35	0.8	448	Lift Light not working	Time office	06.01.2024	11.15 am	
26	06.01.2024	11.25	11.4	0.15	1326	Switch Board not working	EMS -P	06.01.2024	11.45 am	
27	06.01.2024	13	15.25	2.25	1905	LED Light not working	Ophthal OT	06.01.2024	04.32 pm	
28	08.01.2024	9.3	9.3	0	569	LED Light hanging	Labour Room	08.01.2024	09.45 am	
29	08.01.2024	11.2	11.2	0	5783	Extension Board not working	MICU	08.01.2024	11.35 am	
30	08.01.2024	11.2	11.25	0.05	5782	LED Light not working	MICU	08.01.2024	11.40 am	
31	08.01.2024	11.54	12.18	0.64	1784	LED Tube light not working	FSW 02	08.01.2024	03.11 pm	
32	08.01.2024	15	15.55	0.55	1027	LED Tube light not working	OT Complex	08.01.2024	04.00 pm	
33	08.01.2024	17	17	0	1033	Req. new switch board	OT Complex	08.01.2024	07.34 pm	
34	08.01.2024	16.3	16.5	0.2	925	LED Light not working	Super Deluxe	09.01.2024	11.00 amS	

*(Handwritten Signature)*  
24/10/24

35	09.01.2024	11.28	11.45	0.17	2293	Led Tube light not working	FMW 02	09.01.2024	12.10 pm	
36	09.01.2024	11.3	11.3	0	1324	Extension Board not working	EMS -P	09.01.2024	12.00 pm	
37	09.01.2024	11.29	14	2.71	484	LED Tube light not working	MJPJAY Ward	09.01.2024	03.00 pm	
38	09.01.2024	8	9.25	1.25	449	Lift no 05 not working	Time office	09.01.2024	10.00 am	
39	10.01.2024	11.15	11.35	0.2	1725	LED Tube light not working	Surgury opd	10.01.2024	11.55 am	
40	10.01.2024	10.06	12	1.94	450	LED Tube light not working	Time office	10.01.2024	12.31 pm	
41	10.01.2024	4.1	16.49	12.39	1968	Celling Fan not Working	Central Liabrary	11.01.2024	12.05 pm	
42	10.01.2024	16.1	17	0.9	2062	Pedastral Fan not working	Cathlab	11.01.2024	03.20 pm	
43	10.01.2024	11.3	12.45	1.15	3370	LED Tube light not working	PSM Department	10.01.2024	03.20 pm	
44	11.01.2024	8.45	9	0.55	2783	LED Tube light not working	Male Ortho Ward	11.01.2024	09.07 am	
45	11.01.2024	16	16.3	0.3	2953	Switch Board not working	OBGY ICU	12.01.2024	03.50 pm	
46	11.01.2024	12.51	14.35	1.84	1185	Switch Board not working	Microbiology	11.01.2024	02.44 pm	
47	12.01.2024	11	11.5	0.5	485	LED Bulb not working	Physiotherepy Opd	12.01.2024	12.10 pm	
48	12.01.2024	11.05	11.25	0.2	3436	Switch Board not working	Pead.ward 01	12.01.2024	12.20 pm	
49	12.01.2024	16.4	16	-0.4	254	Remove the skylighter	OBGY WD 03	12.01.2024	06.00 pm	
50	13.01.2024	9.15	9.3	0.15	1040	Switch Board not working	OT Complex	13.01.2024	10.00 am	
51	13.01.2024	9.35	9.5	0.15	472	Extension Board not working	Isolation ICU	13.01.2024	10.45 am	
52	13.01.2024	16.4	17.2	0.8	3155	LED Tube light not working	Linen Department	15.01.2024	11.45 am	
53	13.01.2024	11	11.28	0.28	928	LED Light not working	Super Deluxe	15.01.2024	11.15 am	
54	13.01.2024	17.3	18	0.7	5988	LED Tube & Fan not working	CSSD	15.01.2024	10.45 am	
55	14.01.2024	17.3	18.25	0.95	461	Lift no 01 Not working	Time office	14.01.2024	07.15 pm	
56	15.01.2024	12	12.35	0.35	1159	Req.Projector cable Laying	Dental opd	15.01.2024	03.00 pm	
57	15.01.2024	13.1	14	0.9	27	LED Light not working	MCRI OPD	15.01.2024	03.15 pm	
58	15.01.2024	14.45	15	0.55	4295	Camera cable laying work	IT Department	15.01.2024	03.45 pm	
59	15.01.2024	14.3	15	0.7	1044	Switch Board not working	OT Complex	15.01.2024	03.30 pm	
60	15.01.2024	15.4	16	0.6	464	Founton not working	Time office	17.01.2024	02.48 pm	
61	15.01.2024	6.37	7.3	0.93	642	Lift no 01 Not working	Time office	15.01.2024	08.00 am	
62	15.01.2024	17.45	18.2	0.75	995	LED Tube light not working	Pead.Ward 02	16.01.2024	10.00 am	
63	16.01.2024	18.26	18.45	0.19	468	Lift no 01 Not working	Time office	16.01.2024	07.20 pm	
64	16.01.2024	14	15	1	993	Exhust fan not working	Pead.Ward 02	16.01.2024	03.35 pm	
65	16.01.2024	15.3	15.4	0.1	5788	Exhust fan not working	MICU	16.01.2024	04.00 pm	
66	16.01.2024	10	10	0	Latter	All G Toilet check Tube&e.fan	Time office	16.01.2024	04.50 pm	
67	16.01.2024	11.51	12	0.49	261	Switch Board not working	Dialysis	16.01.2024	02.30 pm	
68	17.01.2024	11.2	11.3	0.1	689	Casing patti Broken	FSW 03	17.01.2024	11.55 am	
69	17.01.2024	10.24	10.5	0.26	1618	Tharmameter not working	FMW 01	17.01.2024	11.00 am	
70	17.01.2024	9.35	10.2	0.85	256	Celling Fan not Working	OBGY WD 03	17.01.2024	12.20 pm	
71	17.01.2024	17	17.3	0.3	248	Switch Board not working	Blood Bank	19.01.2024	04.20 pm	
72	17.01.2024	10.5	14	3.5	292	Celling Fan not Working	Medical Store	17.01.2024	02.30 pm	
73	18.01.2024	10	10	0	2349	Wall Fan not working	PSY WD	18.01.2024	02.00 pm	



74	18.01.2024	16.4	16.5	0.1	1160	Celling Fan not Working	Dental opd	19.01.2024	11.00 am	
75	18.01.2024	10.3	13.45	3.15	473	Celling Fan not Working	Pul.medi.ward	18.01.2024	02.10 pm	
76	18.01.2024	14	15.3	1.3	4094	Req.new Extension board	MCRI OPD	18.01.2024	04.15 pm	
77	19.01.2024	8.15	9.3	1.15	2350	LED Tube light not working	PSY WD	19.01.2024	10.00 am	
78	19.01.2024	10.2	10.4	0.2	3069	Gizer not working	MCRI ICU	19.01.2024	11.30 am	
79	19.01.2024	15.1	15.25	0.15	1477	Fan regulator cap brokrn	OBGY WD 02	19.01.2024	04.20 pm	
80	19.01.2024	16.45	17.15	0.7	293	LED Light not working	Medical Store	20.01.2024	10.00 am	
81	19.01.2024	16.2	16.5	0.3	7754	Req.new Extension board	OBGY Dept.	25.01.2024	03.30 pm	
82	19.01.2024	16.25	16.25	0	1904	Fan regulator cap brokrn	MSW 03	19.01.2024	04.35 pm	
83	20.01.2024	10	11.4	1.4	1419	Celling Fan not Working	Biochemistry Dept.	20.01.2024	12.09 pm	
84	20.01.2024	15.4	16.15	0.75	3889	R.no. 656 Light not working	Old Deluxe	20.01.2024	05.35 pm	
85	20.01.2024	13	16	3	323	LED Light not working	MRD 02	20.01.2024	04.45 pm	
86	20.01.2024	16.1	16.15	0.05	590	LED Tube light not working	PSY OPD	23.01.2024	03.02 pm	
87	20.01.2024	13	14	1	5797	Install the new exhust fan	MICU	06.02.2024	03.00 pm	
88	20.01.2024	16.1	16.15	0.05	591	Req.New Tube light	PSY OPD	23.01.2024	03.02 pm	
89	20.01.2024	16	16.1	0.1	5993	Auto-clove m/c not working	CSSD	20.01.2024	04.30 pm	
90	21.01.2024	9	9.1	0.1	4480	Switch Board not working	Dialysis	21.01.2024	09.30 am	
91	21.01.2024	12.2	12.25	0.05	2153	Power supply Off	Central Lab	21.01.2024	12.54 pm	
92	23.01.2024	10.2	11	0.8	2789	LED Tube light not working	Male Ortho Ward	23.01.2024	11.25 am	
93	23.01.2024	14.35	15.05	0.7	488	LED Tube light not working	MJPIAY Ward	23.01.2024	04.10 pm	
94	23.01.2024	12.3	16	3.7	1336	LED Light not working	EMS -P	23.01.2024	04.50 pm	
95	24.01.2024	10.2	10.2	0	3442	Tharmameter not working	Pead.Wd 01	24.01.2024	10.25 am	
96	24.01.2024	10	10	0	1061	Req.new Extension board	ENT OPD	24.01.2024	12.31 pm	
97	24.01.2024			0	803	Gizer not working	MICU	25.01.2024	02.40 pm	
98	24.01.2024	14.45	15	0.55	1271	LED Light not working	Casualty	25.01.2024	03.23 pm	
99	24.01.2024			0	3070	Gizer not working	MCRI ICU	29.01.2024	02.47 pm	
100	24.01.2024	10.3	15.3	5	1714	Celling Fan not Working	Anaesthesia Dept	25.01.2024	04.10 pm	
101	24.01.2024	14.36	14.5	0.14	1068	LED Tube light not working	OT Complex	24.01.2024	03.10 pm	
102	25.01.2024	11.37	14.45	3.08	607	Switch Board not working	New Deluxe	25.01.2024	03.00 pm	
103	25.01.2024	11.35	15	3.65	606	Exhust fan not working	New Deluxe	08.02.2024	10.25 am	
104	25.01.2024	15.15	15.15	0	471	Tharmameter not working	CVTS	25.01.2024	03.20 pm	
105	27.01.2024	11.11	11.3	0.19	1219	Focus lamp not working	OBGY OPD	27.01.2024	11.45 am	
106	27.01.2024	10.5	11.2	0.7	1339	LED Light not working	EMS -P	27.01.2024	02.15 pm	
107	27.01.2024	10.43	11	0.57	956	LED Light not working	KT ICU	27.01.2024	02.45 pm	
108	27.01.2024	15	15	0	3296	Switch Board not working	Pead.Dept	27.01.2024	03.15 pm	
109	29.01.2024	11	12.45	1.45	1279	LED Light not working	Casualty	29.01.2024	01.40 pm	
110	30.01.2024			0	1727	Celling Fan not Working	Surgury opd	30.01.2024	10.00 am	
111	30.01.2024	10.15	10.2	0.05	972	Switch Board not working	Surgury wd 02	30.01.2024	10.28 am	
112	30.01.2024	11.15	11.3	0.15	2745	Exhust fan not working	Pead. OPD	30.01.2024	12.03 pm	

113	30.01.2024	12.28	12.5	0.22	1556	Celling Fan not Working	F. Ortho WD	30.01.2024	02.33 pm	
114	30.01.2024	15.48	15.55	0.07	1972	Bathroom light not working	Central Liabrary	30.01.2024	04.05 pm	
115	31.01.2024	11.25	11.45	0.2	3898	Switch Board not working	Old Deluxe	30.01.2024	11.45 am	

**Electrical Supervisor**  
MGM-EED Aurangabad

**Electrical Engineer**  
MGM-EED Aurangabad

**Technical Executive(Elect.)**  
MGM-EED Aurangabad

**HOD**  
MGM-EED Aurangabad

**MGM MEDICAL COLLEGE & HOSPITAL**  
**ELECTRICAL MAINTANCE REPORT 01 Feb 2024 to 29 Feb 2024**

Sr.No.	Received Date	Time	Attende Time	Response Time	Cpmplaint No.	Nature Of Complent	Name Of Department	Date Of Complation	Close Time	Remark
1	01.02.2024	15.4	16	0.6	142	Switch Board not working	Physiotherepy Collage	01.02.2024	04.15 pm	
2	01.02.2024	12.35	15	2.65	975	Switch Board not working	Surgury Ward Male 02	01.02.2024	03.30 pm	
3	01.02.2024	14.45	15.25	0.8	487	Lift no 05 not working	Time office	01.02.2024	04.00 pm	
4	01.02.2024	15.3	16	0.7	1114	Switch Board not working	Male Surgury Ward 01	01.02.2024	04.20 pm	
5	01.02.2024	13.45	14.2	0.75	1973	cctv cable fix	Central Liabrary	03.02.2024	11.20 pm	
6	02.02.2024	11.4	12.15	0.75	143	Switch Board not working	Physiotherepy Collage	03.02.2024	11.00 am	
7	03.02.2024	12.39	12.39	0	611	Extension Board not working	New Deluxe	03.02.2024	02.17 pm	
8	04.02.2024	16.24	16.24	0	2355	Wall Fan not working	Psy Ward	07.02.2024	09.45 am	
9	05.02.2024	12.44	14.15	1.71	2732	Switch Board not working	Nephro Ward	05.02.2024	03.00 pm	
10	05.02.2024	10.4	10.4	0	2792	Bathroom light not working	Male Ortho Ward	05.02.2024	10.55 am	
11	06.02.2024	10.05	10.05	0	170	All Department light not work	Physiotherepy Collage	06.02.2024	10.10 am	
12	06.02.2024	10.3	11	0.7	490	Lift no 03 not working	Time office	06.02.2024	11.45 am	
13	06.02.2024	12.26	15.1	2.84	579	Focus lamp not working	Labour Room	06.02.2024	03.25 pm	
14	07.02.2024	10.46	14.45	3.99	3802	LED Tube light not working	Female Surgury Ward 01	07.02.2024	03.00 pm	
15	07.02.2024	15	15.45	0.45	3216	Celling Fan not Working	Skin Ward	08.02.2024	02.50 pm	
16	07.02.2024	10.45	14.5	4.05	3801	Celling Fan not Working	Female Surgury Ward 01	07.02.2024	03.10 pm	
17	08.02.2024	8.05	8.05	0	2733	Electricity power off all ward	Nepro Ward	08.02.2024	08.10 am	
18	08.02.2024	11.2	11.5	0.3	3449	Gizer not working	Pead. Ward 01	08.02.2024	12.05 pm	
19	08.02.2024	10	10.2	0.2	492	Shp motor not working	Time office	08.02.2024	11.00 am	
20	08.02.2024	10.15	14.4	4.25	2967	Switch Board not working	OBGY ICU	08.02.2024	03.00 pm	
21	08.02.2024	17.15	17.15	0	268	Reprocessing m/c pump not wo	Dialysis	08.02.2024	06.00 pm	
22	08.02.2024	10.15	14.4	4.25	2966	View box not working	OBGY ICU	08.02.2024	03.00 pm	
23	09.02.2024	10	10.2	0.2	Latter	Switch Board not working	OT Complex	09.02.2024	10.10 am	
24	09.02.2024	13.5	14.15	0.65	936	Celling Fan not Working	Super Deluxe	09.02.2024	02.20 pm	
25	09.02.2024	17.45	17.45	0	492	Bell not working	MJPJAY Ward	09.02.2024	06.03 pm	
26	10.02.2024	9.3	11.1	1.8	983	Switch Board not working	NICU	10.02.2024	11.40 am	
27	10.02.2024	11.1	12.3	1.2	4565	LED Light not working	EICU	10.02.2024	12.55 pm	
28	11.02.2024	11.5	12.5	1	40	Bathroom light not working	MCRI OPD	11.02.2024	12.00 pm	
29	12.02.2024	9.31	10	0.69	496	Lift no 05 not working	Time office	12.02.2024	11.00 am	
30	12.02.2024	11.01	11.3	0.29	1686	LED Light not working	SICU	12.02.2024	12.00 pm	
31	12.02.2024	13.5	15.3	1.8	983	Exhust fan not working	Surgury Ward Male 02	12.02.2024	04.00 pm	
32	12.02.2024	10.3	15.55	5.25	937	LED Light not working	Super Deluxe	12.02.2024	05.20 pm	
33	12.02.2024	12.3	17.3	5	616	Switch Board not working	New Deluxe	13.02.2024	04.02 pm	
34	12.02.2024	7.2	9	1.8	501	Lift no 06 not working	Time office	12.02.2024	10.40 am	

*(Handwritten signature)*  
W.P. Ambekar  
24/10/24

35	12.02.2024	17.4	18.3	0.9	500	Lift no 01 Not working	Time office	13.02.2024	03.10 pm	
36	13.02.2024	14.35	15.2	0.85	1292	LED Light not working	Casualty	13.02.2024	03.50 pm	
37	13.02.2024	11.1	16	4.9	4956	Tharmameter not working	FMW 02	13.02.2024	04.10 pm	
38	13.02.2024	11.21	14	2.79	1035	LED Light not working	OT Complex	15.02.2024	12.50 pm	
39	13.02.2024	16	16.35	0.35	252	Ac not working	Blood Bank	14.02.2024	10.00 am	
40	13.02.2024	16.4	16.5	0.1	369	LED Light not working	MCRI Ortho OPD	13.02.2024	04.24 pm	
41	14.02.2024	15.31	15.55	0.24	476	Tharmameter not working	CVTS	14.02.2024	03.25 pm	
42	14.02.2024	15	17	2	1633	Switch Board not working	FMW 01	14.02.2024	05.35 pm	
43	15.02.2024	12.45	12.45	0	1099	LED Light not working	OT Complex	15.02.2024	12.50 pm	
44	15.02.2024	12.45	18	5.55	2799	Celling Fan not Working	Male Ortho Ward 01	15.02.2024	06.45 pm	
45	15.02.2024	16	16.1	0.1	940	Tharmameter not working	Super Deluxe	16.02.2024	11.10 am	
46	15.02.2024	15.3	16	0.7	7495	LED Light not working	Anatomy	04.03.2024	02.45 pm	
47	15.02.2024	12.45	14.25	1.8	2798	Exhust fan not working	Male Ortho Ward 01	16.02.2024	10.35 pm	
48	16.02.2024	13.1	14	0.9	1100	AC Ducts has to be clean	OT Complex	16.02.2024	02.30 pm	
49	16.02.2024	12.15	12.3	0.15	1974	Table fan not working	Central Liabrary	04.04.2024	12.30 pm	
50	16.02.2024	10.3	11.45	1.15	941	Light Hanging	Super Deluxe	16.02.2024	02.15 pm	
51	17.02.2024	10.3	10.35	0.05	701	Switch Board not working	OT Complex	17.02.2024	10.50 am	
52	17.02.2024	9.45	11.45	2	1483	Exhust fan not working	OBGY WD 02	17.02.2024	12.05 pm	
53	17.02.2024	14.1	14.3	0.2	1374	Exhust fan not working	OBGY WD 01	17.02.2024	03.00 pm	
54	17.02.2024	11.05	12.45	1.4	1733	Exhust fan not working	Female Surgury Ward 01	17.02.2024	02.15 pm	
55	20.02.2024	11	11.3	0.3	706	Passage Light not working	OT Complex	20.02.2024	12.40 pm	
56	20.02.2024	10	10.1	0.1	2272	Light & fan connection	STP/ETP	20.02.2024	02.00 pm	
57	20.02.2024	15.2	16	0.8	1918	Celling Fan not Working	MSW 03	20.02.2024	04.00 pm	
58	20.02.2024	14	15.3	1.3	506	Motor Starter not working	HR Dept	20.02.2024	04.00 pm	
59	20.02.2024	9.31	9.31	0	1881	Tharmameter not working	Male Ortho Ward 02	21.02.2024	10.00 am	
60	21.02.2024	10.3	10.3	0	593	Burning smell	PSY OPD	21.02.2024	10.40 am	
61	21.02.2024	10.45	11.15	0.7	254	LED Light not working	Blood Bank	21.02.2024	11.45 am	
62	21.02.2024	11	14	3	1484	Celling Fan not Working	OBGY 02 WD	21.02.2024	02.35 pm	
63	21.02.2024	14.29	14.29	0	322	Tharmameter not working	ENT WD	21.02.2024	02.30 pm	
64	22.02.2024	9.35	9.35	0	1122	LED Tube light not working	Physiology Dept	22.02.2024	10.45 am	
65	22.02.2024	10	10	0	4568	Tharmameter not working	EICU	22.02.2024	10.10 am	
66	22.02.2024	9.32	13	3.68	267	LED Tube light Hanging	OBGY WD 03	22.02.2024	01.45 pm	
67	22.02.2024	12.15	14	1.85	1484	Celling Fan not Working	OBGY WD 02	22.02.2024	02.55 pm	
68	22.02.2024	12.15	14	1.85	1485	Bathroom light not working	OBGY WD 02	22.02.2024	02.55 pm	
69	22.02.2024	12	12	0	3453	Tharmameter not working	Pead.Wd 01	22.02.2024	12.10 pm	
70	22.02.2024	16.43	16.58	0.15	147	Switch Board not working	Physiotherepy Collage	23.02.2024	10.10 am	
71	22.02.2024	11.45	11.5	0.05	2271	Motor not working	STP/ETP	22.02.2024	12.20 pm	
72	22.02.2024	16	16.25	0.25	2363	Switch Board not working	PSY WD	24.02.2024	11.50 aam	
73	22.02.2024	16	16.25	0.25	2361	LED Light not working	PSY WD	24.02.2024	11.50 aam	

74	22.02.2024	9.45	10.4	0.95	513	Lift no 06 not working	Time office	22.02.2024	12.30 am	
75	22.02.2024	19.3	19.55	0.25	508	Lift no 06 not working	Time office	24.02.2024	03.00 pm	
76	22.02.2024	13.4	14	0.6	1555	Ac not working	MJPJAY ICU	22.02.2024	02.50 pm	
77	23.02.2024	11	11.1	0.1	4961	Power supply Off	FMW 02	23.02.2024	11.20 am	
78	23.02.2024	9.15	10.3	1.15	1573	Exhust fan not working	Female Ortho Ward	23.02.2024	11.10 am	
79	23.02.2024	12	14.55	2.55	2554	LED Tube light not working	Record Section	24.02.2024	10.00 am	
80	23.02.2024	10.35	11	0.65	269	Celling Fan not Working	OBGY 03	23.02.2024	11.35 am	
81	23.02.2024	12.25	13.1	0.85	1560	Switch Board not working	MJPJAY ICU	23.02.2024	02.00 pm	
82	23.02.2024	10.35	11	0.65	269	Celling Fan not Working	OBGY WD 03	23.02.2024	11.35 am	
83	24.02.2024	12.47	13.35	0.88	2906	Cabin Fan not working	MCRI ICU	26.02.2024	03.45 pm	
84	24.02.2024	9.45	10.2	0.75	1206	LED Light not working	Swab Collection Dept.	24.02.2024	10.45 am	
85	25.02.2024	7.2	9.45	2.25	517	Lift no 06 not working	Time office	25.02.2024	10.30 am	
86	26.02.2024	12.5	14	1.5	1212	X-Ray machine pin not work	Casualty	26.02.2024	02.30 pm	
87	26.02.2024	10.45	11.3	0.85	366	LED Tube light not working	MMW	26.02.2024	12.00 pm	
88	26.02.2024	10.5	11	0.5	1197	LED Tube light not working	Microbiology	26.02.2024	11.25 am	
89	26.02.2024	9.2	11	1.8	925	LED Light not working	Dayotan Hall	28.02.2024	04.25 pm	
90	26.02.2024	16.04	16.5	0.46	586	Switch Board not working	Labour Room	26.02.2024	05.17 pm	
91	27.02.2024	15.11	15.11	0	587	Extension Board not working	Labour Room	27.02.2024	03.18 pm	
92	27.02.2024	16.05	16.3	0.25	7726	Celling Fan not Working	OBGY Dept.	27.02.2024	04.50 pm	
93	27.02.2024	15	15.3	0.3	7492	Req.the new switch board	Anatomy	27.02.2024	04.00 pm	
94	27.02.2024	15.11	15.27	0.16	277	Switch Board not working	Dialysis	27.02.2024	04.30 pm	
95	28.02.2024	8.19	11	2.81	522	Lift no 05 Light not working	Time office	28.02.2024	11.45 am	
96	28.02.2024	14.15	14.15	0	270	Tharmameter not working	OBGY WD 03	28.02.2024	02.15 pm	
97	28.02.2024	11.3	11.3	0	2914	Extension Board not working	MCRI ICU	28.02.2024	11.45 am	
98	28.02.2024	13	13.45	0.45	2913	Extension Board not working	MCRI ICU	28.02.2024	02.30 pm	
99	28.02.2024	19.45	19.57	0.12	3610	Switch Board not working	NICU	28.02.2024	07.50 pm	
100	29.02.2024	11.15	11.4	0.25	524	Parking lift not working	Time office	29.02.2024	12.25 pm	
101	29.02.2024	8.5	9.35	0.85	523	Lift no 01 Not working	Time office	29.02.2024	10.45 am	
102	29.02.2024	11.3	11.45	0.15	858	LED Light not working	2 D Echo	29.02.2024	12.10 pm	

**Electrical Supervisor**  
MGM-EED Aurangabad

**Electrical Engineer**  
MGM-EED Aurangabad

**Technical Executive(Elect.)**  
MGM-EED Aurangabad

**HOD**  
MGM-EED Aurangabad

**MGM MEDICAL COLLEGE & HOSPITAL**  
**ELECTRICAL MAINTANCE REPORT 01 Mar 2024 to 31 Mar 2024**

Sr.No.	Received Date	Time	Attende Time	Response Time	Cpmplaint No.	Nature Of Complent	Name Of Department	Date Of Complation	Close Time	Remark
1	01.03.2024	9.55	11.5	1.95	2368	Wall Fan not working	PSY Ward	01.03.2024	12.20 pm	
2	01.03.2024	11	14	3	64	LED Light not working	MCRI OPD	01.03.2024	02.35 pm	
3	01.03.2024	10.3	12	1.7	1359	Switch Board not working	EMS -P	01.03.2024	12.40 pm	
4	01.03.2024	15	15	0	1644	Tharmameter not working	FMW 01	01.03.2024	03.00 pm	
5	01.03.2024	15.3	16.45	1.15	4104	Switch Board not working	CSSD	01.03.2024	05.05 pm	
6	01.03.2024	15.3	16	0.7	1125	Fan & Tube not working	Anatomy	02.03.2024	12.15 pm	
7	01.03.2024	15.3	11	-4.3	1422	Switch Board not working	Biochemistry Dept.	02.03.2024	11.45 am	
8	01.03.2024	10.35	10.4	0.05	537	6th floor motor not working	Time office	01.03.2024	11.30 pm	
9	01.03.2024	11	11.25	0.25	526	Collage lift not working	Time office	01.03.2024	12.00 pm	
10	01.03.2024	16.5	16.5	0	531	Celling Fan not Working	Time office	01.03.2024	05.10 pm	
11	02.03.2024	9.45	10.3	0.85	2744	Gizer not working	Nepro Ward	02.03.2024	11.00 am	
12	02.03.2024	14.4	15.45	1.05	272	Focus lamp not working	OBGY WD 03	02.03.2024	04.00 pm	
13	02.03.2024	14.35	15	0.65	3089	LED Light not working	MCRI ICU	02.03.2024	03.50 pm	
14	02.03.2024	14.35	15	0.65	3090	Exhust fan not working	MCRI ICU	02.03.2024	03.50 pm	
15	02.03.2024	12.15	16.4	4.25	1198	Req.new LED Light	Microbiology	04.03.2024	12.00 pm	
16	03.03.2024	9.05	9.35	0.3	534	Lift not working medical collage	Time office	03.03.2024	10.00 am	
17	04.03.2024	16.1	16.3	0.2	536	Lift no 03 not working	Time office	04.03.2024	05.30 pm	
18	04.03.2024	10.19	11	0.81	7499	Celling Fan not Working	Anatomy	05.03.2024	04.50 pm	
19	05.03.2024	9.45	9.5	0.05	7205	LED Tube light hanging	Pead. Ward 01	05.03.2024	10.05 am	
20	05.03.2024	11.3	12	0.7	490	Switch Board not working	CCU	05.03.2024	12.40 pm	
21	05.03.2024	11.5	12	0.5	229	LED Tube light not working	RMO Office	05.03.2024	12.24 pm	
22	05.03.2024	16.42	16.49	0.07	610	Fan Regulator not working	Old Deluxe	06.03.2024	10.10 am	
23	05.03.2024	7.2	9	1.8	538	Lift no. 06 not working	Time office	05.03.2024	10.15 am	
24	06.03.2024	10.3	10.45	0.15	701	LED Tube light not working	Surgury Ward Male 02	06.03.2024	11.10 am	
25	06.03.2024	11.05	11.3	0.25	619	Exhust fan not working	Super Deluxe	06.03.2024	11.50 am	
26	06.03.2024	9.4	10.3	0.9	541	Collage lift not working	Time office	06.03.2024	11.40 am	
27	06.03.2024	12.5	15.45	2.95	3218	Celling Fan not Working	Dermatology skin opd	06.03.2024	04.15 pm	
28	06.03.2024	12.2	12.45	0.25	702	Exhust fan not working	Surgury Ward Male 02	06.03.2024	03.45 pm	
29	07.03.2024	11	11.2	0.2	491	Three pin top installation	CVTS	07.03.2024	11.45 am	
30	07.03.2024	13.52	14.35	0.83	545	Lift no 05 not working	Time office	07.03.2024	04.00 pm	
31	07.03.2024	12.3	13.45	1.15	805	Fan & Tube not working	Pharmacology	07.03.2024	02.30 pm	
32	07.03.2024	11	11.3	0.3	1571	Fan Regulator not working	MJPJAY ICU	07.03.2024	12.00 pm	
33	08.03.2024	10.25	11.5	1.25	328	LED Tube light not working	ENT WD	08.03.2024	12.00 pm	
34	08.03.2024	9.25	9.55	0.3	1492	Air cooler not working	OBGY WD 02	08.03.2024	10.15 am	

*Handwritten signature*  
24/10/24

35	08.03.2024	13.3	14	0.7	1671	LED Light not working	Excavite Deluxe	08.03.2024	02.35 pm	
36	09.03.2024	13.15	13.15	0	280	Switch Board not working	OBGY WD 03	09.03.2024	01.15 pm	
37	09.03.2024	11.15	15.45	4.3	1650	Switch Board not working	FMW	09.03.2024	04.15 pm	
38	09.03.2024	15.2	15.3	0.1	1420	Wall Fan not working	Dean Office	09.03.2024	04.30 pm	
39	09.03.2024	12.11	18	5.89	2104	Extension board not working	Pead.Ward 03	09.03.2024	06.22 pm	
40	09.03.2024	12.15	12.4	0.25	1599	Fan regulator cap brokern	Dermatology skin opd	11.03.2024	10.45 am	
41	09.03.2024	12.15	12.4	0.25	1598	LED Tube light not working	Dermatology skin opd	11.03.2024	11.47 am	
42	09.03.2024	12.15	12.15	0	2103	Extension Board not working	Pead.Ward 03	11.03.2024		
43	09.03.2024	11.3	12	0.7	735	LED Tube light not working	OT Complex	10.03.2024	04.15 pm	
44	11.03.2024	9	10.3	1.3	281	Fan Regulator not working	OBGY 03	11.03.2024	11.11 am	
45	11.03.2024	12.45	12.45	0	1600	LED Tube light not working	Dermatology skin opd	11.03.2024	12.50 pm	
46	11.03.2024	11.55	14.15	2.6	2371	LED Tube light not working	PSY Ward	11.03.2024	02.45 pm	
47	11.03.2024	15.55	15.55	0	2375	LED Light & Board not working	PSY Ward	11.03.2024	04.00 pm	
48	12.03.2024	13.1	13.4	0.3	2801	Water coolar not working	Anatomy	12.03.2024	02.20 pm	
49	12.03.2024	11.45	12.18	0.73	548	Wall Fan not working	Time office	13.03.2024	11.25 am	
50	12.03.2024	11.28	11.55	0.27	2745	Celling Fan not Working	Nepro Ward	12.03.2024	12.10 pm	
51	13.03.2024	12.45	13.35	0.9	497	Celling Fan not Working	MJPJAY Ward	18.03.2024	03.30 pm	
52	13.03.2024	11.3	12	0.7	1423	Req.new bell point	Biochemistry Dept.	13.03.2024	04.35 pm	
53	14.03.2024	15.13	15.35	0.22	951	All switch board checked	Super Deluxe	14.03.2024	04.35 pm	
54	14.03.2024	16.4	16.5	0.1	618	Switch Board not working	Old Deluxe	14.03.2024	05.00 pm	
55	15.03.2024	12.2	16	3.8	1582	LED Tube hanging	Female Ortho Ward	15.03.2024	04.15 pm	
56	16.03.2024	12	12	0	496	Celling Fan not Working	Physiotherepy OPD	16.03.2024	12.08 pm	
57	16.03.2024	12.1	12.25	0.15	2377	Wall Fan not working	PSY Ward	16.03.2024	12.50 pm	
58	16.03.2024	12.1	12.25	0.15	2379	LED Tube light not working	PSY Ward	16.03.2024	12.50 pm	
59	16.03.2024	13.04	13.04	0	1233	LED Light not working	Rediology	16.03.2024	01.15 pm	
60	16.03.2024	15.05	15.2	0.15	1778	LED Tube light not working	Central Store	16.03.2024	03.40 pm	
61	16.03.2024	12.4	18.3	5.9	1385	Gizer not working	OBGY Ward 01	16.03.2024	06.40 pm	
62	16.03.2024	11	11.35	0.35	751	LED Tube light not working	OT Complex	19.03.2024	03.30 pm	
63	16.03.2024	18	18.35	0.35	285	Switch Board not working	Dailysis	16.03.2024	07.00 pm	
64	16.03.2024	12.15	12.35	0.2	3459	LED Tube light not working	Pead.Ward 01	17.03.2024	10.25 am	
65	16.03.2024	20.35	20.51	0.16	1676	Bathroom light not working	Excavite Deluxe	16.03.2024	09.25 pm	
66	17.03.2024	13	13	0	286	Switch Board not working	Dailysis	17.03.2024	01.15 pm	
67	18.03.2024	10.45	11	0.55	74	Pedstral fan not working	MCRI OPD	18.03.2024	11.55 am	
68	18.03.2024	15.4	16.15	0.75	496	Exhust fan not working	Pul.medi.ward	28.03.2024	10.35 am	
69	18.03.2024	10.25	16.45	6.2	852	LED Light not working	MICU	18.03.2024	04.10 pm	
70	19.03.2024	10.45	11.3	0.85	76	LED Light not working	MCRI OPD	19.03.2024	01.30 pm	
71	19.03.2024	17	17	0	1376	View box not working	EMS -P	19.03.2024	05.20 pm	
72	19.03.2024	16.39	16.42	0.03	3739	Celling Fan not Working	Excavite Deluxe	20.03.2024	05.16 pm	
73	19.03.2024	8.2	9.3	1.1	556	Lift no 05 not working	Time office	19.03.2024	10.30 am	

74	20.03.2024	11.5	16.15	4.65	1387	Air cooler not working	OBGY WD 01	20.03.2024	04.35 pm
75	20.03.2024	11.4	12.15	0.75	767	Switch Board not working	OT Complex	21.03.2024	11.50 am
76	21.03.2024	14.25	14.5	0.25	1132	Switch Board not working	MSW 01	21.03.2024	03.10 pm
77	22.03.2024	14.3	14.5	0.2	497	LED Light not working	Physiotherapy OPD	22.03.2024	03.00 pm
78	22.03.2024	9.25	15	5.75	2381	LED Tube light not working	PSY Ward	22.03.2024	03.30 pm
79	22.03.2024	15.15	15.35	0.2	79	LED Light not working	MCRI OPD NO 25	22.03.2024	04.00 pm
80	22.03.2024	17	17.3	0.3	571	Lift no 04 not working	Time office	22.03.2024	06.25 pm
81	22.03.2024	12.15	12.4	0.25	844	Camera Shifting work	Endoscopy	29.03.2024	05.00 pm
82	22.03.2024	11.15	11.45	0.3	4	LED Tube light hanging	Male Medicine ward	22.03.2024	11.45 am
83	23.03.2024	11.45	11.45	0	375	Switch Board not working	Male Medicine ward	23.03.2024	12.10 pm
84	23.03.2024	11.42	12.3	0.88	2752	LED Tube light not working	Pead. OPD	26.03.2024	10.00 am
85	23.03.2024	11	12	1	1496	Air cooler not working	OBGY WD 02	23.03.2024	12.45 pm
86	24.03.2024	10.27	10.35	0.08	3463	Gizer not working	Pead. Ward 01	24.03.2024	11.45 am
87	24.03.2024	10.31	11	0.69	565	Lift no 01 Not working	Time office	24.03.2024	11.50 am
88	24.03.2024	10.1	11.5	1.4	771	LED Tube light not working	OT Complex	24.03.2024	12.10 pm
89	26.03.2024	10.3	10.45	0.15	82	Celling Fan not Working	MCRI OPD NO 13	26.03.2024	11.00 am
90	26.03.2024	11.45	11.45	0	1225	Switch Board not working	OBGY OPD	26.03.2024	12.05 pm
91	26.03.2024	14.15	15.31	1.16	772	Switch Board not working	OT Complex	26.03.2024	04.18 pm
92	26.03.2024	12.5	13.35	0.85	2388	Wall Fan not working	PSY WD	28.03.2024	11.25 am
93	26.03.2024	14.1	14.4	0.3	573	Lift no 4&05 not working	Time office	26.03.2024	05.30 pm
94	27.03.2024	9.3	10	0.7	7728	Bathroom light not working	OBGY WD	27.03.2024	10.30 am
95	27.03.2024	11	11.4	0.4	1377	LED Light not working	EMS -P	27.03.2024	05.15 pm
96	27.03.2024	14.35	14.5	0.15	709	Switch Board not working	Male surgery ward 02	27.03.2024	03.30 pm
97	27.03.2024	14.35	15.45	1.1	1391	Celling Fan not Working	OBGY WD 01	27.03.2024	04.05 pm
98	28.03.2024	11	11.1	0.1	2374	Wall Fan not working	PSY WD	28.03.2024	11.30 am
99	28.03.2024	10.4	11.5	1.1	4114	Switch Board not working	CSSD	28.03.2024	12.35 pm
100	28.03.2024	10.1	10.1	0	1169	LED Light not working	Dental opd	28.03.2024	11.00 am
101	28.03.2024	16	16.35	0.35	629	Switch Board not working	Old Deluxe	29.03.2024	10.15 am
102	28.03.2024	14.2	14.5	0.3	579	Lift no 05 not working	Time office	28.03.2024	03.35 pm
103	28.03.2024	16	16.35	0.35	630	Fan Regulator not working	Old Deluxe	29.03.2024	10.15 am
104	29.03.2024	10.45	11.5	1.05	711	Switch Board not working	Female Surgery Ward 01	29.03.2024	12.13 pm
105	29.03.2024	12.4	13.4	1	1127	LED Tube light not working	Anatomy	29.03.2024	02.10 pm
106	29.03.2024	9.05	10	0.95	580	Lift no 01 Not working	Time office	29.03.2024	11.00 am
107	29.03.2024	12.56	13.48	0.92	882	Air cooler not working	MJPJAY Dept	06.04.2024	11.45 am
108	29.03.2024	14.3	14.55	0.25	785	Celling Fan not Working	OT Complex	30.03.2024	10.30 am
109	30.03.2024	11.3	12	0.7	787	Switch Board not working	OT Complex	30.03.2024	12.25 pm
110	30.03.2024	10.2	10.2	0	1183	All light & fan not working	Urology ward	30.03.2024	10.35am
111	30.03.2024	12.45	13.45	1	1240	LED Light not working	Radiology	30.03.2024	02.25 pm
112	30.03.2024	14.45	15.3	0.85	1655	LED Tube light not working	Female Medicine ward	31.03.2024	03.45 pm



113	30.03.2024	10.25	10.55	0.3	581	R/O Water Motor not working	MCRI ICU	31.03.2024	10.40 am	
114	30.03.2024	14.12	14.45	0.33	4297	LED Light not working	IT Department	30.03.2024	03.11 pm	
115	31.03.2024	13.5	13.3	-0.2	583	Fish pot motor not working	Time office	31.03.2024	01.50 pm	
116	31.03.2024	10.1	12.25	2.15	584	1 HP Motor not working	Time office	31.03.2024	01.05 pm	

**Electrical Supervisor**  
MGM-EED Aurangabad

**Electrical Engineer**  
MGM-EED Aurangabad

**Technical Executive(Elect.)**  
MGM-EED Aurangabad

**HOD**  
MGM-EED Aurangabad

**MGM MEDICAL COLLEGE & HOSPITAL**  
**ELECTRICAL MAINTANCE REPORT 01 Apr 2024 to 30 Apr 2024**

Sr.No.	Received Date	Time	Attende Time	Response Time	Cpmlaint No.	Nature Of Complent	Name Of Department	Date Of Complation	Close Time	Remark
1	01.04.2024	18.4	18.4	0	1498	Req.new Extension board	OBGY 02 WD	01.04.2024	06.43 pm	
2	01.04.2024	11.1	11.35	0.25	2392	Wall Fan not working	PSY WD	03.04.2024	11.00 am	
3	01.04.2024	13	13.5	0.5	174	Celling Fan not Working	School of physiotherepy	03.04.2024	02.10 pm	
4	01.04.2024	9.36	12.3	2.94	4116	Call Bell not working	CSSD	10.04.2024	11.00 am	
5	01.04.2024	15.36	16	0.64	1658	Switch Board not working	Female medicine ward 01	02.04.2024	11.15 am	
6	02.04.2024	9.3	10.2	0.9	91	LED Light not working	MCRI OPD NO 12	02.04.2024	10.45 am	
7	02.04.2024	11	11.15	0.15	1392	Air cooler not working	OBGY WD 01	02.04.2024	11.45 am	
8	02.04.2024	12.4	13.45	1.05	715	LED Light not working	Female Surgury Ward 01	02.04.2024	04.25 pm	
9	02.04.2024	16.3	16.3	0	883	Pedstral fan feeting	MJPJAY ward	02.04.2024	04.38 pm	
10	02.04.2024	15.4	16.35	0.95	3744	Switch Board not working	Excative Deluxe	03.04.2024	10.40 am	
11	02.04.2024	9.31	11	1.69	963	Tharmameter not working	Super Deluxe	05.04.2024	11.20 am	
12	02.04.2024	10		#VALUE!	7730	Req.New switch board	OBGY	02.04.2024	12.15 pm	
13	03.04.2024	11	15.15	4.15	175	Air cooler not working	School of physiotherepy	05.04.2024	03.50 pm	
14	03.04.2024	11	11.25	0.25	2803	Celling Fan not Working	Anatomy	03.04.2024	11.50 am	
15	04.04.2024	10	10.3	0.3	1394	Celling Fan not Working	OBGY WD 01	04.04.2024	11.10 am	
16	04.04.2024	11	11.25	0.25	792	Switch Board not working	OT Complex	04.04.2024	11.40 am	
17	04.04.2024	12.1	12.1	0	3467	Table fan not working	Pead ward 01	04.04.2024	12.30 pm	
18	04.04.2024	12.1	12.1	0	3468	Tharmameter not working	Pead ward 01	04.04.2024	12.30 pm	
19	04.04.2024	11.55	12.25	0.7	979	Switch Board not working	KT ICU	04.04.2024	03.15 pm	
20	04.04.2024	15.2	16.25	1.05	1139	LED Tube light not working	Male surgury ward 01	04.04.2024	03.40 pm	
21	04.04.2024	10.45	12	1.55	1393	Air cooler not working	OBGY WD 01	08.04.2024	04.45 pm	
22	04.04.2024	11.3	12.25	0.95	151	Fan regulator not available	School of physiotherepy	04.04.2024	04.12 pm	
23	04.04.2024	16.4	16.55	0.15	1272	LED Light not working	MET Cell	25.04.2024	12.45 pm	
24	05.04.2024	10.2	10.25	0.05	1228	Fan & Tube not working	OBGY OPD	05.04.2024	10.43 am	
25	05.04.2024	11.05	11.3	0.25	1242	LED Light not working	Rediology	05.04.2024	11.45 am	
26	05.04.2024	10.2	14	3.8	716	Celling Fan not Working	Female Surgury Ward 02	05.04.2024	02.30 pm	
27	05.04.2024	14.3	15.5	1.2	24188	Casing patti Broken	Narsing collage	05.04.2024	04.20 pm	
28	05.04.2024	14.45	16	1.55	1140	Fridge not working	Male surgury ward 01	09.04.2024	04.00 pm	
29	05.04.2024	15	15	0	3011	All celling fan checked	Male Ortho ward	05.04.2024	05.55 pm	
30	05.04.2024	12	12.32	0.32	2393	Wall Fan not working	PSY Ward	10.04.2024	03.50 pm	
31	06.04.2024	9.3	9.5	0.2	1072	LED Tube light not working	ENT OPD	06.04.2024	10.10 am	
32	06.04.2024	13	13.5	0.5	798	LED Tube light not working	OT Complex	08.04.2024	04.00 pm	
33	06.04.2024	9.05	10	0.95	596	Lift no 01 Not working	Time office	06.04.2024	11.00 am	
34	06.04.2024	16	16.3	0.3	2301	Tharmameter not working	Immunization OPD	10.04.2024	10.30 am	

*(Handwritten Signature)*  
 24/10/24

35	06.04.2024	10	12	2	717	All fan checked	Surgary ward 02	06.04.2024	12.35 pm	
36	07.04.2024	15.25	15.25	0	290	All fan checked	OBGY WD 02	07.04.2024	06.10 pm	
37	08.04.2024	10.3	12	1.7	3013	Celling Fan not Working	Male Ortho ward	08.04.2024	12.30 pm	
38	08.04.2024	10	10.1	0.1	4573	LED Light not working	EICU	08.04.2024	10.40 am	
39	08.04.2024	14	14	0	1819	All fan & light not working	H.R Dept	08.04.2024	02.25 pm	
40	08.04.2024	14.31	15	0.69	2704	Celling Fan not Working	Medicine OPD	08.04.2024	03.45 pm	
41	08.04.2024	14.3	16.4	2.1	338	LED Tube light not working	ENT Ward	08.04.2024	05.10 pm	
42	08.04.2024	11.15	16	4.85	1397	Celling Fan not Working	OBGY WD 01	08.04.2024	04.45 pm	
43	08.04.2024	17	17	0	293	All ceiling fan checked	OBGY WD 03	08.04.2024	06.15 pm	
44	08.04.2024	12.35	12.35	0	3477	New tharmameter req.	Pead ward 01	10.04.2024	12.49 pm	
45	08.04.2024	16.45	17.1	0.65	95	LED Light not working	MCRI OPD NO 26	10.04.2024	06.00 pm	
46	08.04.2024	7.15	9.35	2.2	599	Lift no 05 not working	Time office	08.04.2024	12.00 pm	
47	09.04.2024	9	9.4	0.4	600	Celling Fan not Working	Time office	11.04.2024	04.26 pm	
48	10.04.2024	10.23	11	0.77	2001	Air cooler not working	OBGY WD 02	10.04.2024	11.28 am	
49	10.04.2024	9.35	9.45	0.1	4120	Air cooler not working	CSSD	10.04.2024	10.57 am	
50	10.04.2024	11.35	12	0.65	712	Bathroom light not working	Surgury ward 02	10.04.2024	12.35 pm	
51	10.04.2024	11.35	12	0.65	718	Celling Fan not Working	Surgury ward 02	10.04.2024	12.35 pm	
52	10.04.2024	11.35	12.15	0.8	294	Celling Fan not Working	OBGY WD 03	10.04.2024	12.48 pm	
53	10.04.2024	12.1	12.35	0.25	2759	Tube light hanging	Nepro Ward	10.04.2024	01.00 pm	
54	10.04.2024	11.3	14	2.7	1254	Celling Fan not Working	Casualty	10.04.2024	02.30 pm	
55	10.04.2024	11.4	14.3	2.9	3157	Air cooler not working	Linen Department	10.04.2024	02.40 pm	
56	10.04.2024	13.05	13.35	0.3	857	Celling Fan not Working	Endoscopy	10.04.2024	02.13 pm	
57	10.04.2024	13.05	13.35	0.3	856	Bathroom light not working	Endoscopy	10.04.2024	02.13 pm	
58	10.04.2024	10.3	11	0.7	2807	Air cooler not working	Anatomy	10.04.2024	11.25 am	
59	11.04.2024	12.28	13.35	1.07	3158	Air cooler not working	Linen Department	15.04.2024	10.15 am	
60	11.04.2024	11	11.05	0.05	2754	All fan & light not working	Nepro Ward	11.04.2024	11.10 am	
61	11.04.2024	11.35	11.35	0	2509	LED Light brightness low	CCU	02.05.2024	18.00 pm	
62	12.04.2024	10	10	0	2042	All ceiling fan checked	Ophthal ward	12.04.2024	11.45 am	
63	12.04.2024	14.3	15	0.7	480	Celling Fan not Working	Ortho OPD	12.04.2024	03.40 pm	
64	12.04.2024	10.3	10.45	0.15	2706	Lift no 07 not working	Time office	13.04.2024	10.25 am	
65	12.04.2024	15.4	16	0.6	293	Switch Board not working	Dailysis	12.04.2024	04.32 pm	
66	13.04.2024	12	12.3	0.3	1230	Air cooler not working	OBGY OPD	13.04.2024	01.00 pm	
67	13.04.2024	10.05	15.2	5.15	2998	LED Light not working	OBGY ICU	13.04.2024	03.56 pm	
68	13.04.2024	13.15	14	0.85	1683	Switch Board not working	Excative Deluxe	13.04.2024	02.30 pm	
69	13.04.2024	15.5	16.5	1	4975	LED Tube light hanging	Female medicine ward 02	13.04.2024	05.05 pm	
70	13.04.2024	16.4	16.5	0.1	719	All fan & light not working	Surgury ward 02	13.04.2024	04.58 pm	
71	13.04.2024	15.35	15.41	0.06	2396	Wall Fan not working	PSY Ward	23.04.2024	03.41 pm	
72	14.04.2024	17.45	17.45	0	865	Switch Board not working	MICU	14.04.2024	05.45 pm	
73	15.04.2024	10.24	10.24	0	2710	Lift no 01 Not working	Time office	15.04.2024	10.00 am	

74	15.04.2024	12.1	12.4	0.3	2003	Celling Fan not Working	OBGY WD 02	15.04.2024	01.30 pm	
75	19.04.2024	16.15	16.31	0.16	2397	Wall Fan not working	PSY WD	19.04.2024	12.00 PM	
76	16.04.2024	14.53	15.05	0.52	1978	Pedstral fan not working	Library	16.04.2024	02.53 pm	
77	16.04.2024	11	11.45	0.45	1143	Celling Fan not Working	MSW 01	18.04.2024	04.50 pm	
78	16.04.2024	15.45	16.2	0.75	720	Switch Board not working	Surgury wd 02	16.04.2024	04.50 pm	
79	17.04.2024	10	10	0	3113	All Fan & switch checked	FSW 03	17.04.2024	11.55 am	
80	17.04.2024	10.45	10.55	0.1	869	Switch Board not working	MICU	17.04.2024	11.05 am	
81	17.04.2024	11.15	11.35	0.2	Latter	Air cooler & AC not working	Nursing Collage	17.04.2024	03.00 pm	
82	17.04.2024	14.3	15	0.7	724	Exhust fan not working	Surgury wd 02	17.04.2024	03.40 pm	
83	18.04.2024	12.27	12.27	0	3693	Humidity meter not working	Cardiac OT	18.04.2024	12.30 pm	
84	18.04.2024	12.2	12.37	0.17	1396	Switch Board not working	EMS -P	18.04.2024	01.24 pm	
85	18.04.2024	12.2	14.4	2.2	2722	Parking bathroom light not wo	Time office	18.04.2024	03.00 pm	
86	18.04.2024	15.3	15.3	0	1145	Tharmameter not working	Male surgury wd 01	18.04.2024	03.35 pm	
87	18.04.2024	11	17	6	1592	Switch Board not working	Nursing office	18.04.2024	05.30 pm	
88	18.04.2024	14.3	15.1	0.8	1926	Celling Fan not Working	Ophthal OT	19.04.2024	10.42 pm	
89	18.04.2024	15	15.1	0.1	1440	Exhust fan not working	Central lab	19.04.2024	02.30 pm	
90	18.04.2024	10.3	16	5.7	1144	LED Tube light not working	Male surgery ward 01	18.04.2024	04.40 pm	
91	18.04.2024	16.2	16.35	0.15	3642	100 HP pump spider not worki	fire safety	19.04.2023	02.30 pm	
92	18.04.2024	14.35	14.41	0.06	3101	Wall Fan not working	PSY Ward	23.04.2024	03.30 pm	
93	19.04.2024	12	12	0	1684	All Fan & light checked	Excative Deluxe	19.04.2024	12.35 pm	
94	19.04.2024	13	14.3	1.3	1268	Exhust fan not working	Casualty	19.04.2024	03.10 pm	
95	19.04.2024	13	14.3	1.3	1269	LED Tube light not working	Casualty	19.04.2024	03.10 pm	
96	19.04.2024	12.15	16.25	4.1	647	LED Light not working	Old Deluxe	19.04.2024	04.45 pm	
97	19.04.2024	12.15	16.25	4.1	646	Fan Regulator not working	Old Deluxe	19.04.2024	05.00 pm	
98	19.04.2024	11	15.5	4.5	296	Celling Fan not Working	OBGY WD 03	19.04.2024	04.10 pm	
99	20.04.2024	15.15	15.15	0	1937	celling fan oll chekeng	male surgury wd 03	20.04.2024	05.00 pm	
100	20.04.2024	16.55	17.05	0.5	652	wall fan old fix	Old Deluxe	20.04.2024	05.30 pm	
101	20.04.2024	10	10.3	0.3	843	Celling Fan not Working	Pul.medi.ward	22.0.4.2024	03.30 pm	
102	20.04.2024	10	10.31	0.31	639	celling fan not working	New Deluxe	20.04.2024	05.48 pm	
103	20.04.2024	11.55	11.55	0	2707	Wall Fan not working	Medicine OPD	23.04.2024	04.00 pm	
104	20.04.2024	15.05	15.2	0.15	3106	Wall Fan not working	PSY Ward	22.04.2024	03.35 pm	
105	20.04.2024	12.2	12.2	0	7215	Switch Board not working	Peadiatric ward	20.04.2024	03.15 pm	
106	22.04.2024	12.3	15.2	2.9	571	LED Tube light not working	MGM opd complex	22.04.2024	03.50 pm	
107	22.04.2024	15.25	15.25	0	2044	celling fan all checked	ophthal ward	22.04.2024	05.35 pm	
108	22.04.2024	11.3	12	0.7	845	celling fan not working	Pul.medi.ward	23.04.2024	11.20 am	
109	22.04.2024	11.3	12.15	0.85	1685	LED Light not working	Excative Deluxe	24.04.2024	05.20 pm	
110	22.04.2024	11.3	12.15	0.85	1686	LED Tube light not working	Excative Deluxe	24.04.2024	05.20 pm	
111	22.04.2024	12.1	14.45	2.35	1426	Fan Regulator not working	Biochemistry Dept.	24.04.2024	03.30 pm	
112	22.04.2024	12.2	12.35	0.15	3107	Wall Fan not working	PSY Ward	23.04.2024	03.40 pm	

113	23.04.2024	12.25	12.5	0.25	3483	Switch Board not working	Pead ward 01	24.04.2024	03.14 pm	
114	23.04.2024	10.45	11.2	0.75	3116	Celling fan shifting	FSW 03	25.04.2024	01.00 pm	
115	23.04.2024	14.1	15.2	1.1	2912	Switch Board not working	OT Complex	25.04.2024	04.30 pm	
116	23.04.2024	11.1	11.3	0.2	133	Air cooler not working	Ophthal OPD	23.04.2024	11.45 am	
117	24.04.2024	15	15	0	728	Tharmameter not working	Surgury Ward 02	24.04.2024	03.05 pm	
118	24.04.2024	11.35	12.45	1.1	727	Switch Board not working	Surgury ward 02	24.04.2024	04.30 pm	
119	24.04.2024	10.45	11.2	0.75	3108	Tharmameter not working	PSY Ward	25.04.2024	11.30 am	
120	24.04.2024	8	9.3	1.3	2734	Lift no 05 not working	Time office	24.04.2024	10.15 am	
121	24.04.2024	17.1	17.45	0.35	1689	Celling Fan not Working	Excavite Deluxe	24.04.2024	06.23 pm	
122	25.04.2024	9.5	9.5	0	1803	Extension Board not working	Labour Room	25.04.2024	10.00 am	
123	25.04.2024	10.1	10.45	0.35	833	LED Light not working	Quality Department	25.04.2024	11.00 am	
124	25.04.2024	10.55	10.55	0	266	LED Light not working	Blood Bank	25.04.2024	10.55 am	
125	25.04.2024	10.1	11	0.9	2011	LED Light not working	MS Office	25.04.2024	11.30 am	
126	25.04.2024	15.1	15.1	0	573	Water cooler not working	OPD Complex	25.04.2024	03.10 pm	
127	25.04.2024	14.35	15.25	0.9	1826	Water cooler not working	HR Dept	25.04.2024	03.10 pm	
128	25.04.2024	12	12.48	0.48	2556	LED Tube light not working	Record Section	25.04.2024	03.20 pm	
129	25.04.2024	2.3	3	0.7	2516	Switch Board not working	CVTS	25.04.2024	03.40 pm	
130	25.04.2024	11	11.45	0.45	24190	Water Fillter not working	Mother Teresa Col.	26.04.2024	11.00 am	
131	25.04.2024	4.4	4.55	0.15	24191	Switch Board not working	Mother Teresa Col.	26.04.2024	10.00 am	
132	25.04.2024	14.19	15.35	1.16	2950	LED Light not working	MCRI ICU	26.04.2024	04.14 pm	
133	25.04.2024	14.19	15.35	1.16	2951	LED Light not working	MCRI ICU	26.04.2024	04.15 pm	
134	25.04.2024	14.19	15.35	1.16	2952	Night light not working	MCRI ICU	26.04.2024	04.17 pm	
135	26.04.2024	9.5	9.5	0	3658	Switch Board not working	NICU	26.04.2024	09.55 am	
136	26.04.2024	10.35	10.35	0	131	Switch Board not working	Ophthal OPD	26.04.2024	12.57 pm	
137	26.04.2024	13.5	14.1	0.6	861	LED Light not working	Endoscopy	26.04.2024	02.25 pm	
138	26.04.2024	14.3	14.3	0	862	LED Light not working	Endoscopy	26.04.2024	03.15 pm	
139	26.04.2024	4	4	0	3660	Extension Board not working	NICU	26.04.2024	04.10 pm	
140	26.04.2024	15.4	15.5	0.1	2737	Water cooler not working	OPD Complex	26.04.2024	04.00 pm	
141	26.04.2024	15.3	15.3	0	300	Celling fan removed	Dailysis	27.04.2024	10.06 am	
142	27.04.2024	11.45	12.1	0.65	351	All Fan& Switch board checked	ENT Ward	27.04.2024	01.10 pm	
143	27.04.2024	10.1	11	0.9	300	Gizer not working	OBGY WD 03	27.04.2024	11.45 am	
144	27.04.2024	10.1	11	0.9	296	Celling Fan not Working	OBGY WD 03	27.04.2024	11.30 am	
145	27.04.2024	10.3	12	1.7	4981	Switch Board not working	FMW 02	27.04.2024	12.42 pm	
146	27.04.2024	10.3	12	1.7	4980	LED Tube light not working	FMW 02	27.04.2024	12.42 pm	
147	27.04.2024	16.1	16.1	0	1671	LED Tube light not working	FMW 01	29.01.2024	03.00 pm	
148	27.04.2024	16.3	16.3	0	2116	Wall Fan not working	Pead ward 03	29.01.2024	02.10 pm	
149	27.04.2024	11.1	12	0.9	1672	Switch Board not working	FMW 01	27.04.2024	03.30 pm	
150	27.04.2024	12.1	15.35	3.25	2918	LED Tube light not working	OT Complex	27.04.2024	04.10 pm	
151	27.04.2024	12.4	13.1	0.7	1232	Wall Fan not working	PSY ward	06.05.2024	03.50 pm	

152	29.04.2024	10.3	11.15	0.85	3111	Wall Fan not working	PSY Ward	29.04.2024	04.15 pm	
153	30.04.2024	11.54	12.35	0.81	3164	Iron Wire cut from 3pin top	Linen Department	30.04.2024	12.38 pm	
154	30.04.2024	15	15	0	2741	USG Passage Light not working	Time office	30.04.2024	03.00 pm	
155	30.04.2024	12.16	14	1.84	1109	Air cooler not working	MJPJAY Ward	30.04.2024	03.25 pm	
156	30.04.2024	12.16	13.45	1.29	4126	LED Tube light not working	CSSD	30.04.2024	04.00 pm	
157	30.04.2024	15	15	0	2740	Wall Fan not working	Time office	30.04.2024	04.20 pm	
158	30.04.2024	14	14	0	7218	Tharmameter not working	Pead.ward 02	07.05.2024	02.00 pm	

**Electrical Supervisor**  
MGM-EED Aurangabad

**Electrical Engineer**  
MGM-EED Aurangabad

**Technical Executive(Elect.)**  
MGM-EED Aurangabad

**HOD**  
MGM-EED Aurangabad

**MGM MEDICAL COLLEGE & HOSPITAL**  
**ELECTRICAL MAINTANCE REPORT 01 May 2024 to 31 May 2024**

Sr.No.	Received Date	Time	Attende Time	Response Time	Cpmlaint No.	Nature Of Complent	Name Of Department	Date Of Complation	Close Time	Remark
1	01.05.2024	22	22.15	0.15	2742	Lift no 04 not working	Time office	02.05.2024	11.45 am	
2	02.05.2024	9.15	10	0.85	1806	Switch Board not working	Labour Room	02.05.2024	10.55 am	
3	02.05.2024	11.12	11.35	0.23	24192	Celling Fan not Working	Mother Teresa Col.	02.05.2024	12.03 pm	
4	02.05.2024	14.2	14.2	0	3165	Iron not working	Linen Department	02.05.2024	02.30 pm	
5	02.05.2024	10	10.35	0.35	106	Switch Board not working	OBY ICU	02.05.2024	02.45 pm	
6	02.05.2024	11.55	12.5	0.95	2555	Air cooler not working	Record Section	22.05.2024	01.25 pm	
7	02.05.2024	12.25	12.5	0.25	2810	Req.new elect. Point	Anatomy	02.05.2024	04.15 pm	
8	03.05.2024	10.45	11.05	0.6	1251	LED Light not working	Radiology	03.05.2024	11.30 am	
9	03.05.2024	14	14	0	847	All light & fan not working	Pul. Medicine opd	03.05.2024	02.20 pm	
10	03.05.2024	14.3	15.25	0.95	2124	Air cooler not working	Pead. Ward 03	03.05.2024	05.00 pm	
11	03.05.2024	11.4	12.15	0.75	3115	Wall Fan not working	PSY Ward	04.05.2024	09.50 am	
12	03.05.2024	15.05	17.1	2.05	886	LED Light not working	MICU	06.05.2024	10.20 am	
13	04.05.2024	11.25	11.4	0.15	2125	Air cooler not working	Pead.ward 03	04.05.2024	11.55 am	
14	04.05.2024	10	10.45	0.45	702	All fan & Board checked	Male Ortho Ward 02	04.05.2024	11.45 am	
15	04.05.2024	12.05	13	0.95	4127	LED Lube light not working	CSSD	04.05.2024	02.10 pm	
16	04.05.2024	12.05	12.2	0.15	1288	LED Tube light not working	Casualty	04.05.2024	12.50 pm	
17	04.05.2024	12.2	15	2.8	269	Switch Board not working	Blood Bank	04.05.2024	03.45 pm	
18	04.05.2024	15	15.35	0.35	1113	Air cooler not working	MJPJAY ward	06.05.2024	10.50 am	
19	04.05.2024	10.5	11.2	0.7	3304	Gizer not working	OBY WD 03	06.05.2024	11.30 am	
20	06.05.2024	9.3	9.45	0.15	2929	Fridge temp not show	OT Complex	06.05.2024	10.10 am	
21	06.05.2024	11	11	0	3026	Tharmameter not working	Male Ortho ward 02	06.05.2024	11.10 am	
22	06.05.2024	11.2	11.2	0	3166	Iron not working	Linen Department	06.05.2024	11.20 am	
23	06.05.2024	11.05	12.25	1.2	7219	LED Tube light not working	Pead. Ward 02	06.05.2024	02.15 pm	
24	06.05.2024	11.2	13.35	2.15	1114	Air cooler not working	MJPJAY Ward	06.05.2024	02.05 pm	
25	06.05.2024	16.1	16.1	0	4129	Burn smell plz check all eqp.	CSSD	06.05.2024	04.25 pm	
26	06.05.2024	14.3	14.55	0.25	2764	Switch Board not working	Nepro Ward	06.05.2024	05.12 pm	
27	07.05.2024	11.3	13	1.7	1165	LED Tube light not working	MSW 01	08.05.2024	01.55 pm	
28	07.05.2024	12.3	13.2	0.9	396	Celling Fan not Working	MMW 01	08.05.2024	01.37 pm	
29	07.05.2024	14.45	15.55	1.1	2755	Air cooler not working	Pead.OPD	22.05.2024	03.30 pm	
30	07.05.2024	12.05	12.35	0.3	738	Switch Board not working	Surgury Ward 02	08.05.2024	02.55 pm	
31	07.05.2024	15.53	16.25	0.72	2812	Celling Fan not Working	Anatomy	08.05.2024	04.30 pm	
32	08.05.2024	11.3	12.1	0.8	861	LED Tube light not working	2D Eco	08.05.2024	01.57 pm	
33	08.05.2024	11.35	12	0.25	3220	LED Tube light not working	Skin OPD	08.05.2024	03.12 pm	
34	09.05.2024	11.3	12	0.7	3489	LED Tube light not working	Pead.Wd 01	09.05.2024	02.12 pm	

*(Signature)*  
 (V. A. Ambekar)  
 24/10/24

35	09.05.2024	13.05	14.35	1.3	4579	LED Light not working	EICU	10.05.2024	03.53 pm	
36	09.05.2024	11.45	12.15	0.7	2813	Celling Fan not Working	Anatomy	21.05.2024	11.26 am	
37	09.05.2024	13.39	13.39	0	663	Tharmameter not working	Old Deluxe	09.05.2024	01.44 pm	
38	10.05.2024	9.05	10	0.95	979	Tharmameter not working	Super Deluxe	10.05.2024	10.15 am	
39	10.05.2024	11.15	12	0.85	1729	LED Light not working	Microbiology	10.05.2024	12.55 pm	
40	10.05.2024	14	14.15	0.15	1313	Tube light not working	Central Store	10.05.2024	02.30 pm	
41	10.05.2024	13.1	14	0.9	646	Celling Fan not Working	New Deluxe	10.05.2024	02.23 pm	
42	10.05.2024	17	17	0	4992	Light & fan not working	FMW 02	10.05.2024	05.05 pm	
43	11.05.2024	12.35	13.3	0.95	814	Passage Light not working	Pharmacology	11.05.2024	02.00 pm	
44	11.05.2024	14.4	15.35	0.95	812	Air cooler not working	OBGY WD 01	11.05.2024	04.05pm	
45	12.05.2024	11.54	12.25	0.71	740	Bathroom light not working	Surgury wd 02	12.05.2024	01.00 pm	
46	12.05.2024	12.06	12.15	0.09	647	Celling Fan not Working	New Deluxe	12.05.2024	12.35 pm	
47	14.05.2024	11	12.1	1.1	1811	Celling Fan not Working	Labour Room	14.05.2024	05.10 pm	
48	14.05.2024	11.45	12.25	0.8	3113	Wall Fan not working	PSY WD	14.05.2024	04.00 pm	
49	14.05.2024	10.21	11	0.79	1169	Switch Board not working	MSW 01	14.05.2024	03.30 pm	
50	14.05.2024	7.2	10	2.8	2761	Lift no 06 not working	Time office	14.05.2024	01.30 pm	
51	14.05.2024	16	16.2	0.2	298	Celling Fan not Working	Medical Store	14.05.2024	04.40 pm	
52	15.05.2024	10.4	10.5	0.1	2014	Air cooler not working	OBGY WD 02	15.05.2024	11.00 am	
53	15.05.2024	9.3	11	1.7	2762	Water cooler not working	Time office	15.05.2024	11.45 am	
54	15.05.2024	14.5	17.45	2.95	1117	Air cooler not working	MJPJAY WD	22.05.2024	01.15 pm	
55	15.05.2024	10.35	11.28	0.93	648	Celling Fan not Working	New Deluxe	15.05.2024	04.00 pm	
56	16.05.2024	10.56	11.1	0.54	1429	LED Light not working	Biochemistry Dept.	16.05.2024	11.40 am	
57	16.05.2024	15.1	15.45	0.35	2756	Air cooler not working	Pead.wd 03	22.05.2024	02.35 pm	
58	16.05.2024	5.05	5.05	0	2012	LED Light not working	M.S Office	16.05.2024	05.05 pm	
59	17.05.2024	11.45	11.45	0	1119	LED Tube light not working	MJPJAY WD	17.05.2024	11.50 am	
60	17.05.2024	9.15	9.35	0.2	2766	Lift no 03 not working	Time office	17.05.2024	10.00 am	
61	17.05.2024	14.25	15	0.75	2323	Pedstral fan not working	MCRI OPD	17.05.2024	03.50 pm	
62	17.05.2024	15	15	0	2770	Exhust fan not working	Nepro Ward	17.05.2024	03.15 pm	
63	17.05.2024	12.11	12.11	0	886	Wall Fan not working	MJPJAY OPD	18.05.2024	10.21 am	
64	17.05.2024	15	15	0	2769	Celling Fan not Working	Nepro Ward	17.05.2024	05.15 pm	
65	18.05.2024	11.2	11.45	0.25	650	Celling Fan not Working	New Deluxe	18.05.2024	12.35 pm	
66	18.05.2024	10.15	11.15	1	984	Switch Board not working	Super Deluxe	18.05.2024	11.30 am	
67	18.05.2024	11.15	12	0.85	633	Celling Fan not Working	Pathology Dept.	18.05.2024	03.45 pm	
68	18.05.2024	6.3	9.1	2.8	2767	Lift no 05 not working	Time office	18.05.2024	01.00 pm	
69	18.05.2024	16.35	16.4	0.05	2469	Switch Board not working	Central lab	18.05.2024	04.50 pm	
70	20.05.2024	11	14.15	3.15	2771	Lift no 05 not working	Time office	20.05.2024	02.27 pm	
71	20.05.2024	10.08	11	0.92	1172	Celling Fan not Working	MSW 01	20.05.2024	04.00 pm	
72	21.05.2024	12.3	13.3	1	1946	Celling Fan not Working	MSW 03	21.05.2024	02.14 pm	
73	21.05.2024	12.45	13	0.55	1739	Exhust fan not working	Microbiology	21.05.2024	02.01 pm	



74	21.05.2024	15.1	15.25	0.15	1736	Tube light not working	Surgury OPD	21.05.2024	03.25 pm	
75	21.05.2024	17.1	17.35	0.25	161	Switch Board not working	Community Dept.	22.05.2024	10.00 am	
76	21.05.2024	13.55	14.35	0.8	2769	Lift no 01 Not working	Time office	22.05.2024	11.00 am	
77	21.05.2024	13.05	14.35	1.3	887	Air cooler installtion	MJPJAY OPD	21.05.2024	04.02 pm	
78	22.05.2024	11.15	11.15	0	1947	Tharmameter not working	MSW 03	22.05.2024	11.15 am	
79	22.05.2024	11.3	11.3	0	3122	Switch Board not working	PSY WD	22.05.2024	11.45 am	
80	22.05.2024	10.3	11.1	0.8	910	Switch Board not working	Casualty	22.05.2024	12.00 pm	
81	22.05.2024	10.3	11.1	0.8	909	Blank plate Open	Casualty	22.05.2024	12.00 pm	
82	22.05.2024	10.3	11.1	0.8	905	Tube light not working	Casualty	22.05.2024	11.36 am	
83	22.05.2024	12.49	13.35	0.86	12	Light & fan not working	Male Medicine ward	23.05.2024	12.15 pm	
84	22.05.2024	11.45	12.2	0.75	874	LED Light not working	Endoscopy	28.05.2024	10.00 am	
85	22.05.2024	10.3	11.1	0.8	908	Switch Board not working	Casualty	22.05.2024	11.42 am	
86	23.05.2024	9.15	9.15	0	5556	Switch Board not working	MCRI Opthal OPD	23.05.2024	09.27 am	
87	23.05.2024	14.05	14.2	0.15	275	Switch Board not working	Blood Bank	23.05.2024	02.20 pm	
88	23.05.2024	11.55	12.35	0.8	2711	Air cooler not working	Medicine OPD	23.05.2024	02.45 pm	
89	23.05.2024	14.4	15.15	0.75	2774	Air cooler not working	Nepro Ward	26.05.2024	02.30 pm	
90	23.05.2024	10.3	10.45	0.15	202	LED Light not working	MICU	23.05.2024	11.00 am	
91	24.05.2024	13.11	13.45	0.34	3851	Celling Fan not Working	FSW 01	24.05.2024	04.10 pm	
92	24.05.2024	9.15	10.15	1	1123	Tube light not working	MJPJAY Ward	24.05.2024	04.00 pm	
93	24.05.2024	12.27	14.25	1.98	2775	Exhust fan not working	Time office	24.05.2024	05.00 pm	
94	25.05.2024	10.15	10.5	0.35	1949	Tube light not working	MSW 03	25.05.2024	11.45 pm	
95	25.05.2024	10	10.45	0.45	3167	Tube light not working	Linen Department	25.05.2024	11.30 am	
96	25.05.2024	12.05	13.15	1.1	3125	Wall Fan not working	PSY WD	25.05.2024	03.10 pm	
97	25.05.2024	16.52	16.52	0	2052	Air cooler installtion	opthal ward	25.05.2024	04.55 pm	
98	26.05.2024	8.15	10.1	1.95	2780	Lift no 06 not working	Time office	26.05.2024	11.30 am	
99	27.05.2024	9.15	9.3	0.15	279	LED Light not working	Blood Bank	27.05.2024	10.00 am	
100	27.05.2024	10	10	0	888	Cooler not working	MJPJAY OPD	27.05.2024	10.10 pm	
101	27.05.2024	10	10.35	0.35	482	Celling Fan not Working	Orhto OPD	27.05.2024	11.05 am	
102	27.05.2024	10.45	11.25	0.8	1586	LED Light not working	PICU	27.05.2024	12.30 pm	
103	27.05.2024	15.51	16.22	0.71	1984	LED Light not working	HR Dept	28.05.2024	11.20 am	
104	27.05.2024	13.25	14.1	0.85	3494	Celling Fan not Working	Pead. Wd 01	28.05.2024	12.30 pm	
105	28.05.2024	11	11.35	0.35	1314	Tube light not working	Central Store	28.04.2024	12.00 pm	
106	28.05.2024	15.25	15.25	0	2775	All light & fan not working	Nepro Ward	28.05.2024	03.42 pm	
107	29.05.2024	10.2	10.25	0.05	3685	Switch Board not working	NICU	29.05.2024	10.50 am	
108	29.05.2024	10.05	10.05	0	2981	Switch Board not working	MCRI ICU	29.05.2024	10.15 am	
109	29.05.2024	10.58	11.25	0.67	994	Switch Board not working	Super Deluxe	29.05.2024	12.10 pm	
110	29.05.2024	12.2	13.4	1.2	24198	Switch Board not working	Nursing Collage	29.05.2024	02.10 pm	
111	29.05.2024	13.26	14	0.74	1717	Celling Fan not Working	Anaesthesia Dept	29.05.2024	04.00 pm	
112	29.05.2024	15	15.3	0.3	755	Switch Board not working	Surgury wd 02	29.05.2024	04.20 pm	

113	30.05.2024	10.3	11	0.7	365	Fan Regulator not working	ENT WD	30.05.2024	11.35 am	
114	30.05.2024	14.5	15.15	0.65	2053	Tharmameter not working	Ophthal WD	30.05.2024	03.45 pm	
115	31.05.2024	10.45	11.3	0.85	1748	Light & fan not working	Microbiology	31.05.2024	12.00 pm	
116	31.05.2024	10.3	10.3	0	2020	Switch Board not working	OBY WD 02	31.05.2024	10.40 am	
117	31.05.2024	12.5	12.5	0	7226	Tharmameter not working	Pead WD 01	31.05.2024	01.00 pm	
118	31.05.2024	13	13.35	0.35	1934	Celling Fan not Working	Get No 01	31.05.2024	02.15 pm	

**Electrical Supervisor**  
MGM-EED Aurangabad

**Electrical Engineer**  
MGM-EED Aurangabad

**Technical Executive(Elect.)**  
MGM-EED Aurangabad

**HOD**  
MGM-EED Aurangabad

**MGM MEDICAL COLLEGE & HOSPITAL**  
**ELECTRICAL MAINTANCE REPORT 01 Jun 2024 to 30 Jun 2024**

Sr.No.	Received Date	Time	Attende Time	Response Time	Cpmlaint No.	Nature Of Complent	Name Of Department	Date Of Complation	Close Time	Remark
1	01.06.2024	9.2	9.3	0.1	2786	Celling Fan not Working	MICU	01.06.2024	10.10 am	
2	01.06.2024	10.4	10.5	0.1	2560	Air cooler not working	Record Section	01.06.2024	11.00 am	
3	01.06.2024	12.16	12.35	0.19	2333	Peadstral fan not working	MCRI OPD	01.06.2024	12.45 pm	
4	01.06.2024	12.45	13.1	0.65	280	AC Not working	Blood Bank	01.06.2024	03.25 pm	
5	01.06.2024	11.39	12	0.61	675	LED Light not working	Old Deluxe	01.06.2024	12.30 pm	
6	01.06.2024	12.35	13	0.65	1185	LED Tube light not working	MSW 01	01.06.2024	01.30 pm	
7	01.06.2024	12.45	12.45	0	3694	Switch Board not working	NICU	01.06.2024	01.00 pm	
8	01.06.2024	14.15	14.3	0.15	2023	Switch Board connection	OBYG WD 02	01.06.2024	02.50 pm	
9	01.06.2024	10.15	11	0.85	655	All Light & fan chrcking	New Deluxe	01.06.2024		
10	01.06.2024	15.3	17	1.7	2024	Celling Fan not Working	OBYG WD 02	01.06.2024	05.30 pm	
11	03.06.2024	11.5	12.5	1	2776	Air cooler not working	Nepro Ward	03.06.2024	01.00 pm	
12	03.06.2024	12.35	12.35	0	2788	Lift no 01 Not working	Time office	03.06.2024	12.50 pm	
13	03.06.2024	16.35	16.4	0.05	3404	Air cooler not working	Urology ward	03.06.2024	05.00 pm	
14	03.06.2024	23	23.3	0.3	823	Celling Fan not Working	OBYG WD 01	04.06.2024	12.00 am	
15	03.06.2024	15.19	17	1.81	822	Air cooler not working	OBYG WD 01	04.06.2024	11.15 am	
16	04.06.2024	11.46	12	0.54	224	Switch Board not working	PSY OPD	04.06.2024	12.30 pm	
17	04.06.2024	14.15	14.15	0	2985	Tharmameter not working	OT Complex	04.06.2024	02.25 pm	
18	04.06.2024	15.17	16	0.83	215	LED Light not working	MICU	04.06.2024	04.50 pm	
19	04.06.2024	11.35	11.35	0	677	Celling Fan not Working	Old Deluxe	04.06.2024	04.05 pm	
20	04.06.2024	10.3	11.3	1	758	Switch Board not working	Surgery Wd 02	05.06.2024	04.50 pm	
21	04.06.2024	16.05	16.05	0	679	Celling Fan not Working	Old Deluxe	04.06.2024	06.39 pm	
22	05.06.2024	15.28	15.55	0.27	2757	Install new wall fan work	Pead opd	05.06.2024	04.05 pm	
23	05.06.2024	14.55	16.5	1.95	3355	Gizer not working	SICU	05.06.2024	05.15 pm	
24	05.06.2024	10.02	11	0.98	714	Air cooler not working	Male Ortho wd 02	05.06.2024	11.25 am	
25	05.06.2024	15.2	15.2	0	2028	Air cooler not working	OBYG WD 02	05.06.2024	03.51 pm	
26	05.06.2024	10.05	12	1.95	3322	LED Tube light not working	OBYG WD 03	05.06.2024	03.35 pm	
27	05.06.2024	11	11.5	0.5	3323	Regulator cap not avaiable	OBYG WD 03	07.06.2024	12.50 pm	
28	05.06.2024	18.05	18.25	0.2	2792	Medical collage lift nit working	Time office	05.06.2024	07.00 pm	
29	06.06.2024	9.4	11.3	1.9	2337	LED Light not working	MCRI OPD	06.06.2024	12.00 pm	
30	06.06.2024	12.15	12.45	0.3	1188	Switch Board not working	MSW 01	06.06.2024	01.00 pm	
31	06.06.2024	15.3	15.3	0	3699	Insect killer machine not work	NICU	06.06.2024	03.30 pm	
32	06.06.2024	14.3	16	1.7	2759	Fan Regulator not working	Pead. OPD	06.06.2024	04.40 pm	
33	06.06.2024	10.15	11.4	1.25	2758	Wall Fan not working	Pead. OPD	06.06.2024	05.00 pm	
34	06.06.2024	15	15.3	0.3	767	Exhust fan not working	MSW 02	06.06.2024	04.10 pm	

*W. R. Ambrose*  
24/10/24

35	06.06.2024	16.3	16.3	0	2794	Fish pot motor not working	Time office	06.06.2024	04.50 pm	
36	06.06.2024	16	16.45	0.45	2700	LED Light not working	Exam Cell	07.06.2024	11.30 am	
37	07.06.2024	10.2	10.2	0	1431	Celling Fan not Working	Biochemistry Dept.	07.06.2024	11.20 am	
38	07.06.2024	12.32	16	3.68	2779	Switch Board not working	Nepro Ward	07.06.2024	04.45 pm	
39	07.06.2024	11.3	15.3	4	3404	Air cooler not working	Urology ward	07.06.2024	04.00 pm	
40	07.06.2024	16.1	16.35	0.25	2816	Celling fan & Tube light not working	Anatomy	12.06.2024	04.35 pm	
41	07.06.2024	12.15	13	0.85	136	Air cooler not working	Ophthal OPD	07.06.2024	03.43 pm	
42	08.06.2024	11.45	11.45	0	221	Switch Board not working	MICU	08.06.2024	12.10 pm	
43	08.06.2024	11.15	11.5	0.35	2996	Passage Light not working	OT Complex	08.06.2024	12.22 pm	
44	08.06.2024	11.15	11.5	0.35	2995	M.Changing room light not working	OT Complex	08.06.2024	12.22 pm	
45	08.06.2024	11.07	11.45	0.38	1189	Switch Board not working	MSW 01	08.06.2024	12.43 pm	
46	08.06.2024	11.45	13	1.55	222	Side room Light not working	MICU	08.06.2024	04.26 pm	
47	09.06.2024	9	9.3	0.3	3360	AC Not working	SICU	09.06.2024	11.30 am	
48	10.06.2024	14.28	16.1	1.82	3858	Celling Fan not Working	FSW 01	12.06.2024	03.42 pm	
49	10.06.2024	12.4	15.35	2.95	711	Celling Fan not Working	Female Ortho Ward	10.06.2024	04.01 pm	
50	10.06.2024	14.15	15	0.85	1465	Gizer not working	CCU	11.06.2024	12.20 pm	
51	11.06.2024	10.25	10.38	0.13	3552	Exhust fan not working	EMS-P	11.06.2024	10.38 am	
52	11.06.2024	11	11	0	3553	Extension Board not working	EMS-P	11.06.2024	11.00 am	
53	11.06.2024	10.1	12.35	2.25	3329	Gizer not working	OBGY WD 03	11.06.2024	12.50 pm	
54	11.06.2024	12.03	12.25	0.22	773	Exhust fan not working	SUR- WD 02	11.06.2024	12.35 pm	
55	11.06.2024	17	17.1	0.1	Latter	View box not working	Endoscopy	11.06.2024	05.30 pm	
56	12.06.2024	9.57	11	1.43	127	Switch Board not working	OBGY ICU	12.06.2024	04.30 pm	
57	12.06.2024	12.24	14.15	1.91	712	LED Tube light not working	Female Ortho Ward	14.06.2024	10.24 pm	
58	13.06.2024	12.45	14.2	1.75	774	Switch board not working	Surgury ward 02	14.06.2024	04.06 pm	
59	13.06.2024	15.05	15.45	0.4	3647	Switch board shifting work	fire safety	13.06.2024	05.15 pm	
60	13.06.2024	11.3	12.1	0.8	682	LED Light not working	Old Deluxe	14.06.2024	04.15 pm	
61	13.06.2024	10.16	10.35	0.19	597	Wall Fan not working	PSY Ward	13.06.2024	11.45 am	
62	14.06.2024	10.3	11	0.7	936	Switch board not working	Casualty	14.06.2024	11.15 am	
63	14.06.2024	12	13.25	1.25	24	Celling Fan not Working	MMW 01	14.06.2024	01.40 pm	
64	14.06.2024	14.5	15.3	0.8	18.05	LED Tube light not working	OT Complex	15.06.2024	04.10 pm	
65	15.06.2024	11	11.3	0.3	1470	Gizer not working	CCU	15.06.2024	11.40 am	
66	15.06.2024	16.1	16.4	0.3	3331	Fouse lamp not working	Labour Room	15.06.2024	05.00 pm	
67	15.06.2024	18	18.15	0.15	202	Passage Light not working	Super Deluxe	15.06.2024	06.30 pm	
68	15.06.2024	17	17.3	0.3	1827	Fouse lamp not working	Labour Room	15.06.2024	06.00 pm	not repairable
69	15.06.2024	11.49	12.25	0.76	18.08	View box not working	OT Complex	17.06.2024	05.15 pm	
70	16.06.2024	12.2	12.3	0.1	3862	Nursing counter light not working	FSW 01	16.06.2024	12.35 pm	
71	16.06.2024	19.3	19.4	0.1	1913	Switch Board not working	Time office	16.06.2024	07.53 pm	
72	16.06.2024	22.3	22.3	0	230	B. no 13 switch board not working	MICU	16.07.2024	10.30 pm	
73	16.06.2024	10	10	0	18.1	LED Tube light not working	OT Complex	16.06.2024	10.00 am	

74	17.06.2024	10.23	10.23	0	16.07	LED Tube light not working	FMW 02	17.07.2024	10.23 am	
75	17.06.2024	13.16	13.16	0	1907	Extension Board not working	NICU	17.06.2024	01.20 pm	
76	17.06.2024	11.49	12	0.51	1810	LED Tube light not working	OT Complex	17.06.2024	12.30 pm	
77	17.06.2024	12.58	13.25	0.67	1269	AC Not working	Radiology	17.06.2024	13.55 pm	
78	17.06.2024	11.37	12	0.63	3147	AC Not working	PSY Ward	17.06.2024	12.25 pm	
79	17.06.2024	15	17	2	3333	Celling Fan not Working	OBYG WD 03	17.06.2024	05.45 pm	
80	17.06.2024	17	17.2	0.2	2353	LED Light not working	MCRI OPD	17.06.2024	05.30 pm	
81	17.06.2024	10.38	11	0.62	3332	Bathroom light not working	OBYG WD 03	17.06.2024	06.00 pm	
82	17.06.2024	11.28	15.45	4.17	1239	Switch Board not working	OBYG OPD	17.06.2024	04.15 pm	
83	17.06.2024	14.37	16.5	2.13	2352	LED Light not working	MCRI OPD	17.05.2024	05.20 pm	
84	17.06.2024	11.29	13	1.71	1240	Celling Fan not Working	OBYG OPD	22.06.2024	04.30 pm	
85	18.06.2024	15.35	15.5	0.15	1991	Exhust fan not working	Central Liabrary	18.06.2024	04.08 pm	
86	18.06.2024	12.1	15	2.9	2713	LED Tube light not working	Medicine OPD	18.06.2024	03.45 pm	
87	18.06.2024	14.43	15.3	0.87	1813	Switch Board not working	OT Complex	18.06.2024	05.10 pm	
88	18.06.2024	10.46	10.46	0	1917	Peadstral fan not working	Dean Office	18.06.2024	05.25 pm	
89	18.06.2024	11	11.05	0.05	1913	Tharmameter not working	NICU	18.06.2024	11.10 am	
90	18.06.2024	12.42	13.45	1.03	232	Celling Fan not Working	PSY OPD	21.06.2024	10.15 am	
91	19.06.2024	14.45	14.45	0	1816	Tempreture meter not workin	OT Complex	19.06.2024	03.00 pm	
92	19.06.2024	11.51	12.25	0.74	1814	Switch Board not working	OT Complex	19.06.2024	01.45 pm	
93	19.06.2024	16	16.48	0.48	3152	LED Tube light not working	PSY Ward	20.06.2024	05.15 pm	
94	19.06.2024	14.25	15.3	1.05	3558	LED Light not working	EMS-P	26.06.2024	02.50 pm	
95	20.06.2024	9.45	10.3	0.85	18702	Switch board shifting work	Nursing Collage	20.06.2024	11.00 am	
96	20.06.2024	10	13.2	3.2	35	New Wall fan installation	Dermatology skin ward	20.06.2024	01.50 pm	
97	20.06.2024	15.15	15.46	0.31	583	Celling Fan not Working	SS OPD	20.06.2024	03.55 pm	
98	20.06.2024	15.5	15.5	0	891	Celling Fan not Working	MJPJAY OPD	20.06.2024	04.10 pm	
99	20.06.2024	14.25	15.1	0.85	2715	Celling Fan not Working	Medicine OPD	20.06.2024	03.45 pm	
100	20.06.2024	14.25	15.2	0.95	2714	LED Tube light not working	Medicine OPD	20.06.2024	03.45 pm	
101	20.06.2024	16	16.35	0.35	819	LED Light not working	Pharmacology	20.06.2024	04.50 pm	
102	20.06.2024	11.03	13.1	2.07	233	LED Bulb not working	PSY OPD	21.06.2024	10.10 am	
103	20.06.2024	11.5	14.38	2.88	1820	LED Tube light not working	OT Complex	21.06.2024	04.00 pm	
104	20.06.2024	16.2	17	0.8	1925	Lift no 04 not working	Time office	20.06.2024	05.31 pm	
105	21.06.2024	10.2	11	0.8	1587	Exhust fan not working	PICU	21.06.2024	11.45 am	
106	21.06.2024	10.45	11	0.55	1193	LED Light not working	Dental opd	21.06.2024	11.30 am	
107	21.06.2024	9.15	9.15	0	1914	Switch Board not working	NICU	21.06.2024	09.30 am	
108	21.06.2024	12	14	2	829	Celling Fan not Working	OBYG WD 01	21.06.2024	02.45 pm	
109	21.06.2024	14.44	16.5	2.06	1080	Endosopy room light not work	ENT OPD	22.06.2024	05.00 pm	
110	21.06.2024	12.38	14	1.62	2782	Bathroom light not working	Nepro Ward	22.06.2024	05.15 pm	
111	21.06.2024	17.4	18	0.6	1926	Lift no 06 not working	Time office	21.06.2024	06.31 pm	
112	21.06.2024	11	12.1	1.1	944	New switch board installation	Casualty	24.06.2024	04.50 pm	

113	22.06.2024	12.3	13	0.7	1928	Collage lift not working	Time office	22.06.2024	02.00 pm	
114	22.06.2024	14.32	18	3.68	3648	Booster pump not working	fire safety	22.06.2024	06.25 pm	
115	24.06.2024	11.3	12.5	1.2	821	LED Light not working	Pharmacology	24.06.2024	01.00 pm	
116	24.06.2024	11.3	11.4	0.1	1920	Switch Board not working	NICU	24.06.2024	11.50 am	
117	24.06.2024	15.05	15.15	0.1	3564	Switch Board not working	EMS-P	24.06.2024	15.20 pm	
118	24.06.2024	10.41	12	1.59	1197	LED Tube light not working	MSW 01	24.06.2024	03.25 pm	
119	24.06.2024	11.08	12.15	1.07	372	Fan Regulator broken	ENT Ward	24.06.2024	03.10 pm	
120	24.06.2024	16.55	17	0.45	2273	50 watt focus not working	STP / ETP	24.06.2024	05.30 pm	
121	25.06.2024	10	10	0	1825	Water cooler not working	OT Complex	25.06.2024	10.20 am	
122	25.06.2024	10	11.45	1.45	1590	Exhust fan not working	PICU	25.06.2024	12.10 pm	
123	25.06.2024	12.3	12.4	0.1	3159	Cooler not working	Linen Department	25.06.2024	12.50 pm	
124	25.06.2024	22.1	22.1	0	788	All fan & light not working	Surgury 02	25.06.2024	10.26 pm	
125	25.06.2024	10.11	12	1.89	1473	LED Light not working	CVTS	26.06.2024	12.30 pm	
126	25.06.2024	11.3	12.5	1.2	203	LED Light not working	Super Deluxe	26.06.2024	01.00 pm	
127	26.06.2024	12.05	12.3	0.25	955	Exhust fan not working	Casualty	26.06.2024	01.00 pm	
128	26.06.2024	14.16	14.35	0.19	1271	LED Light not working	Radiology	26.06.2024	03.05 pm	
129	26.06.2024	15.3	15.5	0.2	3038	Switch Board not working	Male Ortho ward	26.06.2024	04.10 pm	
130	26.06.2024	17.5	18	0.5	2361	LED Light not working	MCRI Casualty	26.06.2024	06.00 pm	
131	27.06.2024	11.53	12	0.47	180	All fan & light not working	Nursing Collage	27.06.2024	12.00 pm	
132	27.06.2024	10.15	11.4	1.25	3223	Fan & Tube not working	Dermatology skin ward	27.06.2024	12.05 pm	
133	27.06.2024	13.2	13.25	0.05	3335	Fan & Tube not working	OBGY WD 03	27.06.2024	01.25 pm	
134	27.06.2024	14.25	15.05	0.8	833	Celling Fan not Working	OBGY WD 01	27.06.2024	03.26 pm	
135	27.06.2024	14.5	14.5	0	3170	Air cooler not working	Linen Department	27.06.2024	15.00 pm	
136	27.06.2024	14.3	14.4	0.1	2783	LED Tube light not working	Nepro Ward	27.06.2024	02.45 pm	
137	27.06.2024	16	16	0	1474	Extension Board not working	CVTS	27.06.2024	04.20 pm	
138	27.06.2024	12.18	15.4	3.22	3568	LED Light not working	Step Down ICU	27.06.2024	04.10 pm	
139	27.06.2024	10.44	10.5	0.06	5559	LED Light not working	MCRI Ophthal OPD	27.06.2024	10.50 am	
140	27.06.2024	16	17.15	1.15	1475	Gizer not working	CVTS	28.06.2024	0450 pm	
141	28.06.2024	15	16	1	1836	Switch Board not working	Labour Room	28.06.2024	04.50 pm	
142	29.06.2024	10.33	10.33	0	1132	Tharmameter not working	MJPJAY Ward	29.06.2024	10.40 am	
143	29.06.2024	11.05	11.1	0.05	668	Switch board cap removed	New Deluxe	29.06.2024	11.20 am	
144	29.06.2024	12	13.25	1.25	932	LED Bulb not working	Pharmacology passage	29.06.2024	02.00 pm	

Electrical Supervisor  
MGM-EED Aurangabad

Electrical Engineer  
MGM-EED Aurangabad

Technical Executive(Elect.)  
MGM-EED Aurangabad

HOD  
MGM-EED Aurangabad

**MGM MEDICAL COLLEGE & HOSPITAL**  
**ELECTRICAL MAINTANCE REPORT 01 July 2024 to 31 July 2024**

Sr.No.	Received Date	Time	Attende Time	Response Time	Cpmplaint No.	Nature Of Complent	Name Of Department	Date Of Complation	Close Time	Remark
1	01.07.2024	10.05	10.5	0.45	1481	Gizer not working	CCU	01.07.2024	11.10 am	
2	01.07.2024	10.05	10.5	0.45	1480	Pedstral fan not working	CCU	01.07.2024	11.10 am	
3	01.07.2024	10.43	11.1	0.67	1133	Gizer not working	MJPJAY Ward	01.07.2024	11.20 am	
4	01.07.2024	11	11.1	0.1	2099	UPS Not working	Cath lab	01.07.2024	11.30 am	
5	01.07.2024	10	10.35	0.35	963	LED Light not working	Casualty	01.07.2024	04.10 pm	
6	01.07.2024	11.44	14.45	3.01	1833	Tube light not working	OT Complex	01.07.2024	03.30 pm	
7	01.07.2024	11.44	14.45	3.01	1834	Tube light not working	OT Complex	01.07.2024	03.30 pm	
8	01.07.2024	15.13	16.48	1.35	184	Switch Board not working	Nursing Collage	03.07.2024	12.00 pm	
9	02.07.2024	11.52	12.15	0.63	1510	LED Light not working	Cardiac OT	02.07.2024	05.00 pm	
10	02.07.2024	10.45	11.1	0.65	895	Exhust fan not working	Endoscopy	03.07.2024	04.00 pm	
11	02.07.2024	14.3	15	0.7	1614	Wall Fan not working	FMW 02	06.07.2024	03.45 pm	
12	02.07.2024	12.33	14.25	1.92	722	Gizer not working	Female Ortho Ward	04.07.2024	12.15 pm	
13	03.07.2024	14	14	0	236	Wall Fan not working	Physiotherepy OPD	03.07.2024	02.45 pm	
14	03.07.2024	15	15	0	689	Tharmameter not working	Old Deluxe	03.07.2024	03.10 pm	
15	03.07.2024	11	15	4	1138	Gizer not working	MJPJAY Ward	03.07.2024	03.20 pm	
16	03.07.2024	10.45	12.35	1.9	965	Switch Board not working	Casualty	03.07.2024	03.30 pm	
17	03.07.2024	11.15	13.5	2.35	2407	Switch Board not working	MJPJAY ICU	03.07.2024	02.20 pm	
18	03.07.2024	10.15	11	0.85	3777	Celling Fan not Working	Excative Deluxe	03.07.2024	11.00 am	
19	04.07.2024	10.15	11.45	1.3	725	Switch Board not working	Female Ortho Ward	04.07.2024	12.00 pm	
20	04.07.2024	9.45	10	0.55	287	LED Light not working	Blood Bank	04.07.2024	10.30 am	
21	04.07.2024	10.51	12.35	1.84	804	View box not working	MCRI ICU	04.07.2024	12.55 pm	
22	04.07.2024	12.35	15.3	2.95	1763	Cat-6 Cable laying work	Microbiology	05.07.2024	04.10 pm	
23	04.07.2024	15.4	15.4	0	3159	Tube light not working	PSY Ward	04.07.2024	04.00 pm	
24	04.07.2024	16	16.35	0.35	3605	Gizer not working	MSW 01	09.07.2024	04.00 pm	
25	05.07.2024	10.4	10.48	0.08	1841	Extension Board not working	OT Complex	05.07.2024	10.55 am	
26	05.07.2024	11.25	14.35	3.1	1840	Switch Board not working	Labour Room	05.07.2024	03.10 pm	
27	05.07.2024	11.25	14.35	3.1	1841	Fouse lamp not working	Labour Room	05.07.2024	02.35 pm	
28	05.07.2024	13	14	1	1842	LED Light not working	Labour Room	05.07.2024	02.45 pm	
29	05.07.2024	10.16	11	0.84	1842	Switch Board not working	EMS-P	05.07.2024		
30	06.07.2024	11	14.15	3.15	3575	Switch Board not working	Blood Bank	06.07.2024	02.45 pm	
31	06.07.2024	15.3	15.45	0.15	2477	Switch Board not working	OBGY Dept.	06.07.2024	04.00 pm	
32	06.07.2024	20	20	0	7734	Celling Fan not Working	Excative Deluxe	08.07.2024	06.50 pm	
33	08.07.2024	13.1	14.18	1.08	3783	Celling Fan not Working	Casualty	08.07.2024	02.25 pm	
34	08.07.2024	12.03	17	4.97	978	R/O not working	MICU	08.07.2024	05.15 pm	
					250	X-Ray view box not working				

*(Signature)*  
 24/10/24

35	08.07.2024	11.21	12.05	0.84	2838	Wall Fan not working	Medical Store	09.07.2024	03.35 pm	
36	08.07.2024	14.1	14.55	0.45	1947	Lift no.05 fan not working	Time office	09.07.2024	05.00 pm	
37	09.07.2024	11.54	11.54	0	Latter	Light & fan not working	Yeshwant Graphics	09.07.2024	12.10 pm	
38	09.07.2024	11.35	12	0.65	3417	Round plate ceiling removed	Urology ward	09.07.2024	04.15 pm	
39	09.07.2024	11.51	12.15	0.64	241	Stabilaizer loos connection	PSY OPD	09.07.2024	12.45 pm	
40	09.07.2024	11.43	12.1	0.67	3374	Switch Board not working	SICU	09.07.2024	04.58 pm	
41	09.07.2024	19	19.15	0.15	1948	Dr.hostel light not working	Time office	09.07.2024	07.30 pm	
42	10.07.2024	10.05	10.2	0.15	1843	LED Light hanging	Labour Room	10.07.2024	10.30 am	
43	10.07.2024	11.05	11.3	0.25	33	Tharmameter not working	MMW 01	10.07.2024	12.15 pm	
44	10.07.2024	10	10.15	0.15	930	LED Light not working	Dyotan Hall	10.07.2024	12.17 pm	
45	10.07.2024	13.11	14.3	1.19	1001	LED Light not working	Endoscopy	10.07.2024	03.00 pm	
46	10.07.2024	14.3	15.4	1.1	1949	Dr.hostel light not working	Time office	10.07.2024	04.15 pm	
47	10.07.2024	18.1	18.18	0.08	256	Switch Board not working	MICU	10.07.2024	06.30 pm	
48	10.07.2024	17.3	17.5	0.2	18705	Fridge not working	Nursing Collage	11.07.2024	09.35 am	
49	10.07.2024	10.3	11	0.7	3378	LED Light not working	SICU	27.07.2024	10.00 am	
50	11.07.2024	14.18	15	0.82	1275	Lan cable laying work	Radiology	11.07.2024	04.15 pm	
51	11.07.2024	11.28	11.5	0.22	379	LED Tube light not working	ENT Ward	11.07.2024	12.35 pm	
52	11.07.2024	12	14	2	1766	Cat-6 Cable laying work	Microbiology	12.07.2024	04.45 pm	
53	11.07.2024	12.21	13	0.79	1996	Exhust fan not working	Central Liabrary	26.07.2024	12.40 pm	
54	12.07.2024	10.35	11.31	0.96	1317	Central Store light not working	Central Store	12.07.2024	11.46 am	
55	12.07.2024	10.35	15	4.65	823	Bathroom light not working	Pharmaclogy Dept.	12.07.2024	03.55 pm	
56	12.07.2024	11.36	12	0.64	3224	Tube light not working	Dermatology skin ward	13.07.2024	10.10 am	
57	13.07.2024	9.15	10	0.85	1004	New tharmameter req.	Endoscopy	13.07.2024	10.35 am	
58	13.07.2024	11.15	13.5	2.35	1611	LED Tube light not working	FMW 02	13.07.2024	02.15 pm	
59	13.07.2024	7.01	7.1	0.09	1956	Dr.hostel light not working	Time office	13.07.2024	07.15 am	
60	13.07.2024	9.15	9.3	0.15	699	R.no 656 light not working	Old Deluxe	13.07.2024	09.39 am	
61	13.07.2024	12.4	13	0.6	3145	Celling Fan not Working	FSW 02	15.07.2024	11.46 am	
62	14.07.2024	13.2	13.2	0	840	Switch Board not working	OBGY 01	14.07.2024	01.27 pm	
63	15.07.2024	11.15	11.15	0	292	Wall Fan not working	Blood Bank	15.07.2024	11.20 am	
64	15.07.2024	9.59	10.2	0.61	1854	LED Tube light not working	OT Complex	15.07.2024	10.45 am	
65	15.07.2024	12.38	12.38	0	644	Extension Board not working	Pathology Dept.	15.07.2024	12.40 pm	
66	15.07.2024	11.02	12	0.98	1085	Wire insulation removed	ENT OPD	15.07.2024	12.40 pm	
67	15.07.2024	10	10	0	187	Light & fan not working	Physiotherepy OPD	15.07.2024	10.10 am	
68	15.07.2024	15.03	15.25	0.22	1489	Gizer not working	CCU	15.07.2024	15.35 pm	
69	15.07.2024	11.56	12.2	0.64	700	Celling Fan not Working	Old Deluxe	16.07.2024	11.20 am	
70	15.07.2024	11.12	12	0.88	843	Celling Fan not Working	OBGY 01	16.07.2024	05.35 pm	
71	16.07.2024	11	13.3	2.3	3610	Gizer not working	MSW 01	16.07.2024	02.00 pm	
72	16.07.2024	12.05	12.3	0.25	844	Bathroom light not working	OBGY 01	16.07.2024	01.40 pm	
73	16.07.2024	2	2.2	0.2	1594	LED Light not working	Metran office	16.07.2024	02.40 pm	



74	16.07.2024	2.1	2.3	0.2	260	Celling Fan not Working	MICU	16.07.2024	04.35 pm	
75	16.07.2024	10.2	15	4.8	144	Cat-6 Cable Hanging	OBGY ICU	16.07.2024	05.15 pm	
76	16.07.2024	13	13.4	0.4	1005	15 w. LED light not working	Endoscopy	18.07.2024	01.50 pm	
77	16.07.2024	11.3	12	0.7	36	Fridge not working	MMW 01	27.08.2024	12.30 pm	
78	17.07.2024	10.45	11.2	0.75	1846	Tharmameter not working	Labour Room	17.07.2024	12.15 pm	
79	17.07.2024	11.05	13.4	2.35	1041	A/C not working	Medicine Dept.	17.07.2024	02.15 pm	
80	17.07.2024	11.25	11.35	0.1	1504	Tharmameter not working	Old Deluxe	17.07.2024	03.10 pm	
81	17.07.2024	11.45	14.1	2.65	1042	LED Tube light not working	Medicine Dept.	17.07.2024	02.30 pm	
82	17.07.2024	12.35	14.5	2.15	1997	Bell not working	Central Liabrary	17.07.2024	03.20 pm	
83	17.07.2024	14.35	15	0.65	993	15w.LED Light not working	Casualty	17.07.2024	04.20 pm	
84	17.07.2024	10.59	11.45	0.86	18707	Bathroom light not working	Nursing Collage	20.07.2024	02.00 pm	
85	18.07.2024	12.3	13.1	0.8	1506	Exhust fan not working	Old Deluxe	05.08.2024	04.30 pm	
86	18.07.2024	11.35	12	0.65	15	Bathroom light not working	Cath lab	22.08.2024	12.00 pm	
87	19.07.2024	12.4	12.4	0	3428	Humidity meter not working	OT Complex	19.07.2024	12.50 pm	
88	19.07.2024	11.15	12	0.85	1007	15w.LED Light not working	Endoscopy	20.07.2024	10.05 am	
89	19.07.2024	11.2	11.2	0	3043	Tharmameter not working	Male Ortho wd.01	20.07.2024	10.30 am	
90	19.07.2024	10.35	11	0.65	852	LED Tube light not working	Pul.medi.ward	20.07.2024	09.45 am	
91	19.07.2024	14	16.3	2.3	3147	Switch Board not working	FSW 03	20.07.2024	04.40 pm	
92	19.07.2024	12.15	13	0.85	1146	Gizer not working	MJPJAY Ward	20.07.2024	04.51 pm	
93	20.07.2024	14.15	14.15	0	1960	LED Tube light not working	Dean Office	20.07.2024	02.30 pm	
94	20.07.2024	14.15	14.25	0.1	2805	Exhust fan not working	Surgury wd 02	20.07.2024	02.40 pm	
95	20.07.2024	17.09	17.4	0.31	3791	LED Light not working	Excative Deluxe	22.07.2024	05.18 pm	
96	20.07.2024	11.05	11.4	0.35	1510	LED Light not working	Old Deluxe	24.07.2024	05.13 pm	
97	20.07.2024				2274	Air Blower not working	STP / ETP	26.07.2024		
98	21.07.2024	19.3	19.55	0.25	1961	Lift no 01 Not working	Time office	21.07.2024	08.25 pm	
99	22.07.2024	10	10.45	0.45	170	Projector cable hanging	Physiotherepy collage	23.07.2024	11.50 am	
100	22.07.2024	13	14	1	1751	LED Light not working	EICU	25.07.2024	10.00 am	
101	22.07.2024	20.3	20.4	0.1	1962	Lift no 01 Not working	Time office	22.07.2024	08.50 pm	
102	23.07.2024	11.57	13.3	1.73	987	Bathroom light not working	KT ICU	23.07.2024	01.50 pm	
103	23.07.2024	13.55	13.55	0	243	All ceiling fan checked	Physiotherepy opd	23.07.2024	04.29 pm	
104	23.07.2024	15.38	16.2	0.82	1703	Old A/C Supply Disconnect	Dental opd	23.07.2024	04.35 pm	
105	23.07.2024	7.3	8.24	0.94	3422	ELCB Triping 3/4 times	Urology ward	23.07.2024	08.24 pm	
106	23.07.2024	11.45	11.45	0	1848	Extension Board not working	Labour Room	23.07.2024	12.20 pm	
107	23.07.2024	14.3	14.55	0.25	1668	LED Tube light not working	Pul.medi.ward	24.07.2024	03.20 pm	
108	23.07.2024	9.3	10	0.7	1277	LED Light not working	Radiology	23.07.2024	12.40 pm	
109	24.07.2024	11.1	11.1	0	1706	Tharmameter not working	Ped.wd 01	24.07.2024	11.20 am	
110	24.07.2024	12.25	14.53	2.28	853	LED Tube light not working	Pul.medi.ward	24.07.2024	03.00 pm	
111	24.07.2024	11.3	15	3.7	3378	Celling Fan not Working	PSM Dept.	24.07.2024	03.30 pm	
112	24.07.2024	16.45	17.3	0.85	1278	New switch board installation	Radiology	25.07.2024	04.00 pm	

113	24.07.2024	17	17.36	0.36	682	Bathroom light not working	New Deluxe	25.07.2024	05.36 pm	
114	24.07.2024	15	15	0	3653	Req.electrician 2nd floor	fire safety	24.07.2024	03.00 pm	
115	25.07.2024	10	12	2	216	LED Light not working	Super Deluxe	25.07.2024	12.00 pm	
116	25.07.2024	13	13.5	0.5	1903	Switch Board not working	Step Down ICU	25.07.2024	02.10 pm	
117	25.07.2024	13	13.5	0.5	1902	Celling Fan not Working	Step Down ICU	25.07.2024	02.10 pm	
118	25.07.2024	15	16.55	1.55	1617	LED Light not working	PICU	07.08.2024	02.11 pm	
119	25.07.2024	11.4	12.35	0.95	1000	Celling Fan not Working	Casualty	07.08.2024	10.25 am	
120	25.07.2024	16	16.4	0.4	1014	R/O not working	Endoscopy	25.07.2024	04.40 pm	
121	26.07.2024	14.3	14.45	0.15	3176	Burning smell	PSY Ward	26.07.2024	02.45 pm	
122	26.07.2024	16	16.5	0.5	645	LED Light hanging	Pathology Dept.	26.07.2024	05.00 pm	
123	26.07.2024	17	17	0	1972	Near MICU Steps tube not wor	Time office	26.07.2024	05.20 pm	
124	26.07.2024	11.5	12.15	0.65	1669	LED Tube light not working	Pul.med. ward	26.07.2024	04.36 pm	
125	26.07.2024	20.01	20.01	0	1881	Three pin top installation	OT Complex	26.07.2024	08.22 pm	
126	26.07.2024	19.12	19.45	0.33	1973	Parking lift not working	Time office	27.07.2024	09.10 am	
127	26.07.2024	11	12	1	302	LED Light not working	Casualty	06.08.2024	03.10 pm	
128	26.07.2024	11.5	12.35	0.85	3793	LED Light not working	Excavite Deluxe	08.08.2024	10.00 am	
129	27.07.2024	12.45	12.45	0	7251	X Ray view box not working	Pead wd 02	27.07.2024	01.06 pm	
130	27.07.2024	16.47	16.47	0	3634	Celling fan changed	fire safety	27.07.2024	04.47 pm	
131	27.07.2024	15.4	15.4	0	Latter	Celling Fan not Working	Dietetics Dept.	27.07.2024	03.40 pm	
132	27.07.2024	14.5	15.3	0.8	1517	Bathroom light not working	Old Deluxe	27.07.2024	05.20 pm	
133	27.07.2024	21.56	21.56	0	1974	Passage Light not working	Time office	27.07.2024	09.56 pm	
134	28.07.2024	15.4	15.4	0	846	Switch Board not working	OBGY Wd 01	28.07.2024	04.05 pm	
135	29.07.2024	10.45	11.33	0.88	53	Switch Board not working	Dermatology Wd	29.07.2024	05.54 pm	
136	29.07.2024	11.5	12	0.5	847	Switch Board not working	OBGY Wd 01	29.07.2024	05.00 pm	
137	29.07.2024	12.41	13.3	0.89	1951	Switch Board not working	NICU	29.07.2024	04.45 pm	
138	29.07.2024	16	17	1	3879	Switch Board not working	FSW 01	29.07.2024	05.45 pm	
139	29.07.2024	10.51	11.25	0.74	2787	Celling Fan not Working	Nepro Ward	30.07.2024	10.36 am	
140	29.07.2024	11.49	11.56	0.07	684	Switch Board not working	New Deluxe	30.07.2024	11.36 am	
141	29.07.2024	17.3	17.5	0.2	1977	Lift no 06 not working	Time office	30.07.2024	09.35 am	
142	29.07.2024	15.4	16	0.6	3628	Projector cable laying work	Neprology Dept.	30.07.2024	05.30 pm	
143	30.07.2024	14.16	15	0.84	1978	Lift no 01 Not working	Time office	30.07.2024	03.30 pm	
144	30.07.2024	12.35	15	2.65	150	New switch board installation	Ophthal OPD	30.07.2024	03.35 pm	
145	30.07.2024	14.54	15.1	0.56	1980	Switch Board not working	Time office	30.07.2024	03.40 pm	5th floor
146	30.07.2024	14.07	15	0.93	850	Celling Fan not Working	OBGY WD 01	30.07.2024	03.15 pm	
147	30.07.2024	15.15	16	0.85	2823	LED Tube light not working	Anatomy	31.07.2024	10.07 am	
148	30.07.2024	12.18	13	0.82	1275	LED Light not working	MET Cell	08.08.2024	02.20 pm	
149	31.07.2024	10.4	10.4	0	2397	Switch Board not working	MCRI OPD	31.07.2024	10.50 am	
150	31.07.2024	17	17.45	0.45	1202	LED Tube light not working	PSY OPD	02.08.2024	04.10 pm	
151	31.07.2024	16.4	17	0.6	825	LED Light not working	MCRI ICU	09.08.2024	10.15 am	

152	31.07.2024	14.2	15.45	1.25	3629	LED Light not working	Neprology Dept.	09.08.2024	11.40 am	
153	31.07.2024	16.3	17.25	0.95	742	Light & fan not working	Female Ortho Ward	09.08.2024	11.30 am	

**Electrical Supervisor**  
MGM-EED Aurangabad

**Electrical Engineer**  
MGM-EED Aurangabad

**Technical Executive(Elect.)**  
MGM-EED Aurangabad

**HOD**  
MGM-EED Aurangabad

**MGM MEDICAL COLLEGE & HOSPITAL**  
**ELECTRICAL MAINTANCE REPORT 01 Aug 2024 to 31 Aug 2024**

Sr.No.	Received Date	Time	Attende Time	Response Time	Cpmplaint No.	Nature Of Complent	Name Of Department	Date Of Complation	Close Time	Remark
1	01.08.2024	12	12.3	0.3	307	LED Light not working	Casualty	01.08.2024	01.00 pm	
2	01.08.2024	12	12.55	0.55	1893	Switch Board not working	OT Complex	01.08.2024	02.00 pm	
3	01.08.2024	11	11.5	0.5	19	Bathroom light not working	Cath lab	01.08.2024	03.05 pm	
4	01.08.2024	16	17	1	1983	Lift no 01 Not working	Time office	01.08.2024	06.05 pm	
5	02.08.2024	13	13.5	0.5	1532	Celling Fan not Working	Old Deluxe	02.08.2024	02.30 pm	
6	02.08.2024	16	16	0	2549	Pedstral fan not working	CVTS	02.08.2024	16.3	
7	02.08.2024	9.3	10	0.7	1984	Lift no 05 not working	Time office	02.08.2024	10.45 am	
8	02.08.2024	12.3	13.1	0.8	2824	LED Tube light not working	Anatomy	07.08.2024	11.30 am	
9	02.08.2024	12.3	13.1	0.8	2825	A/C not working	Anatomy	07.08.2024	12.30 pm	
10	02.08.2024	16.3	17	0.7	18712	Celling Fan not Working	Nursing Collage	07.08.2024	03.15 pm	
11	02.08.2024	15.3	16	0.7	826	Switch Board not working	Pharmaclogy Dept.	07.08.2024	04.55 pm	
12	03.08.2024	9	9.3	0.3	1986	Switch Board not working	Time office	03.08.2024	09.40 pm	6th floor
13	03.08.2024	12	12	0	3181	Switch Board not working	Psy Ward	03.08.2024	12.1	
14	03.08.2024	12.3	15	2.7	1103	LED Light not working	Exam Cell	03.08.2024	03.40 pm	
15	03.08.2024	11.57	12.35	0.78	1897	LED Light not working	OT Complex	06.08.2024	11.15 am	
16	05.08.2024	10.24	10.3	0.06	2072	Tharmameter not working	Ophthal ward	05.08.2024	10.30 am	
17	05.08.2024	12.58	13.3	0.72	314	LED Light not working	Casualty	06.08.2024	12.35 pm	
18	05.08.2024	10.29	11	0.71	1755	LED Light not working	EICU	05.08.2024	12.00 pm	
19	05.08.2024	10	10.3	0.3	1013	LED Light not working	Endoscopy	05.08.2024	11.15 am	
20	05.08.2024	10	10	0	2808	LED Tube light not working	Anatomy	05.08.2024	11.45 am	
21	05.08.2024	12.05	13	0.95	18713	Light & fan not working	Nursing Collage	07.08.2024	05.03 pm	
22	05.08.2024	10.14	11	0.86	296	LED Light not working	Blood Bank	08.08.2024	03.30 pm	
23	05.08.2024	13.35	15.1	1.75	3185	LED Light not working	PSY Ward	10.08.2024	04.00 pm	
24	06.08.2024	12.05	12.05	0	388	Tharmameter not working	ENT Ward	06.08.2024	12.15 pm	
25	06.08.2024	15	16	1	2807	Switch Board not working	Surgury ward 02	06.08.2024	04.40 pm	
26	06.08.2024	13	14.25	1.25	827	Projector cable laying work	Pharmaclogy Dept.	07.08.2024	04.50 pm	
27	06.08.2024	12.48	15.3	2.82	3874	Switch Board not working	FSW 01	10.08.2024	04.00 pm	
28	07.08.2024	15	16.5	1.5	2646	Switch Board not working	Dialysis	07.08.2024	05.20 pm	
29	08.08.2024	10.55	10.55	0	1963	Switch Board not working	NICU	08.08.2024	11.00 am	
30	08.08.2024	16.45	17	0.55	1282	LED Light not working	Radiology	08.08.2024	05.00 pm	
31	08.08.2024	15.15	15.4	0.25	1283	X-Ray view box not working	Radiology	09.08.2024	05.01 pm	
32	09.08.2024	10	10.3	0.3	690	Tharmameter not working	New Deluxe	09.08.2024	10.30 am	
33	09.08.2024	9.15	11.3	2.15	3046	Fan regulator cap brokrn	Male Ortho wd.01	09.08.2024	12.00 pm	
34	09.08.2024	10	10.25	0.25	2333	Pedstral fan not working	MCRI OPD	09.08.2024	12.45 pm	

*W.A.Ambekar*  
24/10/24

35	09.08.2024	12.2	12.55	0.35	2562	LED Tube light not working	MRD Dept.	09.08.2024	03.00 pm	
36	09.08.2024	11	16	5	1742	LED Tube light not working	Surgury OPD	09.08.2024	04.45 pm	
37	09.08.2024	10.1	11	0.9	1680	Bathroom light not working	Pul.medi.ward	09.08.2024	11.50 am	
38	10.08.2024	9.3	9.3	0	1284	LED Light not working	Radiology	10.08.2024	10.05 am	
39	10.08.2024	10.22	10.5	0.28	852	Switch Board not working	OBGY WD 01	10.08.2024	11.00 am	
40	10.08.2024	9.25	11.4	2.15	3379	Projector cable laying work	PSM Dept.	10.08.2024	12.10 pm	
41	10.08.2024	15.3	16	0.7	692	Celling Fan not Working	New Deluxe	10.08.2024	04.30 pm	
42	10.08.2024	14.05	15.3	1.25	1711	Switch Board not working	Ped.wd 01	10.08.2024	04.00 pm	
43	10.08.2024	11.2	12	0.8	1506	Switch Board not working	OT Complex	16.08.2024	10.40 am	
44	12.08.2024	11	11	0	728	Tharmameter not working	Male ortho wd 02	12.08.2024	11.25 am	
45	12.08.2024	10	14.35	4.35	3890	LED Tube light not working	FSW 01	12.08.2024	03.00 pm	
46	12.08.2024	10	10.3	0.3	1950	LED Light not working	Ophthal OT	12.08.2024	01.20 pm	
47	12.08.2024	11	13.35	2.35	1507	Extension Board not working	OT Complex	16.08.2024	11.00 am	
48	13.08.2024	15.45	16.1	0.65	1166	LED Tube hanging	MJPJAY WD	14.08.2024	11.40 am	
49	13.08.2024	11.08	12	0.92	3716	Switch Board not working	MGM SBSA	13.08.2024	12.25 pm	
50	13.08.2024	11.08	11.08	0	1743	LED Tube light not working	Surgury OPD	13.08.2024	11.22 am	
51	13.08.2024	11.15	11.3	0.15	3799	Gizer not working	Excative Deluxe	13.08.2024	11.55 am	
52	13.08.2024	9.4	10	0.6	1921	Tharmameter not working	Step Down ICU	13.08.2024	10.45 am	
53	13.08.2024	9.55	9.55	0	853	Light & fan not working	OBGY WD 01	13.08.2024	10.00 am	
54	13.08.2024	14.3	14.3	0	3364	Tharmameter not working	OBGY WD 03	13.08.2024	02.44 pm	
55	13.08.2024	11.15	15	3.85	3800	Celling Fan not Working	Excative Deluxe	13.08.2024	03.40 pm	
56	13.08.2024	8.2	8.2	0	3363	Light & fan not working	OBGY WD 03	13.08.2024	08.25 am	
57	14.08.2024	11.55	12.2	0.65	2827	LED Tube light not working	Anatomy	14.08.2024	12.20 pm	
58	14.08.2024	10.1	10.3	0.2	1202	Switch Board not working	MCRI OPD	14.08.2024	11.01 am	
59	14.08.2024	11.2	13.4	2.2	1760	LED Light not working	EICU	14.08.2024	02.20 pm	
60	14.08.2024	14.25	14.25	0	3229	Cat-6 Cable laying work	Dermatology OPD	14.08.2024	03.00 pm	
61	16.08.2024	11.25	12	0.75	2823	Celling Fan not Working	Surgury wd 02	17.08.2024	06.25 pm	
62	16.08.2024	9.2	9.2	0	1856	LED Light not working	Labour Room	16..08.2024	09.25 am	
63	16.08.2024	12.4	15	2.6	173	LED Tube light not working	MSK Neuro	16.08.2024	04.12 pm	
64	16.08.2024	9.4	9.4	0	1139	Light & fan not working	Biochemistry Dept.	16.08.2024	10.05 am	
65	16.08.2024	13.54	14.35	0.81	854	Bathroom light not working	OBGY WD 01	16.08.2024	10.15 pm	
66	16.08.2024	16	16.35	0.35	18718	Light & fan not working	Nursing Collage	17.08.2024	11.40 am	
67	16.08.2024	11.03	11.5	0.47	1205	Celling Fan not Working	MCRI OPD	19.08.2024	11.25 am	
68	16.08.2024	12.45	13.35	0.9	3660	Req.New switch board	fire safety	16.08.2024	02.00 pm	
69	16.08.2024	10.2	11	0.8	3188	Celling Fan not Working	Psy WD	20.08.2024	11.00 am	
70	16.08.2024	12.2	13.35	1.15	1954	LED Light not working	Ophthal OPD	19.08.2024	12.00 pm	
71	16.08.2024	12.4	12.4	0	172	Light & fan not working	IOP	23.08.2024	10.10 am	
72	17.08.2024	10.4	11.45	1.05	67	Switch Board not working	MMW 01	17.08.2024	12.05 pm	
73	17.08.2024	10	10.25	0.25	59	Celling Fan not Working	Plastic sur.wd	19.08.2024	10.45 am	

74	18.08.2024	11.15	12	0.85	295	LED Light not working	MICU	18.08.2024	04.21 pm	
75	18.08.2024	18.2	18.2	0	1630	Switch Board not working	PICU	18.08.2024	06.37 pm	
76	19.08.2024	9.15	9.15	0	1632	Disconnect the exhaust fan	PICU	19.08.2024	09.30 am	
77	19.08.2024	11.2	14	2.8	1627	LED Tube light hanging	FMW 02	19.08.2024	02.45 pm	
78	19.08.2024	15.35	16	0.65	1163	Celling Fan not Working	MJPJAY WD	19.08.2024	05.00 pm	
79	19.08.2024	16.1	17	0.9	2276	LED Tube light not working	STP / ETP	19.08.2024	12.30 pm	
80	20.08.2024	11	12.1	1.1	3622	Exhust fan not working	MSW 01	20.08.2024	04.28 pm	
81	20.08.2024	16	17.2	1.2	2601	Gizer not working	CCU/CVTS	20.08.2024	05.47 pm	
82	20.08.2024	12.15	13	0.85	1744	X-Ray view box not working	Surgury OPD	21.08.2024	10.37 am	
83	20.08.2024	12.45	14.3	1.85	2191	Pedstral fan not working	Registrection	21.08.2024	10.47 am	
84	20.08.2024	11	12	1	3661	Req.New switch board	fire safety	21.08.2024	11.05 am	
85	20.08.2024	14	14.1	0.1	1316	Wall Fan not working	Central Store	21.08.2024	02.31 pm	
86	20.08.2024	10.3	11	0.7	1205	Celling Fan not Working	PSY OPD	21.08.2024	10.10 am	
87	20.08.2024	14	14.35	0.35	1687	LED Tube light not working	Isolation ICU	22.08.2024	11.15 am	
88	21.08.2024	9.55	9.55	0	2834	LED Tube light hanging	Anatomy	21.08.2024	10.07 am	
89	21.08.2024	10.3	11	0.7	1110	LED tube light not working	Time office	21.08.2024	11.33 am	
90	21.08.2024	10.31	11	0.69	697	Switch Board not working	New Deluxe	21.08.2024	11.37 am	
91	21.07.2024	10.3	14	3.7	1824	LED Tube light not working	FMW 01	21.08.2024	02.30 pm	
92	21.08.2024	10.3	14	3.7	1823	Exhust fan not working	FMW 01	21.08.2024	02.15 pm	
93	21.08.2024	15.3	15.3	0	1027	LED Light not working	Endoscopy	21.08.2024	03.45 pm	
94	21.08.2024	12.35	13.25	0.9	1023	Switch Board not working	Endoscopy	21.08.2024	03.25 pm	
95	22.08.2024	10	10.25	0.25	1206	Switch Board not working	PSY OPD	22.08.2024	10.48 am	
96	22.08.2024	10.2	13	2.8	230	LED Light not working	Super Deluxe	22.08.2024	01.30 pm	
97	22.08.2024	9.15	12.5	3.35	1689	LED Light not working	Isolation ICU	22.08.2024	01.25 pm	
98	22.08.2024	10	10	0	1116	R/O not working	Time office	22.08.2024	01.00 pm	
99	22.08.2024	10.2	13	2.8	228	Switch Board not working	Super Deluxe	22.08.2024	01.00 pm	
100	22.08.2024	13.1	13.45	0.35	176	Switch Board not working	Physiotherepy	22.08.2024	02.20 pm	
101	22.08.2024	11.4	15	3.6	489	Celling Fan not Working	Ortho OPD	22.08.2024	03.30 pm	
102	22.08.2024	12.05	12.2	0.15	175	Switch Board not working	Physiotherepy	22.08.2024	12.40 pm	
103	22.08.2024	15.34	15.34	0	589	Celling Fan not Working	SS OPD	22.08.2024	03.56 pm	
104	22.08.2024	10.3	11	0.7	1115	All toilet tube light checked	Time office	22.08.2024	03.15 pm	
105	22.08.2024	16.3	17	0.7	74	Switch Board not working	MMW 01	22.08.2024	05.43 pm	
106	22.08.2024	17.45	17.45	0	1825	Switch Board not working	FMW 01	22.08.2024	05.45 pm	
107	22.08.2024	17.55	17.55	0	1169	X-Ray view box not working	MJPJAY WD	22.08.2024	05.55 pm	
108	22.08.2024	19.07	19.15	0.08	1975	Switch Board not working	NICU	22.08.2024	07.29 pm	
109	22.08.2024	11.55	13.35	1.8	831	LED Tube light not working	Animal House	26.08.2024	10.00 am	
110	22.08.2024	10.4	10.4	0	3441	Switch Board not working	Urology ward	23.08.2024	10.40 am	
111	23.08.2024	11.1	11.5	0.4	3352	LED Tube light not working	OBGY WD 03	23.08.2024	12.15 pm	
112	23.08.2024	14	15.3	1.3	1008	LED Light not working	Excative Deluxe	23.08.2024	04.00 pm	

113	23.08.2024	16.3	16.3	0	1123	G.toile tube not working	Time office	23.08.2024	04.30 pm	
114	23.08.2024	17.25	17.25	0	1122	MICU Waiting area fan not wo	Time office	23.08.2024	05.25 pm	
115	23.08.2024	14.25	14.4	0.15	1526	Switch Board not working	OT Complex	23.08.2024	03.15 pm	
116	24.08.2024	12	12	0	1527	X-Ray view box not working	OT Complex	24.08.2024	02.35 pm	
117	24.08.2024	15	15	0	2604	Air curtain not working	CCU/CVTS	24.08.2024	03.30 pm	
118	24.08.2024	15	15	0	1543	Celling Fan not Working	Old Deluxe	24.08.2024	03.27 pm	
119	24.08.2024	10.4	11	0.6	1440	LED Tube light not working	Biochemistry Dept.	26.08.2024	11.15 am	
120	25.08.2024	12	12	0	2820	Switch Board not working	Surgury ward 02	25.08.2024	12.30 pm	
121	26.08.2024	12.02	13.45	1.43	61	Wall Fan not working	Skin & Plastic sur.wd	27.08.2024	11.20 am	
122	26.08.2024	11.57	12.4	0.83	1977	Switch Board not working	NICU	27.08.2024	11.30 am	
123	26.08.2024	11	12	1	856	LED Light not working	MCRI ICU	27.08.2024	10.20 am	
124	26.08.2024	15.03	16	0.97	833	HDMI Cable laying work	Pharmaclogy Dept.	28.08.2024	11.15 am	
125	26.08.2024	12.1	12.45	0.35	3444	Cat-6 Cable laying work	Urology ward	28.08.2024	05.30 pm	
126	26.08.2024	10.3	11	0.7	3195	Wall Fan not working	PSY ward	06.09.2024	11.40 am	
127	27.08.2024	11.4	11.4	0	3196	Celling Fan not Working	PSY Ward	27.08.2024	11.50 am	
128	27.08.2024	11.1	12	0.9	2564	Air cooler not working	Record Section	27.08.2024	12.40 pm	
129	27.08.2024	15.15	15.15	0	251	Celling Fan not Working	PSY OPD	27.08.2024	03.30 pm	
130	27.08.2024	12.5	13.35	0.85	751	Exhust fan not working	Female Ortho Ward	27.08.2024	03.42 pm	
131	27.08.2024	14.3	15.4	1.1	3197	Celling Fan not Working	PSY Ward	27.08.2024	04.00 pm	
132	27.08.2024	11.2	15	3.8	18724	Switch Board not working	Nursing Collage	27.08.2024	03.30 pm	
133	27.08.2024	15.15	15.5	0.35	858	Exhust fan not working	MCRI ICU	27.08.2024	04.17 pm	
134	27.08.2024	15	16.25	1.25	1546	Celling Fan not Working	Old Deluxe	27.08.2024	04.43 pm	
135	27.08.2024	14	17.2	3.2	901	Celling Fan not Working	FSW 01	27.08.2024	05.50 pm	
136	28.08.2024	12	12.25	0.25	1216	LED Light not working	MCRI OPD	28.08.2024	01.00 pm	
137	28.08.2024	10.25	11	0.75	3198	LED Tube light not working	PSY Ward	28.08.2024	11.35 am	
138	28.08.2024	15	15.2	0.2	1638	Switch Board not working	PICU	28.08.2024	03.45 pm	
139	28.08.2024	12.35	14	1.65	2795	LED Tube light hanging	Neprology Ward	28.08.2024	02.30 pm	
140	28.08.2024	14.1	14.45	0.35	1547	Celling Fan not Working	Old Deluxe	28.08.2024	03.20 pm	
141	29.08.2024	10	10.1	0.1	2084	Tharmameter not working	Ophthal WD	29.08.2024	10.10 am	
142	29.08.2024	10.3	10.3	0	2567	Extension Board not working	CVTS	29.08.2024	10.40 am	
143	29.08.2024	12.45	14.15	1.7	1220	Switch Board not working	MCRI OPD	29.08.2024	02.59 pm	
144	29.08.2024	12	16	4	3434	Switch Board not working	Cardiac OT	29.08.2024	04.40 pm	
145	30.08.2024	11.5	13.45	1.95	651	Switch Board not working	Pathology Dept.	30.08.2024	02.00 pm	
146	30.08.2024	12	12.4	0.4	2192	LED Tube light not working	casualty registrection	30.08.2024	02.00 pm	
147	30.08.2024	12.58	16.3	3.72	1172	Celling Fan not Working	MJPJAY WD	30.08.2024	05.00 pm	
148	30.08.2024	11	16	5	1862	Bathroom light not working	Labour Room	30.08.2024	04.30 pm	
149	31.08.2024	14.3	14.3	0	1540	Switch Board not working	OT Complex	31.08.2024	03.00 pm	
150	31.08.2024	10.4	11.3	0.9	891	LED Light not working	Blood collection lab	31.08.2024	05.00 pm	
151	31.08.2024	12	15	3	2413	NET Rack installation	IT Dept.	31.08.2024	03.30 pm	

Electrical Supervisor  
MGM-EED Aurangabad

Electrical Engineer  
MGM-EED Aurangabad

Technical Executive(Elect.)  
MGM-EED Aurangabad

HOD  
MGM-EED Aurangabad