

Date	Dept:	Type of work	Use material	Qty	St. Sign	Work Sign	Room No
22/09/23	Library	2. wash Room in old 4 ft LED set Remove And New 40w set. Light fitting And ceiling fan Repair	LED set 40 watt fan	02 01	<u>[Signature]</u>		Libry kushna
22/09/23	Pathology	old fan Remove And Repair fan fitting	Fan	01			Path Dept.
22/09/23	PG Hostel	4th floor passage old tube light set Remove and New 20 watt LED Light fitting	LED 20 watt	04		<u>[Signature]</u> 22/09/23	4th Floor Passer
23/09/23	Physiology	2. ceiling fan Repair 1. fan old Remove And Repair fan fitting 1. fan Switch Proc 2. switch connection shifted	Fan	02	<u>[Signature]</u>		PH Pura Room
23/09/23	1st Ye PG Hostel	Fan 2 pin fitting			<u>[Signature]</u>		114
25/9/23	Girls Hostel	Fan capacitor change work	Fan capacitor change work		<u>[Signature]</u>	<u>[Signature]</u>	403
25/9/23	Girls Hostel	Fan Change work Done	Winding fan		<u>[Signature]</u>	<u>[Signature]</u>	209

Date	Dept	Area	Type of work	use material	Qty	Status	Wgn	Room
25/09/23	Girls Hostel	20	Wash Room light change	LED	01	✓	✓	2nd floor
25/09/23	Girls Hostel	10	Reeling Room in one LED light repld	LED	01	✓	✓	Reeling Room
25/09/23	Girls Hostel	10	LED Not working	LED Tubelights	01	✓	✓	
28/09/23	Street ans		2 old light set Remove And New LED set fitting	LED	02	✓	✓	301
28/09/23	PG Host	14	old fan Remove And Repair fan fit	Fan	01	✓	✓	301
29/09/23	PG Host	20	Wash Room Bulb fitting fan chng LED ch	Fan	01	✓	✓	301
29/09/23	PG Hostel		Wash Room Bulb fitting	Bulb	01	✓	✓	302
29/09/23	PG Host		Wash Room Bulb fitting Switch Board fitting Capacitor chng	Bulb	01	✓	✓	303
29/09/23	PG Hostel		old light set Remove LED fitting wash room bul	LED	02	✓	✓	304
			Switch Board R	Bulb	01	✓	✓	

Date	Dept	Type of work	Material	Qty	Room/Any
29/09/23	Staff canteen	Fan Replaced And one LED light Replaced	Fan LED	01 01	501
<del>29/09/23</del>	<del>PG Hostel</del>	<del>Wall fan installation</del>	<del>Fan</del>	<del>01</del>	<del>416</del>
29/09/23	PG Hostel	Fan Repairing capacitor Power supply Problem Trips on - LED ch	Capacitor Bulb LED	01 01 01	305
29/09/23	PG Hostel	Fan Replaced & wash Room Bulb change	Fan Bulb	01 01	307
29/09/23	PG Hostel	LED Light Replaced wash room Bulb Change LED Capacitor ch	LED Capacitor Bulb	01 01 01	308
29/09/23	PG Hostel	Switch Panel Repair Fan Repair wash room Bulb fitting LED Rep	Fan Wash Room Bulb	01 01	309
29/09/23	PG Hostel	Fan Replaced LED Replaced wash room Bulb fitting	Fan LED Bulb	01 01 01	310
29/09/23	PG Hostel	Fan Capacitor ch LED ch Capacitor ch	Capacitor LED Bulb	01 01 01	311

Date	Dept	Type of work
05/10/22	PG Hostel Hospital	gypsum point MCB fitting
05/10/23	PG Hostel Boy's Hostel	wall fan New installation 1 - Fan replace
06/10/23	Kharghar Hostel	4 <sup>th</sup> floor of room fan repairing
06/10/23	PG Hostel	gypsum triper repairing
06/10/23	Animal House	old tube light set remove and new 20 watt LED fitting. Rewiring of LED set. clip properly fitting
6/10/23	Girls Hostel	fan repairing work
6/10/23	Girls Hostel	fan repairing work

Use Mch	Qty	Sty	W. Sic	Room
MCB Box PVC	01			423
MCB SP. 200	01			423
Fan	01			416
1 - Fan replace	01			416
				409
				PG 502
LED	01			Animal Host
Fan repairing work				510
Fan repairing work				414

06/10/23	306 Girls Hostel	Fan repairing work
6/10/23	Girls Hostel	Fan change work room No-2
06/10/23	Boys Hostel	Telnet light point Repairing
07/10/23	University	Auditorium Hall in Extra power point Removal Box And Removal
09/10/23	PG Hostel B Hospital	old light set Removal And New LED fitting
09/10/23	PG Hostel Hosp	old fan Removal And Repaired fan fitting
09/10/23	PG Hostel	old fan Removal And Repaired fan fitting
09/10/23	Girls Hostel	gypsum wire jointing
09/10/23	Girls Hostel	LED chug

Fan repairing work	Handy Room 306
Fan change work	02
Telnet light point Repairing	Boys 01
Auditorium Hall in Extra power point Removal Box And Removal	Auditor Hall
old light set Removal And New LED fitting	PG 410
old fan Removal And Repaired fan fitting	PG 405
old fan Removal And Repaired fan fitting	422
gypsum wire jointing	1st floor
LED chug	01

Date	Dept.	Type of work	use material	Qty	Student	Wardn	Room
10/10/23	university	Academic section Caset Ac. power sup on Tripes on			95 Pad		Acad 25
10/10/23	TIB. Lab.	2 Fans Repairing Capacitor change 6 module 4. switch Board Point Repairing to plywood from Machine And Proping fitting one old pl. Celling Light Remove And 36 watt New pl. light fitting 6 amp socket change	Capacitor LED sq 36 watt 6 Amp socket Switch Play pelt	02 01 01 01 02			T6 Lab
10/10/23	PG Hostel	Fan Repairing capacitor chr	Capacitor	01	Abir		125
11/10/23	PG Hostel	gysers Point Repairing			Pranav		108
11/10/23	Boys Hostel	old fan remove and old repair fan fitting.	Fan	01			113
11/10/23	Boys Hostel	old fan remove And Repaird fan fitting	Fan	01			114

Pranav  
11/10/2023

Date	Department	Type of work	Use material	QTY	Student	Workshop	Room
12/10/23	Animal Hostel	Auto lev-point Repairing 16 Amp combain Box Replect	Combain Box	01			Animal Hostel
12/10/23	staff dattar	1- fan replaced work	1- fan replaced work	01	<u>guzmel</u>		
12/10/23	Girls Hostel	2- fan capacitor change work	2 fan capacitor change work	2-	<u>Wagha</u>		201
12/10/23	P.G Hostel	gizzer switch connection change work	Gizzer switch connection change work	1	<u>Jan</u>		702
12/10/23	PG Hostel	fan repairing capacitor change	Capacitor	01	<u>Alkushi</u>		716
13/10/23	PG Hostel	PG Hostel Main Entrance Security Teluk up side one ceiling fan installation Down Road fitting 5 fit.	fan Down Road Poles Champ.	01 01 01			Flam Entrance Passage
13/10/23	Girls Hostel	fan 2 pin fitting work	2-pin change,	1	<u>Shree</u>		713
13/10/23	Girls Hostel	fan bleed change work.	fan bleed change work.	1	<u>Adar</u>		205
13/10/23	Girls Hostel	fan capacitor change work	fan capacitor change work	01	<u>Katering</u>		103

Date	Department	Type of work
13/10/23	Girls Hostel	4 fan Repairing capacitor change
14/10/23	Pathology	6 ceiling fans Repairing capacitor change. And Tube light point Repairing Switch wire prop- connected 2nd floor power point 4 pin Tweeper. MCB on.
14/10/23	14a PG Hostel	gasser point Repair → pin top fitting
14/10/23	Boys hostel	Switch Board Repairing
16/10/23	BOY'S HOSTEL	Holder fitting and regulator for fitting.
16/10/23	Boys Hostel	fan regulator fitting
16/10/23	BOY'S HOSTEL	regulator cap change
16/10/23	BOY'S HOSTEL	regulator cap change condens + capacitor

Case Material	Qty	Star	Ward	Room
Capacitor	01	<del>Star</del>	<del>Ward</del>	103
Capacitor	06			Patho Dept.
8 pin TOP	01	<del>Star</del>		507
		<del>Star</del>		513
Holder & 1-regulator	01	<del>Star</del>		211
Regulator	01	<del>Star</del>		208
regulator cap	02	<del>Star</del>		205
regulator cap	01	<del>Star</del>		204
change work light switch chan	01	<del>Star</del>		212

of 49. 212/204  
16/10/23



Date	Location	Description	Material	Qty	Remarks	Value
16/10/23	Boys Hostel	2 regulator New pilling work	2-regulator	02	@ 213	
18/10/23	PG Hostel	4 fans Repairing capacitor ch	Capacitor	02	Chang	515
19/10/23	Sq-	giver point Repairing 16 Amp combuin Box ch	16 Amp com	01		03
19/10/23	PG Hostel	LED Light Replaced	LED	01	A	507
20/10/23	University	Ac. point + MCB Replaced 10-to 16-	MCB - 16 An	01	28 Pa	4112
20/10/23	1st floor Medical college	Wash Room LED Light Change	LED	02		1st 4101
20/10/23	University	Ladies Wash Room (only fan)			28 Pa	
20/10/23	Boys Hostel	2 fans Repairing capacitor ch and fan ch	Fan Capacitor	01 01	@ 213	

21 Oct 2023  
20/10/23  
HOG

20/10/23	Boys Hostel	2 Fans Repairing capacitors change
20/10/23	Boys Hostel	fan Repairing capacitors change
21/10/23	PA Hostel	1G And combain Boy And spin top fitting
23/10/23	<del>Boys</del> Girls hostel	fan Replaced old Remover And repaired fitting
23/10/23	Girls hostel	fans repairing capacitors change
23/10/23	Girls Hostel	1- fan fitting fitting work
23/10/23	<del>Boys</del> Hostel Boys	old fan Remover And repaired fan fitting
25/10/23	Girls Hostel	fan Repairing capacitors change and Nut Bolt fix
25/10/23	Girls Hostel	LED change

Capacitor	02	<del>Par</del>	505
fan capacitor	01 01	soil	510
		flushed	112
fan	01	Remove	011
capacitors	02	change	012
1- fan fitting work	01	fix	107
fan	01	Remove fan Remove	206
capacitor	01	change	111
LED	02	fix	111

20/10/23  
20/10/23

Date	Dept.	Typical work
25/10/23	Girls Hostel	Fan Replaced
26/10/23	Kharghar Hostel	2. old Tube Light removed And New 22 watt LED Light fitting wash room light Replaced
26/10/23	Kharghar Hostel	Wash room LED light Replaced 15 watt.
26/10/23	Kharghar Hostel	old LED light set removed And New LED fitting one fan Regulator change
26/10/23	Boys Hostel	Old LED removed And New fitting fan Replaced
26/10/23	Boys Hostel	Fan Replaced old removed And Repair fitting

use material	Qty	Stock	Went to	Room No.
Fan	01			503
LED	02			304
15 watt LED	01			201
LED Regulator	01			312
LED Fan	01			308
Fan	01			201

Date	Department	Type of work	Material	Qty	Size	Wage	Room
26/10/23	Hospital - PG Hostel	Fan Repairing capacitor check	Capacitor	02	<del>1/2"</del>		407
27/10/23	Hospital PG Hostel	Fan Replaced old remove and repair fitting	Fan	01	<del>1/2"</del>		502
27/10/23	Medical College	Staff Ladies Toilet Bubb. Replaced	Bubb. gasket	01			Ladies Wash Room
27/10/23	PG Hostel	Wash Room Light fitting	LED	01	<del>1/2"</del>		113
27/10/23	Boy's Hostel	1-fan replace work	1-fan	01	<del>1/2"</del>		209
27/10/23	PG Hostel	Fan Capacitor check LED Bulb check	Capacitor Bulb	01 01	<del>1/2"</del>		406
27/10/23	PG Hostel	old Tube Light remove and New LED light fitting	LED	01	<del>1/2"</del>		515
27/10/23	PG Hostel	Fan Replaced	Fan	01	<del>1/2"</del>		506

Date	Dept.	Type of work	use number	Qty	SR	Words	Rae
28/10/23	Staff C	Gyzer point fepom Combr Repled -			<del>SR</del>		207
28/10/23	Pr R. Girls Wash	LED Light old Remor New fitting	LED	01	Amf		707
28/10/23	PG Hostel	old fan Remove And repaired fan fitting	fan	01	G		115
28/10/23	Medical College University	University chairman's office to Ac. section Passy- conference Hall And v. s. - cubines fan Reel Nut Bolt cheking And properly fitting Total 30 fans cheking?	Nut Bolt set	5 No-	SR		University
30/10/23	G.M.D.	Fan Repairing capacitor cheng	capacitor	01	Amf		Amf
30/10/23	Sq-	gyze point And wash point Power supply Juse prep Nutbol for And Jover			<del>SR</del>		108
30/10/23	Boys Hostel	1- fan replace work	fan replace work	01	Amf		411

30/11/23	Boys Hostel	1-fan replace work and 2-regulator fix work	1-Fan 2-regulator 01 regulator 02	Warden sign	210
01/11/23	Medical Col	AC section in LCD Display Net. cabling Cat 6 Cable fitting	Cat. 6. Cable 25 mt		PC
01/11/23	Gals Hostel	Fan Repairing	Fan replace		107
01/11/23	Girls Hostel	Fan replace	1-Fan replace 01		101
01/11/23	Girls Hostel	2-regulator replace and charging point connection work.	2-regulator 02 and charging point connection work.		112
01/11/23	Girls Hostel	Fan regulator check work.	Fan regulator 02 check work.		114
02/11/23	Canteen	Store pc point installation 6 model Box fitting 1 Earth Net Connection checking	6 model Box 01 6 model Plate 01 6 Amp Swic 02 Temp sensor 02 Cable 05 mt		Canteen Str
03/11/23	PG Hostel	Fan Repair	Fan 01 Cable 01		115

03/11/23 Hospital  
PG Hostel  
gysar point Repair  
Sun - Change And  
2 fans Repairing capca  
change

04/11/23 Library  
Reading Room: Ac point  
Repairing 16 Amp  
Combin Box And 16 Amp  
Spin Top. Change

04/11/23 Hospital  
Lodha  
gysar point  
Light Remove

06/11/23 PG Hostel  
2 old Tube light set  
Remove And New LED  
light fitting with  
Board Repairing

06/11/23 PG Hostel  
old Tube light set Remove  
And New LED light fitting  
2. Switch Board Repairing  
6 Amp sockets change

06/11/23 Boys Hostel  
fan Replaced old Remove  
And Repair fan filter

Cu 16A 01  
Capacitor 02

16 Amp Spin Top 01  
16 Amp Combin Box 01

LED 02  
Switch 01

LED 01  
Sockets 02

Fan 01

10

Reading Room

104

103

102

Date	Department	Type of work	Use material	Qc	Signature	Room No
07/11/23	PG Hostel	Gypsum point New fitting 16 Amp Combin Box	Combin Box	01	<i>[Signature]</i>	601
07/11/23	Canteen	Wipe Machine power point repairing Switch change	6 Amp Switch	01	<i>[Signature]</i>	121
07/11/23	Pathology	Wall fan Repaired And fitting	=	=	<i>[Signature]</i>	Patho Dept
07/11/23	7th Girls Hostel	Fan Replaced	Fan	01	<i>[Signature]</i>	716
8/11/23	Staff - Gals	Gypsum point Repairing 16 Amp Combin Box chng New LED light set fitting 05 old Tule light set removal 3 pin top change	Combin Box LED	01 03	<i>[Signature]</i>	<u>204</u>
08/11/23	S-Q	Fan repairing rewiring	Capacitor	01	<i>[Signature]</i>	505
08/11/23	7th floor PG Hostel	Fan Replaced	Fan	01	<i>[Signature]</i>	716
08/11/23	PG Hostel	Wash Room Bulb fitting	Bulb	01	<i>[Signature]</i>	411



					Work Site	
09/11/23	Biochemistry	Extension Panel Repairing 6 Amp socket change And 6 amp switch change	6 Amp socket 01 6 Amp switch 01			Bam
10/11/23	<del>Canteen</del> PG Hostel	Main Entrance PG Hostel in switch Panel Repairing Switch And socket Change	Switch 01 Socket 01			Pass
11/11/23	Staffs	Switch Panel Shifting		jul		204
13/11/23	Physiology	Lechertall No-02 in 2 sound speakers Remove And Demo Room in fitting And one Remove And fitting Cabling	Speakers 02	S. S. S.		
13/11/23	PG Hostel	Wash Room light change old Remove And New 6 watt LED light fitting	6 watt LED 01			PG-501
15/11/23	Canteen -	Air curtain front side Junk Remove And one stand fan insulation	Stand fan 01			Canteen

16/11/23	University	2 old 36 watt Panel Light remove And New LED set fitting.	LED	02	28 Poles	Chairman Sir cabin
16/11/23	Anatomy	Anatomy D-section Hall in removal Electrical Point Refitting 6 model Box 04. No fit	(old) 6 model Box 6 model plate Switch socket	04 04	2144/11	Dseg Heck
16/11/23	Girls Hostel	Reading Room with Router properly fitting Ground floor LED Honeyd LED Properly 3rd floor passage Light repairing 5th floor water cooler light Re	LED	02	85 poles	G. for 1st & 5th flr
16/11/23	Boys Hostel	Fan repairing	capacitor	01	(Signature)	05
17/11/23	University	old 2x2 light remove And New 2x2 LED panel light fitting	LED 2x2	01	28 Poles	Dr. S.N. Sir cabin

Date	Dept.	Type of work	Use Minded	Qty	Student Rate	Work on Site	Part No
20/11/23	Staff Q	Fan repairing Ruber Champ - Cheque	Ruber clamp	01	Puram	<del>Delena</del>	401g
20/11/23	Girls Hostel	Fan replace work & mcb checking work	1-fan replace work, mcb box checking work	01	<del>Puram</del>		
20/11/23	Girls hostel	old fan, remove and repaired fan filter	Fan	01	Jayari		311
20/11/23	Girls hostel	Reading Room fan Repld And Nut Bolt Repld Propag fitting	Fan	01			Reading Room
21/11/23	Canteen	water cooler power point fitting 2. combain Box fitting	combain Box	02	Jayari		
21/11/23	PG Hostel	Fan Repld old home And Repld fitting	Fan	01	kar		502
21/11/23	PG Hostel	bulb fitting	—				608
21/11/23	S-Q	Fan repairing capacitor chance	Capacitor	01	<del>Jayari</del>		506

22/11/23	PG Hostel	Fan Repairing capacitor chert	capacitor	01	<del>Handwritten signature</del>	<del>Handwritten signature</del> 22/11/2023	410
22/11/23	Boys Hostel	Fan Repairing	—	—	Durda	<del>Handwritten signature</del> 22/11/2023	506
22/11/23	Boys Hostel	Fan and tube light replece work	tube light Fan repairing	1	<del>Handwritten signature</del>	<del>Handwritten signature</del> 22/11/2023	411
28/11/23	University	Examination section 2. old 40 watt Pined Light Remove And New Light fitting	LED 40 watt	02	—	—	Examined sete
28/11/23	Anatomy	Anatomy Dissection Hall No. 2. 4. New power Point fitting 2. cassing casing pathi And 4. 16 Amp combain Box fitting	Combain Box cassing pathi wire - R-2's wire Black wire Green	02 02 05 m 05 m 05 m	—	—	Anatomy Disect hall
23/11/23	Boys Hostel	old fan remove work.	old fan remove work. and repare fan Rising verde	01	<del>Handwritten signature</del>	—	506
28/11/23	Boys Hostel	1-Fan replece work & Fan clamp change work	Fan replece work & Fan clamp change work Capacitor	01 01 01	<del>Handwritten signature</del>	—	413

Date	Department	Type of work	Use Material	Qty	Sicr	Womn	Ro
23/11/23	Staff	gypsum point Repairing combin Box And 2 pin top Charger	combin Box 2 pin top	02 01	MSS SPT		401
24/11/23	PG Hostel	Switch Board Repairing 16 Amp Switch	16 Amp	01			104 <del>104</del>
25/11/23	S. B. S	Switch Board shifting Well mounted Board frame And extend wire Alum portion up side fit	8 mtr Board Pia	01			SBS
25/11/23	Anatomy	1st floor passage Dissection out side LED Tube Light Hanging properly clip fitting					1st floor
25/11/23	PG Hostel	fan Repairing copper chess	capacitor	01			509
25/11/23	Boys Hostel	fan old Remover And Repair fit	fan	01			414
25/11/23	Boys Hostel	fan Repairing capacitor chess	capacitor	01			501
25/11/23	Canteen	1st floor fan chess	fan	01		सदन	stall Room

29/11/23	Boys Hostel	Fan Replaced old Remove And Repaired fan fitting	Fan	01		B10.
29/11/23	Boys Hostel	4th floor passage light hanging properly fitting				4th floor
29/11/23	Boys Hostel	5th floor passage light properly fitting				5th floor
30/11/23	University	Conference Hall old 2x2 LED panel light remove And New 40 watt panel light fitting	panel light <sup>40 watt</sup>	01		confere hall
30/11/23	Girls Hostel	Fan regulator fitting.	Fan regulator fitting.	01	<del>fitting</del>	402
30/11/23	Girls Hostel	Fan Regulator fitting Regulator	Regulator	02	<del>fitting</del>	409
30/11/23	PS m-	1 old Tube Light set Remove And New LED fitting 02 old Tube light set Rem	LED	01		PSm

01/12/23	Girls Hostel	Fan Repairing Steel choker	Band set -	01	<del>Pradip</del>	204
01/12/23	Girls Hostel	Fan Repairing capacitor chok	capacitor	01	<del>Pradip</del>	205
01/12/23	Canteen	LED Light Repairing Switch Base connect problems. Switch point change				Canteen
02/12/23	PG Hostel Reading Room	3. Fans Repairing old Regulator Remove And New 3. Regulator fitting	Regulator	03		Reading Room
02/12/23	Boys Hostel	old fan Remove And Repair fan fitting	Fan	01	Pradip	113
03/12/23	Nere PSC.	Dental chair connection Nere Hospital 12 model Box with plate fitting Cable fibre piping 6 model Box of Point fitting				Nere Hospital

Date	Dept.	Type of work	Use material	Qty	Sign	Work	Room
04/12/23	PG Hostel	Fan repairing capacitor change	capacitor	01			403
05/12/23	Pathology	Ceiling fan old Remover And Repair fan fitting	fan (Repaired)	01	}		Patho Practical Lab
05/12/23	Pathology	New Exhaust fan fitting old Remover Not worked	Exhaust fan	01			Lab-
05/12/23	P.G. Hostel	Table light repair work	Table light repair work	01			
06/12/23	Biocampus	Fan repairing capacitor change	Capacitor	01			
06/12/23	Canteen	Electrical Power point Checking ALL types fans And light power point 1. Stand fan Installation					Canteen
07/12/23	Library	E. Library PC Point Power supply Checking E.N.L. Property DITEN Test Checking 20. points checking					E. Library



07/12/23	Boys Hostel	1st floor Wash Room old Light Removal And New LED Light fitting	LED	01		1st 4100 watt Wash Room
8/12/23	Girls Hostel	Tube Light Repairing 1. feet 5 watt LED fitting	LED 5 watt	01	<u>ztlalala</u>	6 11
8/12/23	Girls Hostel	22 watt tube light & 12 watt 1-foot tube light.	22 watt - 1 12 watt - 1 3-model - 1	01 01 01	<del>Buyade</del>	
09/12/23	Staff Quarters	20 watt LED Light New fitting old Tube Light set removal And 2. LED Bulb with Room in fit	LED 4 fit LED Bulb	01 02	4	202
09/12/23	7th floor Girls Hostel	old fan removal And repaired fan fitting	Fan	01	<u>Refer</u>	715
11/12/23	Boys Hostel	old Tube Light set Removal And New LED Light fitting	LED	01	<u>Refer</u>	305
11/12/23	Boys Hostel	old Tube Light removal And New LED fit	LED	01	<u>Refer</u>	513
11/12/23	PG Hostel	Fan fixed	FAN	01	<u>Refer</u>	513

12/12/23 Library  
 Fi Library Pc Electrical  
 Power Point Repairing  
 3. Old socket Remove  
 And New fit

12/12/23 Girls Hostel  
 regulator replace work

12/12/23 Girls Hostel  
 capacitor change work

12/12/23 11 2-regulator change work

12/12/23 12 2-tube light

13/12/23 Medical cell  
 MELL  
 MELL. Main entrance  
 passegre Hanging wire  
 Propery fitting in  
 Casting Capping Patti  
 And old ceiling switch  
 Board Remove And PVC  
 8 model Box fitting  
 7th floor

13/12/23 PG Hostel  
 Switch Board Repairing  
 Sereket change

14/12/23 PG Hostel  
 geyser switch change

14/12/23 PG Hostel  
 geyser Switch Panel 16 Amp  
 MCB Remove And New  
 Switch fitting

Socket GA 03

regulator 01

Capacitor 01

2-regulator 02

2-tube light 02

8 model Box plate 01  
 Switch 05  
 socket 01  
 Blank plate 01  
 Casting patti 01

Switch 01

Switch 01

Switch 01

Elala

MELL  
 Passegre

Fikysia

Gog

Hot

Date	Dept	Type of work	Use Material	Qant	Weren Site	Standa	Room
14/12/23	PG Hostel	Fan Regulator fitting	Regul	01		Boys	413
15/12/23	Anatomy	New Dissection Hall in one Exhaust fan fitting And Properly Core chon					
16/12/23	Medical	Gents wash Room in one pl 2x2 # Light Repl	LED	01			Gents Wash Ro
18/12/23	Boys Hostel	Switch Board Repair Switch Socket Ch	Switch Socket	01 01		Boys	411
18/12/23	Boys Hostel	Fan Replaced old Remove And Replaced fir	Fan	01		Boys	410
19/12/23	Microbiology	2. Fans Regulator old Remove Panel New 2. modet. Regulator fitting	Regulator	02			Micro
19/12/23	MAIN CAMPUS Canteen Central	3 Nos 2x2 LED panel Replacement	3 Nos 2x2 LED panel	03		Canteen	19/12/23
19/12/23	Girls Hostel	2 - fan capacitor change work	2 - fan capacitor	02		Girls	511
19/12/23	Girls Hostel	1 - fan changed	1 - fan replaced	01		Girls	508
19/12/23	Girls Hostel	1 - fan replace	1 - fan replace	01		Girls	106

Date	Dept	Type of work	Use material	Qty	Stk	Worn	Per
20/12/23	PG Hostl	Gyser point Repairing Switch Connection check	Swire	01			610
21/12/23	Boys Hostl	Swire Board Repairing				Shunt	214
21/12/23	Girls Hostl	Reading Room in one LED Light Repairing	LED	01			Reading Room
21/12/23	In floor PG Hostl	old fan Remove And Repair fan fitting	Fan	01			402
21/12/23	7th floor PG Hostl	old fan Remove And Repair fan fitting	Fan	01			424
21/12/23	Boys Hostl	1 - Fan replace	01 - Fan	01		Spore	
22/12/23	Girls Hostl	fan old Remove And Repair fitting	Fan	01			405
22/12/23	Girls Hostl	old fan Remove And Repair fan fitting	Fan	01			403
24/12/23	Girls Hostl	Fan Repairing	Fan	01		Faded fan	06
23/12/23	PG Hostl	fan Repairing capacitor check	Capacitor Holder	01 01		disk	13

26/12/23	Medical College Account section	PC point ups Backup Battery Replaced	12 V. DC - Battery	01		AC se-
26/12/23	Anatomy	Exhaust fan fitting Proper power supply connection	fan 1.5	2		Area Dsection Hall
26/12/23	T.6 - Lab	old ceiling fan removed And repaired fan fitting	fan	01		<u>T.6-Lab</u>
27/12/23	MGM Gym	04. old Tube light Removed And New LED Battery light fitting	LED	04		<u>Gym</u>
27-12-23	MGM Hospital 5th floor Room no-516	LED light Replaced	LED	01	RT	516
27/12/23	Boys Hostel	Switch Bad Repairing Sew fitting. Proper	S	02	RT	210
28/12/23	Medical College	Conference hall out Side passage old LED light removed And New LED fitting	LED	01		Conference Hall outside

28/12/23	Micro Dept	one ceiling fan repairing And 2 fans Regulator Change UPS Backup Battery Replaced	Regulator UPS Battery	02 01			Micr
----------	------------	--	--------------------------	----------	--	--	------

28/12/23	Staff -	fan Regulator Replaced	Regul	01	<u>Final</u>		401
----------	---------	------------------------	-------	----	--------------	--	-----

28/12/23	Boys hostel	Switch Board Repairing And Table light Point Repair	/	/	<u>Final</u>		410
----------	-------------	---	---	---	--------------	--	-----

29/12/23	Anatomy	Anatomy Dissection Hall in ceiling fans Repair fan of light fixture 08 fan with Down rod Removal complete Remove blind box	/	/			Anatomy Dissec Hall-01
----------	---------	---	---	---	--	--	------------------------------

29/12/23	PH floor PG Hostel	Table light point sw Board Repairing	/	/			702
----------	-----------------------	---	---	---	--	--	-----

29/12/23	PH floor	Table light point Re light sw Re	/	/	<u>Final</u>		713
----------	----------	-------------------------------------	---	---	--------------	--	-----

30/12/23 Hospital PG Hostel  
 Wash Room Switch Board  
 Repairing given Point  
 Property fitting Room  
 in side. 6 modular Switch  
 Board Point Repairing  
 Neutral problem solve  
 2. 16 amp combain Box  
 fitting Tegul Light  
 Point Repairing

Combin Box 02 401

30/12/23 PG Hostel  
 Wash Room Light fitting  
 1. Switch change

Switch 01  
 Bulb - gwall 01 301

30/12/23 PG Hostel  
 Wash Room Bulb replaced  
 power point Repairing

to Bulb gwall 01 305-


30/12/23 PG Hostel  
 Switch Board Repairing  
 Anal fan Regulator  
 Replaced

fan regulator 01 307-

30/12/23 PG Hostel  
 one switch Board Power  
 Point Repairing socket  
 change

308

ME MHGON



MGM Medical College

Electrical Maintenance

Book January 2024  
to -

→ Nitin pimple (elect-) 9767114360

Bhagwan more (copper) 9702026457



• Excellent Runnability



No.	Date	Department	Type of Working	Use Material	Qty	Student Size	Worker Size	Room/Araya
1)	01/01/2024	Anatomy	Anatomy Dept. Dissection Hall in 8. Ceiling Remove for this Araya of Light set fitting. 8. Fans, Down-Rod, And Rubber clamp. Remove, fan Bleed Remove Handwork to Dept. person	No. material	=			Anatomy Dissection Hall
2)	02/01/24	Anatomy	Dissection Room in 4. New power point installation for ot. Light Hanging Type 4. combain Box fitting 6 model surface Box fitting	ss. combain Box wire. Reel wire Black 6 model Box plate 6 mp switch	04 40mt 40mt 01 04			Dissection Room No 01
3)	03/01/24	Anatomy	Dissection Room No 2 in ot. Light power point New connection installation 4 combain Box fitting wiring And main supply connection	Combain Box wire Reel wire Bk 6 model Box plate Swit-	04 45mt 30mt 01 04			Dissection Room No. 02
4)	03/01/24	PG Hostel	Fan Repairing Bleed change And wash Room Swith Base Repair Playsheet fit	Fan Bleed set	01	1mt		110

Manufactured by and Registered office: THE SHRI RAM PAPER MILLS LTD.

Excellent Printability

No	Date	Department	Type of Working	Use Material	Qty	Student Sign	Warden Sign	Amount/Re
57	03/01/24	Boys Hostel	fan Repairing capacitor change	capacitor	01			400
67	03/01/24	Boys Hostel	Tube-(LED) Light Repairing connection Probe wire properly Joint					507
77	04/01/23	PG Hostel	PG Hostel Mess intranc Ground floor to Basement Corridor Old Light Remove And New LED fitting	LED	01			Ground floor to mess
87	04/01/23	Physiology Demo-Room	PHisiology Demo Room In Temporary sound System fitting 16 Amp 2 socket fitting And 2 speaker fitting Ample fire connection	16 Amp socket 16 Amp switch	02 01			Physiology Demo Room
97	05/01/24	PG Hostel	gysar Repairing Reset					600
107	06/01/24	PG Hostel	old LED Remove And New LED fitting	LED	01			601

Manufactured by and Registered office: THE SHREE PAPER MILLS LTD.

Excellent Quality

No.								
11)	8/01/24	Library	Library stock Room in one 2x2 PL	LED 40 watt	01			Stock Room
12)	8/01/24		LED light fitting					
13)	8/01/24	PG Hostel	Table light point repairing					713
14)	8/01/2024	Boys Hostel	old light remove And new LED light fitting	LED	01			013
15)	09/01/2024	Biochemistry	old fan removed And repair fan fitting	fan	01			staff Cubicle
16)	09/01/2024	Girls Hostel	Reading Room in one 2x2. Light Repairing wire joining				55044	Reading Room
17)	10/01/2024	Girls Hostel	TV. Room in one LED repair	LED	01		55044	TV Room
18)	10/01/2024	Girls Hostel	Fan Repairing fan Bleat charge And Regular charge	fan Regular	01 01		55044	105

Manufactured by and Registered office: THE SHRI PURI PAPER MILLS LTD.

Excellent Printability

19	10/01/24	Girls Hostel	Fan Repairing		01	✓	310
20	10/01/24	Girls Hostel	Fan replace		01	✓	314
21	10/01/24	STAFF QUARTER	Fan re Fan replace		01	✓	504
22	10/01/24	MELL	out side pasting Power point remove And ceiling capping path from to Horn there in				504
23	11/01/2024	Staff Quarters	02 old LED light Remove And New LED fitting 2. New Angular Holder fitting Switch Board Properly fitting fan Repairing capacitor change. Bulb fitting	Holder - LED 4 fit. LED Bulb- Capacitor- Holder	02 02 02 03 02		59. 501.
24	11/01/2024	PG Hostel	Fan (ceiling) repairing	Fan	01		419
25	12/01/2024	PG Hostel	old LED set Remove And New LED fitting	LED	01		316-
26	12/01/2024	PG Hostel	old light remove New LED fitting And 01. Switch Board Repairing				

Manufactured by and Registered office: THE SHARDA PAPER MILLS LTD.

Excellent Printability

281	13/01/2024	PG Hostel	Old LED light removal And New LED light socket Panel fitting					
282	15/01/24	PG Hostel	LED Light Replaced	LED	01	Wise	PrEhe	502
	15/01/2024	Boys Host	Fan Replaced	Fan	01	P		402
	16/01/2024	Pharmacy	Pharmacology Dept. Seminar Hall in VGA Cable Replaced ment old cable removal And New 15 mt VGA cable fitting	VGA cable	15 mt	Private		Seminar Hall
	16/01/2024	MELL	MELL New pc. Point Installation 6 modal sundare box fitting And internet cableing Cat 6 cable Inc	6 modal Box Plat Switch socket Cat 6 ca	01 04	Khan HK 16th Jan 2024		<u>MELL</u>
	17/01/24	Library	Elibrary AC Point MCB Repair on And one Hologram LED Propagay fitr			Still center/...		<u>E. Library</u>
	17/01/24	PG Hostel	Fan Regulator Replaced	Regulator	01			<u>311</u>

Manufactured by and Registered office: THE SHREE PAPER MILLS LTD.

Excellent Runnability

Date	Department	Type of work	Use Material	Qty	Sig	Worke	Revised
18/01/24	PG Hostel Hospital G.	Fan Repl-ed	Fan	01	<del>Sig</del>		518
18/01/24	Khoreghar Hostel	Fan Repl-ed (Acoustimberg) fan	Fan	01			<u>Khoreghar</u> <u>411</u>
18/01/24	Boys Hostel	Fan Repl-ed old Remue And Per fire	Fan	01	<del>Sig</del>		401
19/01/24	Girls Hostel.	fan regulator fitting work and capacitor fitting work.	2-Nos-regulator and 1-capacitor	02 01		<del>Sig</del>	<u>214</u>
19/01/24	girls Hostel	fan regulator fitting work.	01-Nos fan regulator fitting work.	01	<del>Sig</del>		<u>414</u>
19/01/24	Boys Hostel	LED Light Ren	LED	01	Sharan		012
23/01/24	Boys Hostel	Fan Repl-ed	Fan	01	Alkalin		213
23/01/24	Canteen	Mess in 1. Exost fan old Remue And New fan PHILIP Type Atthey	Exost fan	01			Mess

Date	Dept.	type of work	use mater	amt	Sig-	Worshn Sta	Room
24/01/24	T. b. Lab-	old Tube Light set Removal And New LED Light fitting	LED -	01			T. b. Lab Wash Room
25/01/24	Canteen	Canteen Dining Hall Banbery Electrical point Repairing 16 Amp combain Box Change And 16 Amp 3 pin Top. chery	combain Box 3 pin Top	01 01			Canteen
25/01/24	Staff canteen	gypsum point Repair L. wire for pro cutting And proper tightly join on					206-
25/01/24	Medical colleg	Republic Day. Ceter Sound System Installation power point Install Sound Speakers Mice All Types Acoustic work. Extension Base making And pro An					Medu- ednes front

27/01/24	Ac. section	Medical college Ac-section Telephone wire Honey' properly clipping And fit	C- Lap	0 QR		Ac s
29/01/24	Girls Hostel	Fan replaced work	01 - Fan	<del>01</del>		
29/01/24	Girls Hostel	Fan capacitor change work.	1 - Fan capacitor	<del>01</del>		
29/01/24	Girls Hostel	Fan replaced work	01 - Fan replacer	<del>01</del>		
29/01/24	U	Tube light. replace	Tube light replace	<del>01</del>		
30/01/24	Canteen	Old Exsost fan female And New flip type fan fitting	Fan Exost	(01)		<u>Mess</u>
30/01/24	PG Hostel	2. Tebebe Light Installation Combein Box wire And Light fit	Combein Box Spin Top Wire LED	02 02 10 mt. 01	Wheeb	302
30/01/24	PG Hostel	Tebebe Light point Arstak Combein Box Light fit	Light Combein Box Spin TOP Wire	01 01 01 03 mt	<del>01</del>	303
30/1/24	PG Hostel	Tube light, plug fixed.	Regulator Combein Box 02, LED Wire - Spin TOP	01 02 02 10 mt. 02 No	<del>01</del>	<u>302</u>

Manufactured by and Registered office: THE SHIPUR PAPER MILLS LTD.

Excellent Runnability



No.	Date	Department	Type of working	Material	Qty	SR	Used	Rain
	8/01/2024	Microbiology	HoD Cabin PG. Electrical Power point fitting 8 maled surface box And. wire. fitting Casing capping path fitting LCD projector Power point fitting VGA. Cable, HDMI Cable fitting	8 modul Box 8 modul Plate 6 Amp. Switch 6 Amp socket Casing path VGA Cable HDMI Wire. Red Wire Blue Wire Green Screws 35x8. Greep	01 01 02 03 04 15 mt 15 mt 30 mt 30 mt 30 mt 1 Box 2 pat			Seminar Hall And <u>HoD Cabin</u>
	31/01/24	P.G. Hostel.	Table board 3-pin plug connection and fan regulator.	① - 3 pin plug. ① - fan regulator	01 01			308
	31/01/24	P.G. Hostel	led tube light fitting work.	01 tube light fitting work.	01			314
	31/01/24	PG. Hostel	Tube light point fitting	Wire. Cable 3 pin Top Combination Box	10 mt 01 01			311
	31/01/24	PG Hostel	Tube Light point fitting	3 pin Top Cable LED	01 05 mt 02			313
	31/01/24	PG Hostel	Tube Light point fitting 3 pin Top fitting	3 pin Top LED	01 01			310
	31/01/24	PG Hostel	Tube Light point fitting	LED 3 pin Top Cable	03 02 05 pat			312

Manufactured by and Registered office: THE SHREE PAPER MILLS LTD.

Excellent Reliability

Date	Dept.	Type of work	use material	Qty	Sig	Worsh Sig	Room
01/02/24	PG Hostel Hospital	one old LED light Remove And New LED fitting Gypsum point Repair	LED	01	<u>Dr. Perias</u>		410
01/02/24	Canteen	belli stimex. Repairing 1. stimex wire Joining And 1. MCB. 2. pol Repairing.	— —				<u>Kitchen</u>
01/02/24	PG Hostel	Tabel light point Installation combu Box fitting And wire	Combuin Box LED Spin Top- wire Rep	02 02 02 07 mt	<u>Sushil</u>		305
01/02/24	PG Hostel	4 New fan Regulator fitting	Regulator-	01	<u>Sushil</u>		304
01/02/24	UG Hostel	Tabel light point New fitting combu Box fitting LED fitting	LED Combu Spin top Cable	01 01 01 05 mt	<u>TAP</u>		301
02/02/24	Microbiology	LED projector Mount stand fitting And projector fitting	Mount stand- Projector	01 01			<u>Micro Seminar Hall</u>

Manufactured by and Registered office: THE SHRI RAMA PAPER MILLS LTD.

Excellent Durability

Date	Dept	Type of work	use material	Qty	SI	Waste	Rate
02/02/2024	University	4th floor Examination Section & outside one Tube Light point Repairing. Neutral wire back. properes Jaming. And one fan regulator problem. Regulator connection. Remove wire one old 2x2 LED. Remove New light fitting. Exam Sec - In side old LED. Remove New fitn	LED 40 watt - 2x2	02			Exam Sec
02/02/24	UG Hostel	gysr point Repairing. Switch change					305
05/02/24	PG Hostel	3rd floor passage Regulator point fitting. 16 amp combain Box fit	combain Box	01			3rd floor passage
06/02/24	Staff Quarters	Holder fitting. Switch Board fitting		01	Making		402
06/02/24	University ICMR	Fan Repairing. Capacitor change	cap	01			ICMR
06/02/24	Girls Hostel	6-AMP Switch replace work	6-AMP Switch	01			

Manufactured by and Registered Office: THE SHREE PAPER MILLS LTD.

Excellent Pinnability

06/02/24	Girls Hostel	1 - fan replaced	1 - fan	01	010	205
06/02/24	Girls Hostel	LED Light Replaced	LED	01	010	213
06/02/24	Girls Hostel	study table light replace	led	01	010	102
07/02/24						
08/02/24	Medical college	Amg dept. seminar hall in old wing hidden cable cutters selling 4 And. of old 2x2 LED fence New LED fitting	LED 2x2	01		7MD
08/02/24	Boys hostel	fan repairing wire proper work				402
09/02/24	Boys hostel	old fan Repair And repaired fan	fan	01	010	505
09/02/24	Boys hostel	fan repairing capacitor ch	capacitor	01	010	501

Date	Dept.	Type of work	use material	Qty	Size	Workn Site	Room
10/02/24	Canteen	Basement mess 04 fans Change old Permonol And repaired fan fitting 1. Combain Box Repair	Fan	04			Mess
13/02/24	PG Hostel Hospital	gysw point Repairing Switch crew	—		5/6		516
12/02/24	PG Hostel	Switch Board proper fitre	—		<del>3/11</del>		311
13/02/24	PG Hostel	2. old LED Light Remove And New LED fit	LED	02	<del>3/11</del>		<u>307</u>
13/02/24	PG Hostel	New LED Tube light Installed	LED	01	<del>3/11</del>		<u>312</u>
14/02/24	Medical Coler 1 <sup>st</sup> floor	Mantra Biometric Machine New Installation 2. power point New Installation 16 Amp combain Box And Cat 6 cable fitting cossing patti fitting	Cossing patti Cat 6 cable Combain Box	02 60mt 02			1 <sup>st</sup> floor

Manufactured by and Registered office: THE SHRI VAHINI PAPER MILLS LTD.

Excellent Runnability

14/02/24

Sq.

one LED Light set  
Replaced-

LED

01

03

15/02/24

Medical  
2nd Lecher Hall

2nd Lecher Hall in  
work shop. Ent.  
Dept. Extension Board  
Assemble Propag  
Heavy Duty  
16 Amp combain Box  
And Cable Joining  
for main panel

Combain Box 1.0 No.

Insulation Tape 02 No.

Cable 6sq.m 60 mt

MicBBox 03 No.

Lecher Hall  
No. 02

15/02/24

Canteen

Sandwich Machine  
point Repairing New  
Combain Box fit

Combain Box 01

Canteen

16/02/24

S.g.

fan regulator fitting

Regul 01

402

16/02/24

Rhythm  
Academy

water Dispenser Mark  
power point New  
Installation 16 Amp  
Combain Box fitting  
And Spin Top 1.5  
Scor Cable  
And main switch Board  
Repairing

Combain Box 01

Cable 3sq.m 100 mt

Spin Top 01

Rhythm  
Academy

Manufactured by and Registered Office: THE SHRI RAM PAPER PRESS LTD.

Excellant Durability

21/02/24

PG Hostel

2nd floor. All floor  
Light Tripping Problem  
304. Room in ghyser  
point falt Spin  
Top Remove And

21/02/24

Boys Hostel

Wardon Cabin ALL  
Nest wiring Cabal  
And starters Remove  
one New Power  
Point fitting

Combin. Box

01

Boys  
Hostel

22/02/24

Tb. Lab-

New pc. point  
fitting 2. power point

Combin Box

02

Tb. Lab

22/02/24

4th floor  
Exam Hall

one old Tube Light  
set Remove And  
New LED Light  
fitting. one old fan  
Remove And New  
Repanel fan fitting

LED

fan

01

01

Exam  
Hall

22/02/24

PG Hostel

Room No. 110 - PG  
Hostel Wash Room  
Main Board Neutral wire  
fine properly jord-ork

110-

28/02/24

4th floor  
Sport Room

2. old fan Remove  
And Repaired fan  
fitting one fan capacitor  
Change And 1. old  
tube light set Panel And  
New LED fitting

fan

capacitor

LED

02

01

01

Sport  
Room  
4th floor

23/02/24	Hospital PG Hostel	gigre point Repairing 3 pin top chage 16 Amp Switch chere 16 Amp socket chug	Spin top 01 16 Amp Socket 01 16 Amp swin 01		422
----------	-----------------------	---	---	--	-----

23/02/24	PG Hostel	old light Remur And New LED fit	LED 01		113
----------	-----------	------------------------------------	--------	--	-----

23/02/24	PG Hostel	Fan Regulator chera old Remur New fit	Fan Regulator 01		312
----------	-----------	---	------------------	--	-----

24/02/24	Canteen	2x2 40 watt sqw Light old Remur And New fitting - 04 no - Acir curtain front from Remur to clining	LED 40 watt 04		
----------	---------	---	----------------	--	--

24/02/24	PG Hostel	Main Switch Board Repairing 6 Amp socket Cherger	6 Amp sockets 01		101
----------	-----------	--	------------------	--	-----

24/02/24	PG Hostel	Rooms for Extract Not worked old wire Remur			107
----------	-----------	---	--	--	-----

24/02/24	PG Hostel	Extrn Empty Cans putti Remur	=		110
----------	-----------	---------------------------------	---	--	-----

Manufactured by and Registered office: THE SHRI RAM PAPER MILLS LTD.

• Excellent Runnability



Date	Department	Type of work	Use material	Qty	Slip	Wash	Room No
26/02/24	MEL	New power point installation 6 modul surface box with plate And 16 Amp combain Box fitting	(Re Reused) 6 modul Box 6 modul Plate Socket Swich Casting path Combin BOX W fitting	01 01 02 02 01 01 5 mt.			<u>MEL</u>
26/02/24	Boys Hall	Fan remove for Repairing	—		<u>Reused</u>		<u>508</u>
26/02/24	Lecher Hall No: 04	1st floor Lecher Hall No: 04 Electrical supply problem Neutral wire cut main panel in. proper wire joining	—				Lecher Hall 04
27/02/24	PG Hostel	gysen point Repairing swith Remove And 16A Moduler MCB fit	MCB	01	<u>Slip</u>		609
28/02/24	Boys Hostel	old fan remove And repaired fan fitting	Fan	01			<u>509</u>
28/2/23	BOYS Hostel	Fan replece work.	1-Fan replece	01	<u>Slip</u>		<u>509</u>
28/2/23	BOY'S Hostel	Fan replece work	Fan replece work	01.	<u>Slip</u>		

Manufactured by and Registered Office: M/s. SRI LANKA PAPER MILLS LTD.

Excellent Durability

28/02/24

PG Hostel

Light point wire switch  
cheesy And  
Gyser point. Are Not unknod  
socket remove

PG.  
107

28/02/24

Boys Hostel

4th floor Wash Rooms  
in Gyser point out side  
fitting pvc pipe hanging  
properly fitting pvc  
saccul fitting

saccul 10 NO  
S... 1 BX  
1 Greeg 1 PC

4th  
floor  
Wash

29/02/24

Staffa

Equip Board  
Ac. point repair  
- socket And MCB  
ch

~~ATB~~

3 of

29/02/24

Canteen

2 old combain Box  
Power point Not  
working Remove  
And New 16 Amp  
fitting

Combain Box 02

can  
Kitchen

29/02/24

PG Hostel

gyser point Repairing  
16 Amp Combain Box  
for 3 pin top 4Hz

~~ATB~~

4 of

Manufactured by and Registered office: THE SIMPSON PARK PAPER MILLS LTD.


Excellent Runnability

4/03/24	PG Hostel	Fan Repair	Fan	01	<del>fan</del>	504
04/03/24	PG Hostel	Fan Repairing capacitor ch	Capacitor	01	<del>allkusti</del>	316
04/03/24	PG Hostel	Fan Repairing capacitor ch <del>Regulator ch</del>	capacitor Regulator	01 01	<del>Regulator</del>	512
05/03/24	Girls Hostel	Fan Repairing	—		<del>fan</del>	211
06/03/24	Girls Hostel	Fan Repairing capacitor ch	capacitor	01	<del>fan</del>	214
06/3/24	Girls Hostel	Fan replace	01 - Fan	01	<del>fan</del>	204
06/3/24	Girls Hostel	Fan repairing	01	01	<del>fan</del>	310
06/03/24	Girls Hostel	old tube light removal and New LED fitting	LED	01	<del>fan</del>	106
06/3/24	Girls Hostel	Fan replace	01 - Fan	01	<del>fan</del>	11
06/03/24	PG Hostel	water cooler spin top fix	Spin-top	01	<del>fan</del>	151 410

06/03/24	PG Hostel	Fan Repairing capacitor change	capacitor	01	<u>Dr. purvi</u>	511
07/03/24	Pharmacology	5. old fans Remove And Repairing fan fitting 3 fans Repairing capacitor change And one fan connection problem solve.	Fans Repairal. capacitor	05 04		<u>Pharm</u>
07/03/24	PSM	one old tube light set Remove And New LED Light fitting Demo Room In old fan Remove And Repairal fan fitting 1. Tube light set Repairing	Fan LED	01 01		PSM
07/03/24	PG Hostel	Fan Repairing Capacitor ch	capac	01	<del>Dr. purvi</del>	504
07/03/24	PG Hostel	Instant cooler Repair				
08/3/24	PG Hostel	Tubelight change	LED	01	<del>Dr. purvi</del>	610 109
8/03/24	Canteen	Kitchen Fan Bk Light point glass Remove. 20 pc				Kick

Manufactured by and Registered Office: THE SHRI RAM & SONS LTD.

Excellent Runnability

09/03/24	T-b-Lab-	old fan remove And Repaired fan fitting	fan	01		T-b box
11/03/24	Staff. @	old Tube Light remove And New LED fitting	LED	01	DR <u>adul</u>	207
11/03/24	Boys hostel	old fan remove And Repaired fan fan Rubber clamp ch	fan Clamp	01 01	adul	510
11/03/24	Canteen	old fan remove And New Atomberg fan fitting 01 fan fitting	fan Atomberg	01		canteen Store
12/03/24	Security check cabin	old LED light rem And New LED fit	LED	01	adul 12/03/24	sc
14/03/24	Boys hostel	fan Repairing L-wire block properly joining				402
15/03/24	Canteen	Wash Basin Anger Repaired fan fitting	fan	01		Canteen

Manufactured by and Registered Office: THE SHRI... PVT. LTD.

Excellent Runnability

15/03/24	university	4th floor Examination section. L-Type Tubul power point connection Disconnect. Lan cable Disconnect. And Record Room In one old Tube light set Remove New LED light fitting fan Repleat. old Remove Repleat fitting Gents wash Room in one old LED light Remove New LED fitting	fan LED-	01 02		university
----------	------------	---	-------------	----------	--	------------

15/03/24	Boy's Hostel	Tube light fixing	01 - Tube light	07		
----------	--------------	-------------------	-----------------	----	--	--

16/03/24	Staff Quarters	Balcony LED Bulb fit And Hook one ceiling fan Repairing capacitor check	Bulb Capac	09 01		301
----------	----------------	--	---------------	----------	--	-----

16/08/24	Lechworth 02	Extension Board fitting A point And connect to Main panel room				Lechworth 02
----------	--------------	---	--	--	--	--------------

18/03/24	Pathology	UPS Extra Power point fitting Capping fitting 6 model surface Box fitting	Surface Box 6 model plate Switch Socket Wire h.o.g.y cassette plate	01 01 02 02 45mt 01		Path Misto patho Lab
----------	-----------	--	--	------------------------------------	--	-------------------------

Manufactured by and Registered office: THE SIMON PAPER MILLS LTD.

Excellent Runnability

18/03/24	Boys Hostel	Worn supply pipes on					209
19/03/24	PG Hostel Hospital	1. Fan Repairing Capacitor change And. of fan old Remy prepared for fit	fan	01	Dr. Anshu Paul		422
			capac	01			
19/03/24	Boys Hostel	Switch Board Repairing	Sw	01			402
19/03/24	Hospital B. PG Hostel	one old fan remove And Repairing fan fitting of fan capacitor change Regulator connection Remove And. Direct Switch connect -	fan	01			506
			Capacit	01			
19/03/24	PG Hostel	Switch Board Repairing					404
					Dr. Vaishnavi J		411
19/03/24	PG Hostel	gysen switch Change 16 Amp MCB fitting	MCB 16-A	01	Dr. Pallan		615
20/03/24	Boys Hostel	Fan Repairing	capacitor	01			208

Manufactured by and registered office: THE SHRI... PAPER MILLS LTD.

Excellent Runnability

20/03/24	Girls Hostel	Tube light Replaced	LED	01	413
20/03/24	Girls Hostel	Fan Repairing Nut Bolt fitting And capacitor change	capacitor	01	510
20/03/24	Girls Hostel	Fan Repairing capacitor change	capacitor	01	511
20/03/24	Girls Hostel	Fan repairing capacitor change	capacitor	01	414
20/03/24	Girls Hostel	Fan Repairing capacitor change	capacitor	01	402
20/03/24	Girls Hostel	Switch Boxel properly fitting	/	/	408
20/03/24	Girls Hostel	Fan Repairing capacitor change	capacitor	01	409
20/03/24	Girls Hostel	capacitor change	capacitor	01	412



02/04/24	Girls Hostel	Fan old remove And Repair fit	Fan	01	<del>Mulla</del> 02/04/24	301
02/04/24	Girls Hostel	Fan Repairing capacitor check	capacitor	<del>02</del> 01	<del>Dalal</del> 02/04/24	01
02/04/24	Girls Hostel	Fan Repairing capacitor check	capacitor	01	<del>NPT</del> 02/04/24	12
02/04/24	Girls Hostel	Switch Board Repair fit			<del>(Signature)</del>	06
02/04/24	Girls Hostel	Fan capacitor	<del>capacitor</del>	01	<del>tekorati</del>	309
02/04/24	Girls Hostel	Fan capacitor	<del>capacitor</del>	01	<del>tekorati</del>	103

08/04/2024	Staff, Quater	Fan replace work 01-NOS.	Fan	01	<del>589</del> <del>8/14/24</del>	
08/04/2024	Crisis Hostel	Fan repair	Fan repair	01-NOS	<del>589</del>	
08/04/24	Crisis Hostel 405	Fan replace work	01 Fan	01	<del>589</del>	
08/04/24	Crisis Hostel 411	1-fan replace work	1-fan	01	<del>589</del>	
8/04/24	PG Hostel	gigs - point Repa			<del>589</del>	305
10/04/24	PG Hostel	Gigs - Switch Chex connection			<del>589</del>	500
10/04/24	Biochemistry	Total g. ceiling fans Repairing Capacitor cheng	Capacitor	08		Demo Room
10/04/24	Crisis Hostel	Fan capacitor replace work.	capacitor	01	<del>589</del>	room 514
10/4/24	Crisis Hostel.	Fan replace work	01-fan	01	<del>589</del>	room 313
10/04/24	PG Hostel	Switch Board Repa			<del>589</del>	607

16/04/24	Girls Hostel	Fan Repairing Regulator con cut			<del>Shri</del>	211
16/04/24	Girls Hostel	Switch Board Propag fire			<del>BSS</del>	408
16/04/24	Girls Hostel	old fan remove And Repair fan fitting	Fan	01	<del>Shri</del>	<u>214</u>
16/04/23	Girls Hostel	Fan Repairing capacitor change	capacitor	02	SUNESA	505
16/04/24	Girls Hostel	Fan Repairing capacitor change	capacitor	01	Kishish	502
16/04/24	Girls Hostel	Fan Repair wire joint			<del>Shri</del>	512
16/04/24	Girls Hostel	Fan Repairing capacitor change	Capacitor	01	<del>Shri</del>	204
16/04/24	Girls Hostel	Fan Repairing gear for	Capacitor	02	<del>Henry</del> <del>Shri</del>	<u>Green</u> <u>400</u>
16/04/24	PG Host	Fan Repair cap change	capacitor	01	<del>Shri</del>	<u>105</u>

Manufactured by and registered office: THE SHRI ON PAPER MILLS LTD.

Excellent Runnability

17/04/24	Staff	Fan repairing capacitor change	Capacitor	01	<del>301</del>	301
18/04/24	Girls Hostel	Fan repairing old fan remove and repaired fan fitting old LED light remove and new LED fitting	Fan LED	01 01	<del>314</del>	<u>314</u>
18/4/24	GIRLS HOSTEL	1- No.1 Fan capacitor change work.	Fan capacitor change work.	01	<del>304</del>	<u>304</u>
18/4/24	==	Fan repair work	Fan repair work	01	<del>10</del>	<u>10</u>
22/04/24	Boys Hostel	Fan repairing and replace tube light repairing	Fan	02	<del>508</del>	508
22/04/24	Boys Hostel	Fan repairing capacitor change	Capacitor	01	<del>407</del>	407
22/4/24	BOYS HOSTEL	fan replace work.	01- Fan	01	<del>410</del>	410
22/04/24	Boys Hostel	old fan remove and repaired fan fitting	Fan	01	<del>206</del>	206
22/04/24	Boys Hostel	Fan repairing		01	<del>210</del>	210

22/04/24	Boys Hostel	Fan Repairing Capacitor Chg	Capacitor	01	<del>Adms</del>	202
24/04/24	Boys Hostel	Fan Repairing Capacitor Chg	capac	01	<del>A</del>	011
23/04/24	Staff Q-	old Tube Light Set Remove And New LED Light fit	LED	01	<del>Piyanka</del>	504
23/4/24	Girls Hostel	Fan replaced work.	01-fan	01	<del>Riya</del>	112
21/5/24	Girls Hostel	Fan replaced work.	01-fan	01	<del>Riya</del>	10
24/05/24	Xtercy programme	Xtercy main Gate fitery And Lighting fitery				
24/05/24	Medical College 2nd. floor	Medical College 2nd floor Tiles work old switch Board And wiring Remove Pathology Wash Room And. Pharmacology Wash Room				2nd floor
25/05/24	Medical College Ground. Xtercy	Xtercy programme 11. Trees Prop Light fitery And Metal case connection Pray				Ground floor

Manufactured by and registered office: TEL: 011-26109551

Excellent Runnability

27/04/24	PG Hostel	old fan remove for repairing	fan	-	201
27/04/24	PG Hostel	fan remove for repairing	—	-	202
27/04/24	PG Hostel	fan remove for repairing	—	-	203
27/04/24	PG Hostel	fan remove for repairing	—	-	204
27/04/24	PG Hostel	fan remove for repairing	—	-	207
27/04/24	PG Hostel	fan remove for repairing	—	-	209
27/04/24	PG Hostel	fan remove for repairing	—	-	210
27/04/24	PG Hostel	fan remove for repairing	—	-	211
27/04/24	PG Hostel	fan remove for repairing	—	-	213
27/04/24	PG Hostel	fan remove for repairing	—	-	216
29/04/24	Staff an	fan repairing capacitor chry	capacitor	-	508

30/04/24	PG Hostel - 2nd floor	2. old Tube light set Remove And New 20 with LED light fitting Repaired ceiling fan fitting wash Room Bulb fitting & Switch Board Repu.	Fan Bulb LED 20 watt	01 01 02	201
30/04/24	PG Hostel 2nd floor.	Repaired ceiling fan fitting 2. New LED light set fitting wash Room Bulb. fit	Fan Bulb LED	01 01 02	202
30/04/24	PG Hostel 2nd floor	2 LED set fitting 1. LED Bulb fitting 1. ceiling fan fit & Switch Board (proper) fit	LED Bulb fan	02 01 01	203
30/04/24	PG Hostel	Fan Repairing fit Repairing wash Room Bulb. fit	Fan Bulb	01 01	204
30/04/24	PG Hostel 2nd floor	Fan Repairing capac Change 2. New LED light fitting wash Room Bulb fit	Capacitor Bulb LED	01 01 02	205
30/04/24	PG Hostel 2nd floor	2. New LED light fitting 1. ceiling fan fit Repairing wash Room Bulb. fit	Fan Bulb LED	01 01 02	207





02/05/24	PG Hostel	Wash Room Bulb fit fan Repairing capacitor check	Bulb- Capacitor	01 01	208
02/05/24	PG Hostel 2nd floor	2. old tube light set Remove And New LED light fit repair fan fit wash room Bulb fitting 2 switch panel repairing socket of switch check	LED Bulb- fan	02 01 01	209
02/05/24	PG Hostel	1. fan repairing capacitor change And of LED light check wash room Bulb check	LED Bulb capacitor	01 01 01	210
02/05/24	PG Hostel	LED light check fan check wash room Bulb check	fan LED	01 01	211
03/05/24	PG Hostel	fan Repairing capacitor change LED light check Bulb check	Bulb capacitor Bulb LED	01 01 01 01	212
03/05/24	PG Hostel	Wash Room Bulb check Combin Box fit of fan check	fan combin box	01 01	213
03/05/24	PG Hostel	fan repair capacitor Bulb check	LED Bulb capacitor Bulb	01 01 01	214



06/05/24	Staff Qu	Fan Repairing Capacitor change	Capacitor	01	<del>Time Rec</del>	406
06/05/24	PG Hostel	gypsum point repairing switch	SWR 16A	01		305
06/05/24	PG Hostel	Fan Repair	Fan	01		109
07/05/24	PG Hostel 4th floor	4th floor passage power point installation New Retziograph Installation	16 Amp. Comb	01		4th floor
7/05/24	Khongher Hostel	Fan Repairing Capacitor change	Capacitor	01		304
07/05/24	Khongher Hostel	Mess Banteng Point Repairing 16 Amp socket Change And 16 Amp 3 pin Top change	16 Amp socket 16 Amp 3 pin Top	01 01		Mess
08/05/24	Anatomy	Anatomy Dissect table changing room In one Celling Fan Installation	Fan Rubber clamp Down Reel	01 01 01		Ann

Manufactured by an registered office: TEL: 01800 103211

Excellent Runnability

08/05/24	Phis Pathology	G. ceiling fan repairing capacitor change	Capacitor	06		Pathology Dept
08/05/24	PG Hostel	Fan Replaced old Remove And Replaced fan fan	Fan	01		505
08/05/24	Statta	Fan capacitor change And SW Board C	Capacitor	01	919 Kirin	308
08/05/24	Microbiology	Fan Replaced old Remove And Replaced fan fitting	Fan	01		Minor Dept
08/05/24	SBS	old SW-Board And wiring casing capping patch Remove the Civil work				SBS-
08/05/24	Girls Hostel	Fan repairing capacitor change	Capacitor	02		403
08/05/24	Girls Hostel	Fan repairing capacitor change	Capacitor	01		208
08/05/24	Girls Hostel	LED light Replaced	LED	01		108

Manufactured by and registered under the Pat. and Trade Mark Act, 1999.

Excellent Runnability

09/05/24	PG Hostel	Fan Repairing capacitor Change And Wash Room Bulb fitting	Capacitor Bulb	01 01		108
09/05/24	PG Hostel	Fan Replaced old Removal And Repair Fan fitting	Fan	01		201
09/05/24	Canteen	Coconut Grander Washing power supply Disconnect. g. Canteen staff room in one ceiling fan Replaced	Fan	01		Staff Room
09/05/24	Bawemissy	old fan remove And Repair. fan fitting	Fan	01		Sta Dept
09/05/24	Microbeury	Cat G. Cable for -	10 mt - cu	10 mt		Mtr
20/05/24	Staff Club	Washing Machine Point- Repairing SWR Change				207
20/05/24	Girls Hostel	Fan Replaced	Fan	01		302
20/05/24	Girls Hostel	Fan capacitor replace work	01 - fan capacitor	01		506

Manufactured by and registered office: THE SING OR PAPER Mills LTD.

Excellent Runnability

22/05/24	PG. Grls Hostel	old fan remove Repaired like	Fan	01	<del>Amur</del>	307
22/05/24	PG - Bhubar	Fan Reptual	Fan	01	<del>Stph</del>	302
22/05/24	PG Hostel	Fan Replecol.	Fan	01	<del>Quashaali</del>	311
23/5/24	Un Hostel	Fan Capacitor	Capacitor	01	<del>Luc</del>	492
23/05/24	Boys Hostel	Fan Repairing Capacitor ch	Capacitor	01	<del>Luc</del>	08
24/05/24	Hospital PG Hostel	Fan Repairing Capacitor ch	Capacitor	02	<del>Luc</del> Nobin	616 715
25/05/24	PG Hostel 3rd Ho	Fan Replecol	Fan	01	<del>Luc</del>	301
25/05/24	Boys Hostel	Fan Replecol	Fan	01	<del>Luc</del>	504
27/05/24	Microbiology	2 Fans Repairing 1 Capacitor change And 1 fan change	Fan Capacitor	01 01		Micro Dema Room
27/05/24	Anatomy	Civil work, 2. Ceiling Light Remove	—			Anatomy History Lab

27/05/24	Biochemistry	Fan repairing capacitor change	capacitor	01		<u>HO Deakin</u>
27/05/24	Physiology	one ceiling fan Replaced	fan	01		Physiology Dept
27/05/24	Boys Hostel	Wash Room, Mirror Side LED light Replaced	LED	01	Paint	1st floor
27/05	Girls Hostel	fan changed atleast 3 times	fan	03	Paint	211
31/05/24	Girls Hostel	fan repairing work	51-fan	01	\$	05
31/05/24	==  ==	3-pin model board wire board	wire properly joint and testing etc	01	Paint	08
31/05/24	==  ==	bulb holder fixing work.	bulb holder fixing	01	Paint	106
31/05/24	==  ==	fan capacitor change work.	fan capacitor replace	01	Paint	111
31/05/24	Imt. Medical college	Medical college Store the internet Cabling 40 mt Cat 6 cable for And 24 port switch	810mt cat 6 24 port sw	210+ 01		Cable fan

01/06/24	Basement	LCD Projector fitting New LCD.	Projector New	01		Seminar Hall
01/06/24	Boys Hostel	Fan Repairing capacitor change	capacitor	01	<del>8</del>	505
03/06/24	Girls Hostel	Fan. Replaced old Removal And repaired fan 412	Fan	02	<del>Blue</del>	204
03/06/24	Boys Hostel	Fan Replaced	Fan	01	AM	413
03/06/24	Girls Hostel	button / switch not to order	Switch	01	8	609
03/06/24	PG Hostel	Switch Board Repairing Switch change	Switch 16 Amp	02	N	613
04/06/24	T.B. Lab	Ceiling Fan Repairing Capacitor change	Capacitor	01		T.B. Lab
04/06/24	Boys Hostel	Switch Board Repairing			PLD	308
05/06/24	Canteen Mess	Mess in Bamberg wiring 3. Bamberg				

\* \* \* \*

Manufactured by and registered office: THE INK OR PAPER INDUSTRIES LTD.

Excellent Runnability

05/06/24	Boys Hostel	Fan repairing capacitor charges	Capacitor	01	<del>214</del>	214
05/06/24	Staff Quarters	3-model board - Pilling work	3-model board	1	<del>108</del>	108
05/06/24	Staff Quarters	LED light project	CLIP set	01	<del>565</del>	565
05/06/24	3rd floor PG Hostel	gypst switch Repair			<del>315</del>	315
06/06/24	S.B.S.	3. Fans. old removed and repaired fan fitting 4. Fan repairing capacitor charges	Fan capacitor	03 04	<del>S.B.S.</del>	S.B.S.
07/06/24	Physiology	Practical Hall in Tubul Tube light set removed and New LED fitting	LED - 18 watt	03	<del>Practical Hall</del>	Practical Hall
07/06/24	Medical college Account office	Old seminar Room in LED projector removed and handwork to store			<del>Records</del>	Records

Manufactured by and registered office: THE UNIT ON THE 5TH FLOOR, 117,

Excellent Runnability

07/06/24	Microbiology	2. Fans Repairing Capacitor change	Capacitors	02		Seminar Hall
8/06/24	Medical college Account section	6. Cat. 6. cable port. connectors And clamping	<del>Capacitors</del>			AC. SC
8/06/24	Hospital Bill	4th floor water cooler point repairing 2. old switch remove And New 16 Amp. switch fitting.	Switch 16 Amp.	02		4th floor
10/06/24	Canteen	spigot repairing main power cable change.	power cable	2 mt.		Office
10/06/24	Boys Hostel	Fan Repair old Remove And Repaired fan fitting	Fan	01	Acknowled	213
12/06/24	girls Hostel	6-AMP socket repair work	6AMP-2-NO	01	Hand	
12/06/24	Girls Hostel pantry	2. same Bad Repairing 2. same change	Switch	02	Service Service	Pantry

Manufactured by and registered under the name of...

Excellent Runnability



14/6/24 PG Hostel

fan repairing

14/06/24 PG Hostel

Power Point Repairing  
2. modul plate  
3. Switer socket  
4. fitey. And 16 Amp  
Socket Change

Capacitor - (1)

614

(Legend)

2. modul plate 01  
Socket - 01  
Switer 01

112

18/06/24	Boys Hostel	Fan repaired	Fan	01	Veelat	214
18/06/24	Boys Hostel	Fan Repair	Fan	01	Py	210
19/06/24	Htp Plant	Batal Cater Machine Repairing				westgate plant
19/06/24	2nd PG Hostel	Switch Board New Wiring	2 model plate Sw Socket	01 01 01	@	203
19/06/24	PG Hostel	Old Light Remove - New LED fit	LED	01	St	213
19/06/24	2nd- PG Hostel	Switch Board New Wiring	2 model plate Socket Sw	01 01 01	July	211
21/06/24	Staff Quarters	one fan removed for repairing one fan shifting And gas point Sw - Board repair			Stu	301

Manufactured by and registered with the Registrar of Companies, India.

Excellent Runnability

21/06/24	SKILL Lab-	Hospital SKILL Lab. 8. New stand fan installation	Stand fan	08		SKILL Lab
21/06/24	Boys Hostel	Fan Replaced	Fan	01		504
22/06/24	Tr. Office	old LED Removal New fitting	LED	01		
26/06/24	P.G. Hostel	New repair fan fitting work	fan	01		108
26/06/24	Girls Hostel	1- New fan installation work	01- New Fan cromptone	01	<del>01</del>	206
26/06/24	Girls Hostel	capacitor replace work	01- capacitor	01	<del>01</del>	203
26/06/24	Girls Hostel	New cromptone fan installation work	New fan installation work	01	<del>01</del>	
27/06/24	Pathology	Old fan Removal And * Examination Hall in Cellar fan for And other fans capacitor change	Fan	01		
28/06/24						

Manufactured by and registered with THE INDIAN AIR CONDITIONING CO.

Excellent Runnability



08/07/24	Girls Hostel	Fan Replaced Old Removal And New Fits	Fan	01		403
08/07/24	Girls Hostel	Switch Box Repairing properly fits				404
08/07/24	Girls Hostel	Fan Repairing Capacitor Change	Capacitor	02		407
08/07/24	==  ==	New Com to me for installation work capacitor 01-N's	New Com to me for installation work	01		211
08/07/24	Girls Hostel	Fan Repairing Capacitor Change	Capacitor	02		201
09/07/24	Upr Hostel -	Fan Replaced	Fan	01		308
09/07/24	UG Hostel	glass point spin Top fit				208
09/07/24	UG Hostel	Switch Box Repairing connection check Holder point				213

Manufactured by Gull registered office: The Mill Lane, Brixton, London SW9 6NU

Excellent Runnability

10/07/24	Staff Q	Fan Repairing				206
10/07/24	Gills Hostel	Fan Repairing capac ch	Capac	01		308
10/07/24	PG Hostel	Fan Replaced old Rem New Fan MW	Fan	01		214
10/07/24	P.G. Hostel	led tube light.	led tube light	01		204
11/07/24	Physiology Seminar Room	New LCD projector Installation Mount & stand fitting HDMI cable fitting VGA cable fitting point to SS combain Box fitting	projector Mount stand VGA HDMI cassings patti combain box 1.5 wire R.G.B.	01 01 15 mt 15 mt 01 01 60 mt		physiology
12/07/24	UG PG. Host	gypsum point Repa Sw ch	Sw	01		305
12/07/24	UG PG Hostel	Fan Repairing capac ch	Capacitor	01		301

15/07/24	PG Hostel	LED Light old Removal New Firm	LED	01	Divide	309
15/7/24	UG Hostel Bays	Fan New fitting	Fan	<del>4</del> 01	<del>Fan</del>	412
17/07/24	PG Hostel	Fan Repairing capac Chm	capac	01	<del>Fan</del>	519
18/07/24	Canteen	grinder Mashing Spin Top fitting	Spin Top -	01		Canteen
19/07/24	Physiology	Clerk Cabin PL lights fitting	TR LED	01		phu
22/07/24	PG Hostel	Fan CHANGE	Fan	01	<del>Fan</del>	109
22/07/24	UG PG Hostel	gypsum point Repairing SW - Change	6 Amp SW	01		305
22/07/24	Staff Quarters	gypsum point Repairing 16 Amp Combin Box 1. gips - Repairing	Combin Box	01		401
22/07/24	Staff Quarters	wash Room Bulb Change	Bulb quartz	01		408
23/07/24	Boy's Hostel	Fan rubber clamp change work.	rubber clamp replace work	01	<del>Fan</del>	308

23/07/24	BOY'S HOSTEL	Fan replace work.	01 - Fan replace	01	<del>Pf</del>	206
23/07/24	BOY'S HOSTEL	1-fan replace and 1-fan repairing	01 - fan replace	02	<del>Pf</del>	44
24/07/24	Khoreghor Hostel	Khoreghor Hostel 215 Rooms No- All power supply cut. Ground for main triper on				215
25/07/24	Zool House university	PL Light Change old 36 watt LED light Rem And New fitting	LED	01		university
25/07/24	BOY'S HOSTEL CRICKETS	Fan repairing work.	Fan oiling properly work done.	01	MHR	13
25/07/24	== 11 ==	Fan capacitor fitting	01 - capacitor	01	<del>Wakan</del>	13
25/7/24	Girls Hostel	Fan and Tubelight not working	working properly		<del>Zabani</del>	210
25/07/24	Girls hostel	Fan repairing capu Chy Sun Basel Pray fit	Capacitor	01	<del>Pf</del>	
25/07/24	== 4 ==	Fan replace work	01 - Fan	01	RIPul	309
25/07/24	== 4 ==	Fan replace work.	01 - fan replace	01	<del>Wakan</del>	411



26/07/24	3rd floor New Demise	3. ceiling fan remove And fan down reel Remove New 5ft Reel fitting for ceiling work	Fan Reel -	03		New Pediatrics
26/07/24	Baromistry	4. ceiling fan old Remove And Repair fan fitting one fan capacitor Change	Fan Capacitor	04 01		Seminar Demo Room
26/07/24	Boys Hostel	Fan repairing work.	Fan repairing work	01	→ [Signature]	
26/07/24	" " "	Tube light fitting	01- Tube light	01	→ T.P.S. →	
26/07/24	Boys Hostel	Fan repairing capacitor change	Capacitor	01	[Signature]	111

31/07/24 PG Hostel  
 Switch Change  
 Geyser point repairs

Switch 01  
 Geyser

31/07/24 PG Hostel  
 Fan repairing  
 capacitor change  
 Switch box repair  
 Switch change

Capacitor 01  
 Sw 01  
 213

31/07/24 PG Hostel  
 Fan Regulator Change  
 old Remove New  
 fitting

Regulator 01  
 E12

01/08/24 Staff Canteen  
 Ceiling fan fitting  
 LED light fitting  
 old LED Dem  
 4 W

LED fan 01  
 01  
 301

01/08/24 Canteen  
 Groceries  
 Ceiling fan old  
 Remove and Repair  
 fan fitting

fan 01  
 Groceries  
 Aniya


01/08/24 PG Hostel  
 Geyser point repair  
 3 pin 4 pin sw  
 3 modular plate socket

16 Amp socket 01  
 16 Amp switch 01  
 3 pin Top 01  
 3 modular plate 01  
 203

02/08/24	3rd floor New Radiology Dept:	3. ceiling fan fitting of connection proper old LED light Removal of New Ply 2x2 LED light fitting LED projector fitting power point fitting HDMI cable fitting	LED projector Socket 6 Amp	03 01 01	3rd floor
03/08/24	Staff G	Fan replaced			206
03/08/24	PG Hostel	old LED light Removal And New LED fitting	LED	01	314
05/08/24	Medical college Accounts Dept.	New pc Electrical point Installation 8 modul box with plate fitting cat 6 cabling Cass pathi fitting	1.5 3 core cable Cassings pathi 8 modul box 8 modul plate 6 Amp switch 16 amp socket	05 root 02 01 01 02 03	Ac Dept-
05/08/24	PG Hostel	Fan Repair	Fan capac	01 01	<u>602</u>

031



315

19/08/24	PG Hostel Hospital	Fan Repair of Repairing	Fan 01 capa - 01		510
19/08/23	PG Hostel	Fan fitting BDC	BDC fan 01	#	409
19/08/24	PG Hostel	Fan Repair	Fan BDC - 01	Nello Dm	415
				rest	210

Manufactured by and registered with the Registrar of Companies, India.

Excellent Runnability



03/09/24	Boys Hostel	waiting Arrives fan replaced	fan	01		waiting fan
03/09/24	PG Hostel	fan replaced BLOC fan	BLOC fan	01		615
03/09/24	UG BOYS HOSTEL	fan replaced	fan	01		009
03/09/24	UG BOYS Hostel	fan replaced old remove fan fitted	fan	01		10
03/09/24	Khoragor Hostel	old LED light remove And New 20 watt LED fitted	LED	01		311
04/09/24	Boys Hostel	fan removed And fan for fan remove fan fitted	fan	01		01
04/09/24	Animal House	CCTV. camera Repairing wire proposed Jailed				

04/09/24 Staff C 2 fans repairing  
capacitor chgs

04/09/24 Boys Hostel  
~~Staff C~~ Fan fitting 2

9/9/24 Boys hostel fan fitting

04/09/24 Boys Hostel Fan Repairing  
capacitor chgs

09/09/24 PG Hostel Hospital Fan repairing  
capacitor chgs

Capacitor 02 ~~py~~ 204

Fan 02 ~~py~~ 111

fan change 1 ~~py~~ 305

Capacitor 02 ~~py~~ 306

Capacitor 01 ~~py~~ 470

19/09/24	Boys Hostel	one fan repairing And 1. fitting Re-	Capacitor fan	01 01		102
19/09/24	Boys Hostel	one ceiling fan fitting	fan	01		103
19/09/24	Boys Hostel	fan replaced	fan	01		104
19/09/24	Boys Hostel	fan repairing capacitor change And old Tube light set remove New LED fit	Capacitor LED	01 01		105
19/09/24	Boys Hostel	fan repairing capacitor ch	Capac	01	01	501
19/09/24	Boys Hostel	fan repairing capacitor change	Capacitor LED	01 01	<del>01</del>	509
20/09/24	Staff canteen	LED Bulb change	9 watt LED	01	<del>01</del>	408
20/09/24	Staff Rm	fan repairing			<del>01</del>	406
20/09/24	Ground Floor New Library	Library room All points. fan light- wiring	wire 1.5 18 modul plate Box pattic	90 mt 01 01		New Lib



21/09/24	PG Hostel	old fan removed And new BLDC fan fitting	Fan BLDC-	01		404 -
20/09/24	PG Hostel	old fan removed and new BLDC fan fitting	Fan	01		408 -
23/09/24	Staff Qu	Wash Room light change & watt LED Bulb fit	LED Bulb	02	<del>Therpa</del>	404
28/09/24	Boys Hostel	1-fan fitting work	01-fan	01	<del>John</del> <del>James</del>	202
27/09/24	Boys Hostel	Fan old removed and repaired fan fit	Fan	01	Mohd	410
24/09/24	Girls Hostel	Fan repairing capacitor ch	Capacitor	01		308

29/10/24	Boys Hostel	Fan fitting LED fan	fan LED	01 01	<del>Shah</del>	114
4/10/24	Boys Hostel	Fan Repairing cap	—		Shah	105
4/10/24	Boys Hostel	Fan fitting del fan	Fan	01	Shah	112
05/10/24	Girls Hostel	Fan capacitor replace.	Fan capacitor fitting	01	Shah	02
05/10/24	= " =	Fan replace work.	01 - fan	01	Shah	06
05/10/24	= " =	Fan replace work.	01 - fan	01	Shah	501
05/10/24	= " =	3-model board fitting	1 - board fitting work	01	Shah	504
05/10/24	= " =	board fitting work	done. 1 - board	01	Rabia	502
05/10/24	= " =	1-fan fitting work.	01 - fan	01	Shah	505

Manufactured by and registered office: THE SHRI VAISHNAVI TRUST, LTD.

Excellent Runnability

05/10/24	Girls Hostel	fan bleed replace work.	fan bleed replace work.	03-bleed	<del>Prakash</del>	506
05/10/24	==U==	01- tube light repair fan capacitor.	01- tube light repair fan capacitor.	01	<del>Prakash</del>	505
05/10/24	==11==	1- fan replace work	01- fan fitting	01	<del>Prakash</del>	508
05/10/24	==11==	switch board connection fitting	switch board connection fitting.	01	<del>Prakash</del>	509
05/10/24	2111=	1- fan fitting work.	01- fan fitting work.	01	<del>Prakash</del>	
05/10/24	==11-	1- fan fitting work.	1- fan fitting work.	01	<del>Prakash</del>	502
05/10/24	Girls Hostel	old fan removal And New fan fixing	fan	01	<del>Prakash</del>	204
05/10/24	Staff Q	Hotlet connection fix			<del>Prakash</del>	107
05/10/24	Staff Q	old fan remove And repaired fan fix	fan capac	01 01	<del>Prakash</del>	501
07/10/24	Girls Hostel	switch Board Rep Sw char	Sw	01	<del>Prakash</del>	503
07/10/24	Girls Hostel	fan replace old fan Damage	fan Bh	01	<del>Prakash</del>	704



10/10/24 New G PG Hostel Fan removed Atomborg old Rem

Fan B1DC - Atomborg 01 ~~301~~ 301

10/10/24 New Girls Hostel old fan removed New Atomborg fan

B1DC Atomborg fan 01 ~~303~~ 303

10/10/24 PG girls hostel ~~old~~ New Fan installation

B1DC Atomborg fan 01 ~~316~~ 316

10/10/24 New Girls PG Hostel old fan removed And New Atomborg fan

Atomborg fan B1DC 01 ~~314~~ 314

10/10/24 PG Hostel old fan removed New Atomborg fan

Atom fan B1DC 01 ~~313~~ 313

10/10/24 New Girls PG Hostel old fan removed of New Atomborg fan

Atomborg B1DC fan 01 ~~310~~ 310

10/10/24 New PG Hostel old fan removed B1DC fan

Fan 01 ~~315~~ 315

10/10/24 PG girls hostel old fan removed new fan fixed

Atomborg fan 01 ~~312~~ 312

10/10/24	New C PG Hostel	old fan Rem And New B1DC fan fit	fan B1DC	01	<u>Jangi</u>	307
14/10/24	Boys Hostel	Fan Repairing And LED light fit	fan B1DC	01	<del>Blouse</del>	301
15/10/24	PG Hostel	old fan Rem New B1DC fan fitting	fan B1DC	01	<u>Blouse</u>	302
15/10/24	PG Hostel	old fan Rem And New B1DC fan fitting	fan B1DC	01	<u>Trap</u>	308
15/10/24	New portion	old fan Rem And New B1DC fan fitting	fan B1DC	01	<u>Divisha</u>	309
15/10/24	PG Hostel	fan replaced old Rem And B1DC fitting	fan B1DC	01	<u>Rushashi</u>	311
15/10/24	PG Hostel	fan old Rem And New B1DC fan fit	B1DC fan	01	<u>Fuh</u>	304