

ACCEPTED MAKES OF MATERIALS

Sl.No.	Item		Approved Makes	Category of Test Certificate/Inspection
A)	FIREFIGHTING			
1.0	Hydrant Valves	i)	Safeguard	2
		ii)	Shah Bhogilal	
		iii)	Wimco	
		iv)	Safex	
		v)	Minimax	
		iv)	Monsher	
		v)	Newage (Surendarnagar)	
2.0	Thermoplastic Hose	i)	Safeguard	2
		ii)	Safex	
		iii)	Shah Bhogilal	
		iv)	Monsher	
		v)	Newage (Surendarnagar)	
		vi)	Minimax	
3.0	Reinforced Rubber Line Hose (63 mm)	i)	CRC	2
		ii)	Nitin fire	
		iii)	Safegaurd	
		iv)	Monsher	
		v)	Newage (Surendarnagar)	
		vi)	Safex,	
		vii)	Minimax	
4.0	Canvas hose and Branch pipe	i)	Newage	2
		ii)	Shah Bhogilal	
		iii)	HD Fire	
		iv)	Safegaurd	
5.0	Sprinklers	i)	Viking	2
		ii)	HD Fire	
		iii)	Tyco	
6.0	Alarm / Deluge Valve	i)	Tyco	2
		ii)	Viking	
		iii)	HD Fire	

7.0	G I/MS Pipes	i)	Tata	3
		ii)	Jindal	
		iii)	Zenith	
8.0	Fittings (Threaded)	i)	Zoloto	3
		ii)	Viking	
9.0	Fittings (Welded)	i)	Gayathri	3
		ii)	Bharatforge	
10.0	Butterfly Valves / Forged Brass Ball Valve	i)	Audco	3
		ii)	Zoloto	
		iii)	Kitz	
		iv)	Leader	
		vi)	Advance	
11.0	Welding Rods	i)	Advani Oerlikon	4
		ii)	Esab	
12.0	Anchor Fastener	i)	Hilti	4
		ii)	Fischer	
13.0	Flexible hose (Sprinkler drop)	i)	Tyco	2
		ii)	Viking	
		iii)	HD Fire	
		iv)	Monsher	
		v)	Nitin Fire	
14.0	Fire Extinguishers	i)	Minimax	2
		ii)	Kanex	
		iii)	Safex	
		iv)	Cease fire	
		v)	Safeguard	
		vi)	Supremex	
15.0	Pipe Supports	i)	Chilly	4
		ii)	Easyflex	
16.0	Flow Switch with Retard (0-60 seconds)	i)	Potter	3
		ii)	Switzer	
		iii)	Honeywell	
		iv)	System Sensor	
17.0	Butterfly/ Ball valve with tamper	i)	Viking	3
		ii)	Victaulic	

	Proof Switch (factory fitted)	iii) iv)	Tyco HD Fire	
18.0	Pressure Switch	i) ii) iii) iv) v)	HD Fire System Sensor Switzer Danfoss Indfos	3
19.0	Drain Valve Assembly	i) ii) iii)	HD Fire Safeguard Shah Bhogilal	3
20.0	PRV	i) ii) iii)	Tyco HD Fire Viking	3
21.0	Air release valve	i) ii) iii)	Claval Audco Lehry	3

CATEGORY REQUIREMENT OF TEST CERTIFICATE/ INSPECTION

CATEGORY-1:

- a) Type test certificate for similar item done. If not, One of the items offered is to be type tested.
- b) OEMs routine test certificate.
- c) Acceptance test to be conducted in the presence of Clients representative at OEMs factory.

CATEGORY - 2:

- a) Type test certificate for similar item done. If not, one of the items offered is to be type tested.
- b) OEMs routine test certificate.
- c) Visual and functional check by Client official at site.

CATEGORY- 3:

- a) OEM/Dealer/Contractor routine test certificate.
- b) Visual and functional check by Client official at site.

CATEGORY - 4:

- a) Visual and functional check by Client official at site.