



**MAHATMA GANDHI MISSION TRUST**  
**MGM INSTITUTE OF HEALTH SCIENCES, CENTRAL PURCHASE DEPARTMENT (CPD)**  
**Plot 1 &2, Sector -1 Kamothe, Navi Mumbai 410209**

**10. Electrical Outdoor Panel**

Tenders invited from reputed manufactures or their authorised distributors / dealers of Electrical Outdoor Panel for MGM Hospital, Kalamboli in the format given below:

**Name & Address of Vendor:** \_\_\_\_\_

Sr. No.	Name of Item	Sr. No.	Description	Qty	Make	Rate Per Item Group ( Excluding GST)	GST %	
1	Electrical Outdoor Panel	<b>A</b>	<b>INCOMER (FROM MSEB)</b>					
		1	R/Y/B Phase Indication Lamp 230V AC	1	L&T			
		2	6A SP 10KA MCB	3	L&T			
		3	400A FP 36KA MCCB Microprocessor Release Release O/L, S/C, E/F Protection with ROHM, Spreader Link	1	L&T			
			<b>INCOMER (FROM DG)</b>					
		1	R/Y/B Phase Indication Lamp 230V AC	1	L&T			
		2	6A SP 10KA MCB	3	L&T			
		3	400A FP 36KA MCCB Microprocessor Release Release O/L, S/C, E/F Protection with ROHM, Spreader Link	1	L&T			
			<b>400A FP ATS FEEDER</b>					
		1	400A FP ATS	1	ELMEASURE			
		2	Multifunction Meter (V, A, F, PF, kW, Kva, kWh)	1	L&T			
		3	400/5A 15VA Class:1 CT's	3	AE			
		4	6A SP 10KA MCB	3	L&T			
	<b>AMF FEEDER</b>							
1	32A DP 10KA MCB	2	L&T					
2	20A Battery Charger (24V DC)	1	Powertron					
3	DC Voltmeter (0-30V Scale)	1	AE					
4	DC Ammeter (0-20A Scale)	1	AE					
5	Hooter 24V DC (96*96mm)	1	Shreem					
6	Hooter Accept Push Button (Black)	1	L&T					
7	Hooter Accept Push Button (Black)	1	L&T					
8	ON-Delay Timer 230V AC	1	L&T					
9	6A Auto/Manual Selector Switch with OFF	1	Kaycee					
10	6A ON/OFF DC Control Selector Switch	1	Kaycee					
11	2Changeover Auxiliary Relay-24V DC	6	PLA					
12	3Changeover Auxiliary Relay-24V DC	1	PLA					
13	Low Oil Pressure Indication Lamp 24V DC (Green)	1	L&T					

Sr. No.	Name of Item	Sr. No.	Description	Qty	Make	Rate Per Item Group ( Excluding GST)	GST %
1	Electrical Outdoor Panel	14	Low Diesel Level Indication Lamp 24V DC (Yellow)	1	L&T		
		15	Low Oil Temp. High Indication Lamp 24V DC (Yellow)	1	L&T		
		16	High Water Temp. Indication Lamp 24V DC (Yellow)	1	L&T		
		17	Engine Over Speed Indication Lamp 24V DC (Yellow)	1	L&T		
		18	DG Start Push Button (Green)	1	L&T		
		19	DG Stop Push Button (Red)	1	L&T		
		20	DG Stop Push Button (Red)	1	L&T		
		<b>B</b>	<b>OUTGOING FEEDER</b>				
1	250A TPN 25KA MCCB Thermal Magnetic Release O/L, S/C Protection with ROHM, Spreader Link	2	L&T				
<b>Grand Total (A+B)</b>							

Kindly email your lowest quotation for above with your terms & conditions as well as applicable brochure / catalog, user list to only etenders@mgmuhs.com

<b>Date:</b>	<b>Signature of Tenderer:</b>
<b>Seal</b>	<b>Name:</b>
	<b>Designation:</b>
	<b>Email ID:</b>
	<b>Mobile No.:</b>
	<b>Full Address:</b>